

Quarterly Groundwater Monitoring Report

Prepared for

Stanley Black & Decker Inc.

Hampstead, Maryland

January 2013

Prepared by

WESTON SOLUTIONS, INC.

West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 4th Quarter 2012.....	2-2
Table 2-2 Groundwater Elevation Data – 4th Quarter 2012.....	2-3
Table 2-3 Effluent Characteristics Summary – 4th Quarter 2012.....	2-4
Table 2-4 Summary of Groundwater Analytical Results - November 2012	2-5
Table 3-1 Treatment System Maintenance Activities – 4th Quarter 2012	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of October through December 2012.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of October through December 2012, the extraction wells were pumping at an average combined rate of approximately 173 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of October through December 2012 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of October through December 2012, approximately 12.7 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (83.1 %) and tetrachloroethene (PCE) (16.9 %). Analytical results of the groundwater collected from the air stripper for the period of October through December 2012 are included in Appendix C.

A summary of the analytical results from the fourth quarter (November 2012) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 4th Quarter 2012
Stanley Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
October 2012	7,327,763
November 2012	7,047,445
December 2012	7,216,348

Table 2-2
Groundwater Elevation Data - 4th Quarter 2012
Stanley Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV.	TOTAL DEPTH	10/10/2012		11/1/2012		12/28/2012	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NC	DRY	NC	DRY	NC
EW-2	849.21	110	93.14	756.07	93.01	756.20	92.88	756.33
EW-3	846.64	118	83.60	763.04	85.95	760.69	85.06	761.58
EW-4	858.01	97.5	PC	NC	PC	NC	PC	NC
EW-5	864.17	98	90.19	773.98	90.22	773.95	89.77	774.40
EW-6	831.98	115	103.00	728.98	103.00	728.98	103.00	728.98
EW-7	818.38	78	73.00	745.38	73.00	745.38	73.00	745.38
EW-8	811.13	98	96.00	715.13	96.00	715.13	96.00	715.13
EW-9	811.35	141	103.50	707.85	103.00	708.35	103.00	708.35
EW-10	807.74	INA	56.11	751.63	55.88	751.86	55.14	752.60
RFW-1A	864.37	78	50.51	813.86	51.51	812.86	51.43	812.94
RFW-1B	864.23	200	50.55	813.68	51.62	812.61	51.44	812.79
RFW-2A	857.41	35	15.12	842.29	13.33	844.08	14.71	842.70
RFW-2B	857.73	75	15.49	842.24	13.45	844.28	15.02	842.71
RFW-3B	839.21	153	31.13	808.08	30.17	809.04	32.41	806.80
RFW-4A	830.37	62	37.44	792.93	37.01	793.36	37.12	793.25
RFW-4B	830.37	120	37.30	793.07	36.81	793.56	36.84	793.53
RFW-5A	817.50	30	DRY	NC	DRY	NC	DRY	NC
RFW-6	785.04	120	2.87	782.17	2.94	782.10	3.67	781.37
RFW-7	805.14	29	6.90	798.24	4.63	800.51	7.55	797.59
RFW-8	860.07	56	DRY	NC	DRY	NC	DRY	NC
RFW-9	862.02	49	26.17	835.85	25.85	836.17	27.11	834.91
RFW-10	852.06	58	DRY	NC	DRY	NC	DRY	NC
RFW-11A	849.32	72	Damaged	NC	Damaged	NC	Damaged	NC
RFW-11B	849.62	116	63.28	786.34	63.41	786.21	63.06	786.56
RFW-12B	844.87	264	50.04	794.83	50.46	794.41	50.14	794.73
RFW-13	849.11	150	61.44	787.67	62.98	786.13	60.86	788.25
RFW-14B	812.39	281	52.03	760.36	52.09	760.30	51.89	760.50
RFW-16	856.14	41	DRY	NC	DRY	NC	DRY	NC
RFW-17	834.66	60.5	25.83	808.83	27.13	807.53	26.20	808.46
RFW-20	842.49	142	34.46	808.03	35.57	806.92	34.13	808.36
RFW-21	832.65	102	20.94	811.71	21.61	811.04	21.41	811.24
PH-7	805.94	89	32.40	773.54	29.53	776.41	29.41	776.53
PH-9	814.94	98	52.26	762.68	51.94	763.00	51.87	763.07
PH-11	820.68	78	49.53	771.15	48.26	772.42	48.73	771.95
PH-12	828.35	87	52.75	775.60	50.98	777.37	51.60	776.75
B-3	803.02	83	10.40	792.62	10.47	792.55	10.83	792.19
Amoco	842.29	INA	NA	NC	NA	NC	NA	NC
Hamp. Town #22	804.96	INA	1.58	803.38	2.19	802.77	0.79	804.17
Pembroke #1	INA	INA	11.43	NC	11.33	NC	11.12	NC
Pembroke #2	INA	INA	Damaged	NC	Damaged	NC	Damaged	NC
N. Houcks. Rd.	INA	INA	9.89	NC	9.53	NC	9.74	NC
E. Century St.	INA	INA	19.22	NC	19.19	NC	19.21	NC
Lwr. Beckleys. Rd.	INA	INA	56.44	NC	55.49	NC	55.77	NC

NA - Not Available/Not Accessible
NC - Not Calculable
INA - Information not available
PC - Pump Cycles

**Table 2-3
Effluent Characteristics Summary - 4th Quarter 2012
Black & Decker
Hampstead, Maryland**

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				October 2012	November 2012	December 2012	
001	FLOW	average	MGD	NA	0.265	0.243	0.222
		maximum	MGD	NA	1.155	0.980	1.128
	1,1,1-Trichloroethane		ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene		ug/l	5	< 1	< 1	< 1
	Trichloroethylene		ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		monthly average	mg/l	10	< 5	< 5	< 5
	pH	minimum	STD	6.0	6.7	7.0	6.7
		maximum	STD	8.5	7.5	7.8	7.9
BOD		mg/l	15	5.0	0.0	5.0	
TSS	maximum	mg/l	30	5.0	4.0	< 1	
	monthly average	mg/l	20	5.0	4.0	< 1	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.220	0.219	0.199
		maximum	MGD	NA	0.265	0.271	0.277
	Fecal Coliform		MPN/100ml	200	5.0	5.0	1.0
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.235
		maximum	MGD	NA	NR	NR	0.284
	1,1,1-Trichloroethane		ug/l	NA	NR	NR	< 1
	Tetrachloroethylene		ug/l	NA	NR	NR	< 1
	Trichloroethylene		ug/l	NA	NR	NR	< 1

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

Table 2-4

Summary of Groundwater Analytical Results - November 2012

Stanley Black & Decker

Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-8 (DUP)	EW-9	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	0.5 J	0.8 J	0.8 J	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3.5	1.7	1 U	1 U	1 U	5.4	24	24	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	200	48	930	110	6.4	3.8	8	8.2	0.6	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	45	1.5	19	3.4	12	8.8	66	67	110	0.6 J
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

NS = Not Sampled

Table 2-4

Summary of Groundwater Analytical Results - November 2012
Stanley Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	NS	2 U	2 U	NS	2 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	0.7 J	0.8 J	0.8 J	4.1	NS	0.8 J	1 U	NS	7.1	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	0.7 J	0.8 J	1.1	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	0.7	0.6	1 U	29	29	34	NS	2	0.5	NS	5.5	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	0.2 J	1 U	1 U	1 U	1 U	NS	1 U	0.2 J	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	0.5 J	20	20	64	NS	2.3	1 U	NS	2.7	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicate sample
NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
J = Indicates an estimated value.

Table 2-4

Summary of Groundwater Analytical Results - November 2012
Stanley Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	USEPA drinking water method 524.2				
												RFW-20	RFW-21	Town #22	Town #23	Trip Blank
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	NS	2 U	ABD	ABD	ABD	2 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	NA	NA	NA	NA	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	1.8	1 J	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trichloroethene	ug/L	NS	2.8	73	2.7	NS	1 U	ABD	ABD	ABD	1 U	0.5	0.5 U	0.5 U	0.5 U	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	1.1	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	1 U	5	17	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.34 J	0.5 U	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	0.1 J	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division.
Samples from all of the other wells are analyzed with USEPA Method 8260.

NS = Not sampled

U = Compound was analyzed but not detected.

ABD = Well has been abandoned

analytical data package is included in Appendix D.

As found in earlier sampling events at the Stanley Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from wells RFW-4B and EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (October through December 2012) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 4th Quarter 2012
Stanley Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Nov-12	Alarm at EW-7. Found that the heating elements were bad. Replaced heating elements, the well is back online.
Dec-12	New wet well probes were installed, system back online.
Dec-12	EW-6 tripped off. It was found that the pump motor was locked up.
Dec-12	EW-6 pump motor was replaced the pump is back online. The pump was off for less than 24 hours.

4. RECOMMENDATIONS

For the reporting period of October through December 2012, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(OCTOBER – DECEMBER 2012)

Superintendent: Earle Villarreal Certification # 1017

Black & Decker WTP

PWSID # 106 0004

County: Carroll

Month: October

Operated by

Address: BTR CAPITAL GROUP, Hampstead, MD 21073

Maryland Environmental Service

625 Hanover Pike, Hampstead, Carroll County, Maryland

Year: 2012

GENERAL			(DOMESTIC WATER)				CHEMICAL					MONITORING		DISTRIBUTION			RAW WATER		Comments	
Date	Day	Weather	Flow meter reading 0	MGD Total FQIR	pH P.O.E	Free Cl2	Na2CO3 Level	Na2CO3 (gpd)	NaOCl Level	NaOCl (gpd)	VOC'S (ppb)	Bacti Pos/Neg	pH su	TRC mg/l	DISTRIBUTION LOCATION	Operator Initials	pH su	TOTAL RAW WATER WELL (mgd)		
1	Mon	Clear	0	0.0025	7.6	1.42	33.00	1.00	53.00	0.00			7.24	1.23	Admin 1st FI	GD		0.250941		
2	Tue	Rain	0	0.0049	7.7	1.43	31.00	2.00	53.00	0.00						GD		0.225202		
3	Wed	Cloudy	0	0.0078	8.2	1.45	28.00	3.00	53.00	0.00			8.17	1.31	Loading Dock	DJ		0.260285		
4	Thur	Cloudy	0	0.0028	7.6	1.26	27.00	1.00	53.00	0.00						DJ	5.08	0.236611		
5	Fri	Clear	0	0.0051	8.0	1.15	25.00	2.00	53.00	0.00			7.7	1.01	Admin 2nd FI	GD		0.222772		
6	Sat	Cloudy	0	0.0025	7.4	1.20	25.00	1.00	53.00	0.00						AP		0.243717		
7	Sun	Rain	0	0.0028	7.3	1.10	24.00	1.00	53.00	0.00						AP		0.230763		
8	Mon	Cloudy	0	0.0027	7.6	1.12	22.00	2.00	53.00	0.00			7.4	1.05	Loading Dock	PP		0.251608		
9	Tue	Clear	0	0.0035	7.2	1.03	51.00	1.00	53.00	0.00						GD		0.225750		
10	Wed	Clear	0	0.0052	7.2	1.10	50.00	1.00	53.00	0.00			7.4	0.85	Loading Dock	JE		0.225961		
11	Thur	Clear	0	0.0057	7.3	1.19	48.00	2.00	53.00	0.00						PP		0.260892		
12	Fri	Clear	0	0.0034	7.6	1.12	47.00	1.00	53.00	0.00			7.5	1.08	Loading Dock	JE	6.56	0.214155		
13	Sat	Clear	0	0.0029	8.7	1.03	46.00	1.00	53.00	0.00						MW		0.253574		
14	Sun	Cloudy	0	0.0023	7.4	1.01	45.00	1.00	53.00	0.00						MW		0.222175		
15	Mon	Rain	0	0.0024	7.4	0.62	42.00	3.00	53.00	0.00						DJ		0.250698		
16	Tue	Clear	0	0.0059	8.8	1.81	39.00	3.00	53.00	0.00			8.3	1.22	Admin 1st FI	DJ		0.238241		
17	Wed	Clear	0	0.0050	8.0	1.28	37.00	2.00	53.00	0.00			8.1	1.26	Admin 2nd FI	DJ		0.230007		
18	Thur	Clear	0	0.0029	7.4	1.16	36.00	1.00	53.00	0.00						DJ	5.74	0.219760	Nitrate 4.20	
19	Fri	Cloudy	0	0.0055	8.0	1.33	34.00	2.00	53.00	0.00			7.9	1.06	Loading Dock	DJ		0.252101		
20	Sat	Clear	0	0.0026	8.1	1.23	33.00	1.00	53.00	0.00						DJ		0.231024		
21	Sun	Clear	0	0.0027	8.0	1.12	32.00	1.00	53.00	0.00						DJ		0.224256		
22	Mon	Clear	0	0.0025	7.6	1.01	31.00	1.00	53.00	0.00			7.3	0.96	Admin 1st FI	GD		0.235220		
23	Tue	Rain	0	0.0036	8.2	0.90	30.00	1.00	53.00	0.00						GD		0.218469		
24	Wed	Cloudy	0	0.0049	7.4	1.02	28.00	2.00	53.00	0.00						AP		0.243304		
25	Thur	Fog	0	0.0045	7.6	0.93	27.00	1.00	53.00	0.00			7.4	0.75	Loading Dock	DJ	5.72	0.234995		
26	Fri	Cloudy	0	0.0079	7.9	1.56	24.00	3.00	53.00	0.00			7.8	1.23	Admin 2nd FI	DJ		0.255816		
27	Sat	Cloudy	0	0.0025	7.6	1.34	23.00	1.00	53.00	0.00						AP		0.236780		
28	Sun	Cloudy	0	0.0023	7.2	1.22	22.00	1.00	53.00	0.00						AP		0.221526		
29	Mon	Rain	0	0.0019	8.7	1.28	21.00	1.00	53.00	0.00			7.1	1.14	Admin 1st FI	PP		0.217817		
30	Tue	Rain	0	0.0008	7.3	1.17	20.00	1.00	53.00	0.00						DJ		0.239216		
31	Wed	Rain	0	0.0053	7.6	1.53	37.00	3.00	53.00	0.00			7.4	1.17	Loading Dock	DJ	5.26	0.254127		
Total				0.1173	239.3	37.12	1018.0	48.00	1643.0	0.00	0.0	0.0	107	15					7.327763	
Average				0.0038	7.72	1.20	32.84	1.55	53.00	0.00	0.0	0.0	7.62	1.09					0.236379	
Minimum				0.0008	7.16	0.62	20.00	1.00	53.00	0.00	0.0	0.0	7.14	0.75					0.214155	Central MOR
Maximum				0.0079	8.76	1.81	51.00	3.00	53.00	0.00	0.0	0.0	8.27	1.31					0.260892	02/02/12

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:
Maryland Environmental Service
259 Najoles Road, Millersville MD

Facility: BTR Capital Group
Address: 626 Hanover Pike, Hampstead Maryland
Additional Op's & cert # - Dorrance Jones 0763, Gary Dickerson 0782

Permit Number: 02-DP-0022
Superintendent: Earle Villarreal

Certification # 1017

Month: November
Year: 2012

Date	Appearance	Final Effluent outfall 001										Outfall 101					Outfall 201				Operator
		Discharge MGD	pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	Discharge mgd	
1	Clear	0.30800	7.10	0.00							0.206000		0.0	1.0	1.0	5.0				0.237123	Djones
2	Clear	0.18900									0.250000	< 1.8	0.0	1.0	1.0	5.0	< 0.4	< 0.2	< 0.3	0.187384	Djones
3	Clear	0.19600									0.208000		0.0	1.0	1.0	5.0				0.284412	Mwhitt
4	Clear	0.15200									0.199000		0.0	1.0	1.0	5.0				0.229958	Mwhitt
5	Clear	0.16100									0.211000		0.0	1.0	1.0	5.0				0.245468	Djones
6	Clear	0.12800	6.97	0.00	< 0.31	< 0.26	< 0.34	< 2.0	4.0	< 5.0	0.216000	< 1.8	0.0	1.0	1.0	5.0				0.221525	Djones
7	Clear	0.12300									0.202000		0.0	1.0	1.0	5.0				0.251772	Djones
8	Clear	0.12400	7.15	0.00							0.220000		0.0	1.0	1.0	5.0				0.215510	Djones
9	Clear	0.10400									0.225000		0.0	1.0	1.0	5.0				0.253116	Djones
10	Clear	0.12000									0.202000		0.0	1.0	1.0	5.0				0.230258	Djones
11	Clear	0.11200									0.205000		0.0	1.0	1.0	5.0				0.228747	Djones
12	Clear	0.12100									0.202000		0.0	1.0	1.0	5.0				0.232649	Jelliott
13	Clear	0.46400	7.21	0.00							0.184000		0.0	1.0	1.0	5.0				0.229450	Jelliott
14	Clear	0.29100									0.226000	< 1.8	0.0	1.0	1.0	5.0				0.254852	Djones
15	Clear	0.14800	6.95	0.00							0.216000		0.0	1.0	1.0	5.0				0.233099	Djones
16	Clear	0.12700									0.216000		0.0	1.0	1.0	5.0				0.234966	Djones
17	Clear	0.12300									0.202000		0.0	1.0	1.0	5.0				0.226444	Aphillips
18	Clear	0.91000									0.190000		0.0	1.0	1.0	5.0				0.229848	Aphillips
19	Clear	0.11000									0.200000		0.0	1.0	1.0	5.0				0.249417	Djones
20	Clear	0.95000	7.10	0.00							0.266000	< 1.8	0.0	1.0	1.0	5.0				0.240668	Djones
21	Clear	0.14700	7.45	0.00							0.205000		0.0	1.0	1.0	5.0				0.228200	Djones
22	Clear	0.13700									0.263000		0.0	1.0	1.0	5.0				0.189039	Jelliott
23	Clear	0.13400									0.271000		0.0	1.0	1.0	5.0				0.254671	Jelliott
24	Clear	0.15300									0.227000		0.0	1.0	1.0	5.0				0.257712	Mwhitt
25	Clear	0.10700									0.227000		0.0	1.0	1.0	5.0				0.218615	Mwhitt
26	Clear	0.98000	7.20	0.00							0.213000		0.0	1.0	1.0	5.0				0.253601	Djones
27	Clear	0.11700									0.239000	4.5	0.0	1.0	1.0	5.0				0.215160	Djones
28	Clear	0.18900									0.202000		0.0	1.0	1.0	5.0				0.250543	Djones
29	Clear	0.17800									0.230000		0.0	1.0	1.0	5.0				0.212002	Djones
30	Clear	0.18800	7.83	0.00							0.250000		0.0	1.0	1.0	5.0				0.251236	Djones
31																					
Total		7.29100									6.573000									7.047445	
Average		0.24303	7.2	<0.10	0	0	0	2	4	0	0.219100	2	0.0	1.0	1.0	5.0	0	0	0	0.234915	
Minimum		0.10400	7.0	0.00	0	0	0	2	4	0	0.184000	1	0.0	1.0	1.0	5.0	0	0	0	0.187384	
Maximum		0.98000	7.8	<0.10	0	0	0	4	4	0	0.271000	5	0.0	1.0	1.0	5.0	0	0	0	0.284412	MOR 5-11-09

COMMENTS:

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operated By:

Facility: BTR Capital Group

Permit Number: 02-DP-0022

Month: December

Maryland Environmental Service

Address: 626 Hanover Pike, Hampstead Maryland

Superintendent: Earle Villarreal

Certification # 1017

Year: 2012

259 Najoles Road, Millersville MD

Additional Op's & cert # - Dorrance Jones 0763, Gary Dickerson 0782, Anthony Phillips 3001, James Elliott 3738, Martin Whitt 0666

Date	Appearance	Final Effluent outfall 001									Outfall 101					Outfall 201			Operator		
		Discharge MGD	pH su	Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l	Trichloroethene ug/l	BOD ₅ mg/l	TSS mg/l	O&G mg/l	Flow MGD	Fecal mpn	Basin Inches	Alum Gpd	Hypochlorite Gpd	Post Cl2 mg/l	Tetrachloroethylene ug/l	1,1,1-Trichloroethane ug/l		Trichloroethene ug/l	Discharge mgd
1	Clear	0.18800								0.219000		0.0	1.0	1.0	5.0				0.227024	Djones	
2	Clear	0.16300								0.234000		0.0	1.0	1.0	5.0				0.225559	Djones	
3	Clear	0.09700								0.224000		0.0	1.0	1.0	5.0				0.235698	Jelliott	
4	Clear	0.05300	7.91	0.00						0.235000	< 1.8	0.0	1.0	1.0	5.0				0.227945	Jelliott	
5	Clear	0.07700								0.200000		0.0	1.0	1.0	5.0				0.216163	Djones	
6	Clear	0.07100	7.30	0.00						0.245000		0.0	1.0	1.0	5.0				0.206937	Djones	
7	Clear	0.10300								0.249000		0.0	1.0	1.0	5.0				0.247664	Djones	
8	Clear	0.18200								0.229000		0.0	1.0	1.0	5.0				0.237983	APhillips	
9	Clear	0.20300								0.219000		0.0	1.0	1.0	5.0				0.237301	APhillips	
10	Clear	0.29100	7.70	0.00						0.203000		0.0	1.0	1.0	5.0				0.249088	Djones	
11	Clear	0.17700			< 1.00	< 1.00	< 1.00	5.0	< 4.0	< 5.0	0.257000	< 1.8	0.0	1.0	1.0	5.0			0.234651	Djones	
12	Clear	0.14200	7.47	0.00						0.237000		0.0	1.0	1.0	5.0				0.232960	Djones	
13	Clear	0.14000								0.251000		0.0	1.0	1.0	5.0				0.217379	Djones	
14	Clear	0.12300								0.277000		0.0	1.0	1.0	5.0				0.246248	Djones	
15	Clear	0.13600								0.236000		0.0	1.0	1.0	5.0				0.238465	Mwhitt	
16	Clear	0.12700								0.220000		0.0	1.0	1.0	5.0				0.224579	Mwhitt	
17	Clear	0.13800								0.229000		0.0	1.0	1.0	5.0				0.240409	Djones	
18	Clear	0.17700	7.20	0.00						0.274000	< 1.8	0.0	1.0	1.0	5.0				0.238276	Djones	
19	Clear	0.11500								0.260000		0.0	1.0	1.0	5.0				0.205794	Djones	
20	Clear	0.12300	6.95	0.00						0.273000		0.0	1.0	1.0	5.0				0.240581	Djones	
21	Clear	0.84000								0.277000		0.0	1.0	1.0	5.0				0.251868	Djones	
22	Clear	0.28200								0.253000		0.0	1.0	1.0	5.0				0.229096	Djones	
23	Clear	0.15600								0.263000		0.0	1.0	1.0	5.0				0.226153	Djones	
24	Clear	0.17800	6.97	0.00						0.214000		0.0	1.0	1.0	5.0				0.238933	Jelliott	
25	Clear	0.21300								0.175000		0.0	1.0	1.0	5.0				0.190946	Jelliott	
26	Clear	0.14100								0.009000		0.0	1.0	1.0	5.0				0.263114	Gdickerson	
27	Clear	1.27800	6.92	0.00						0.000000	< 1.8	0.0	1.0	1.0	5.0				0.241160	Gdickerson	
28	Clear	0.28700								0.003200		0.0	1.0	1.0	5.0				0.235903	Gdickerson	
29	Clear	0.19700								0.000000		0.0	1.0	1.0	5.0				0.234110	APhillips	
30	Clear	0.31400								0.191000		0.0	1.0	1.0	5.0				0.225910	APhillips	
31	Clear	0.17800	6.65	0.00						0.000000		0.0	1.0	1.0	5.0				0.248451	Djones	
Total		6.89000								6.156200									7.216348		
Average		0.22226	7.2	<0.10	0	0	0	5	0	0	0.198587	1	0.0	1.0	1.0	5.0	#DIV/0!	#DIV/0!	#####	0.232785	
Minimum		0.05300	6.7	0.00	0	0	0	5	0	0	0.000000	1	0.0	1.0	1.0	5.0	0	0	0	0.190946	
Maximum		1.27800	7.9	<0.10	0	0	0	5	0	0	0.277000	1	0.0	1.0	1.0	5.0	0	0	0	0.263114	MOR 5-11-09

COMMENTS:

APPENDIX B
DISCHARGE MONITORING REPORTS
(OCTOBER - DECEMBER 2012)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc
 Address 626 Hanover Pike
 Hampstead, MD 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

MONITORING PERIOD

YEAR	MO	DAY	YEAR	MO	DAY
12	10	01	12	10	31
FROM (20-21) (22-23) (24-25)			TO (26-27) (28-29) (30-31)		

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53)			QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	5	(19)	0	ONCE/MONTH	GRAB					
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L		ONCE/MONTH	GRAB					
pH	SAMPLE MEASUREMENT	*****	*****	****	6.7	*****	7.5	(12)	0	TWICE/WEEK	GRAB					
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY MN	*****	8.5 DAILY MX	SU		TWICE/WEEK	GRAB					
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	5	5	(19)	0	ONCE/MONTH	GRAB					
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA AVG.	30 DAILY MX	MG/L		ONCE/MONTH	GRAB					
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	265,000	1,155,000	(07)	*****	*****	*****	0	Measured	RECORD						
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	0	Measured	RECORD						
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/MONTH	GRAB					
CHLORINE, TOTAL RESIDUAL 50060 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG.	0.019 DAILY MX	MG/L		ONCE/MONTH	GRAB					
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB					
TETRACHLOROETHYLENE 34475 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB					
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB					
1,1,1-TRICHLOROETHANE 34506 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/MONTH	GRAB					
EFFLUENT GROSS VALUE	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)															
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	James M. Harkins MES Director	TPI			PHONE			DATE								
TYPED OR PRINTED		410	729-8350	12	11	27										
		AREA CODE	NUMBER	YEAR	MONTH	DAY										
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT														

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name AG/GFI Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address 626 Hanover Pike

MD0001881

001

Approval expires

Hampstead, MD 21074

PERMIT NUMBER

DISCHARGE NUMBER

*** NO DISCHARGE [] ***

Facility Black and Decker WWTP

MONITORING PERIOD

NOTE: Read instructions before completing this form


Location 626 Hanover Pike

YEAR	MO	DAY	YEAR	MO	DAY
12	10	01	12	10	31

State Discharge Permit

02-DP-0022

Attn:

PARAMETER (32-37)		(3 Card Only) (46-53)			QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45)			QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB					
79141 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L	0	ONCE/ MONTH	GRAB					
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(19)	0	ONCE/ MONTH	GRAB					
OIL AND GREASE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	10	MG/L	0	ONCE/ MONTH	GRAB					
TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	15	30DA AVG.	0	ONCE/ MONTH	GRAB					
70030 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	DAILY MX									
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
	SAMPLE MEASUREMENT															
	PERMIT REQUIREMENT															
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)							TELEPHONE		DATE						
James M. Harkins MES Director								410	729-8350	12	11	27				
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MONTH	DAY				

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
12	10	01	12	10	31
FROM				TO	
(20-21)		(22-23) (24-25)		(26-27) (28-29) (30-31)	

State Discharge Permit

02-DP-0022

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	MEASUREMENT	219,803	265,000	(07)	*****	*****	*****	****	0	ONCE/MONTH	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/MONTH	GRAB	
COLIFORM, FECAL GENERAL 74055 1 0 0	MEASUREMENT	*****	*****	****	*****	*****	5	(30)	0	ONCE/WEEK	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX	MPN		ONCE/WEEK	GRAB	
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 551001 AND 33 U.S.C. 55 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)							TFFPHONE		DATE		
James M. Harkins MES Director TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							410	729-8350	12	11	19
								AREA CODE	NUMBER	YFAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	12	11	01		12	11	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(19)	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY/MX	MG/L		ONCE/ MONTH	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	****	7.0	*****	7.8	(12)	0	TWICE/ WEEK	GRAB
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY-MN	*****	8.5 DAILY/MX	SU		TWICE/ WEEK	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	4	4	(19)	0	ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA AVG	30 DAILY MX	MG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	243,033	980,000	(07)	*****	*****	*****	****	0	Measured	RECORD
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	RECORD
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/ MONTH	GRAB
CHLORINE, TOTAL RESIDUAL 50060 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX	MG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE											

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

James M. Harkins

MES Director

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

410

729-8350

12

12

17

AREA CODE

NUMBER

YEAR

MONTH

DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name AG/GFI Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address 626 Hanover Pike

MD0001881

001

Approval expires

Hampstead, MD 21074

PERMIT NUMBER

DISCHARGE NUMBER

*** NO DISCHARGE ***

Facility Black and Decker WWTP

NOTE: Read instructions before completing this form

Location 626 Hanover Pike

MONITORING PERIOD

State Discharge Permit

Attn:

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	12	11	01		12	11	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

02-DP-0022

PARAMETER (32-37)		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS			
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/MONTH	GRAB
79141 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	UG/L		ONCE/MONTH	GRAB
EFFLUENT GROSS VALUE							DAILY/MX				
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/MONTH	GRAB
TOTAL RECOVERABLE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONCE/MONTH	GRAB
70030 1 0 0						30DA:AVG	DAILY/MX				
EFFLUENT GROSS VALUE											
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
		410	729-8350	12	12	17
James M. Harkins MES Director	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MONTH	DAY
TYPED OR PRINTED						

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD

YEAR			MO			DAY		
12	11	01	12	11	30			
(20-21) (22-23) (24-25)			(26-27) (28-29) (30-31)					

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53) QUANTITY OR LOADING (54-61)			(4 Card Only) (38-45) QUALITY OR CONCENTRATION (46-53) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	219,100	271,000	(07)	*****	*****	*****	****	0	ONCE/ MONTH	GRAB
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	5	(30)	0	ONCE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY-MX	MPN		ONCE/ WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
James M. Harkins
MES Director
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
410	729-8350	12	12	17
AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

001

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
12	12	01	12	12	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

FROM

TO

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)		
		(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM				UNITS	
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	5	(19)	0	ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX			ONCE/ MONTH	GRAB	
pH	SAMPLE MEASUREMENT	*****	*****	****	6.7	*****	7.9	(12)	0	TWICE/ WEEK	GRAB	
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	****	6.0 DAILY MIN	*****	8.5 DAILY MX			TWICE/ WEEK	GRAB	
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/ MONTH	GRAB	
SOLIDS, TOTAL SUSPENDED	PERMIT REQUIREMENT	*****	*****	****	*****	20 30DA AVG	30 DAILY MX			ONCE/ MONTH	GRAB	
00530 1 0 0	SAMPLE MEASUREMENT	222,258	1,278,000	(07)	*****	*****	*****		0	Measured	RECORD	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****			Measured	RECORD	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONCE/ MONTH	GRAB	
50050 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	0.011 30DA AVG	0.019 DAILY MX			ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB	
CHLORINE, TOTAL RESIDUAL	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			ONCE/ MONTH	GRAB	
50060 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			ONCE/ MONTH	GRAB	
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB	
34475 1 0 0	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB	
1,1,1-TRICHLOROETHANE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			ONCE/ MONTH	GRAB	
34506 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	5 DAILY MX			ONCE/ MONTH	GRAB	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX			ONCE/ MONTH	GRAB	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)				SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT			TELEPHONE		DATE		
James M. Harkins MES Director								410	729-8350	13	01	18
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Facility Name/Location if different

DISCHARGE MONITORING REPORT (DMR)

Form Approved.

Name AG/GFI Hampstead, Inc

(2-16)

(17-19)

OMB No.

Address 626 Hanover Pike

MD0001881

001

Approval expires

Hampstead, MD 21074

PERMIT NUMBER

DISCHARGE NUMBER

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	12	12	01		12	12	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form


State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) (46-53) QUANTITY OR LOADING			(4 Card Only) (38-45) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	(28)	0	ONCE/ MONTH	GRAB
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5 DAILY MX	UG/L		ONCE/ MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONCE/ MONTH	GRAB
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10 30DA AVG	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
James M. Harkins
MES Director
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 551001 AND 33 U.S.C. 55 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)


SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TFI PHONE		DATE		
410	729-8350	13	01	18
AREA CODE	NUMBER	YFAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

101

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
12	12	01	12	12	31
(20-21)		(22-23)	(24-25)	(26-27)	
(28-29)		(30-31)			

State Discharge Permit

02-DP-0022

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	198,587	277,000	(07)	*****	*****	*****	****	0	ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE COLIFORM, FECAL GENERAL 74055 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	1	(30)	0	ONCE/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200 DAILY MX	MPN		ONCE/ WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.)	TFI PHONE		DATE		
James M. Harkins MES Director TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	410	729-8350	13	01
		AREA CODE	NUMBER	YEAR	MONTH	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

Name AG/GFI Hampstead, Inc.

Address 626 Hanover Pike

Hampstead, MD 21074

Facility Black and Decker WWTP

Location 626 Hanover Pike

Attn:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

MD0001881

201

PERMIT NUMBER

DISCHARGE NUMBER

Form Approved.

OMB No.

Approval expires

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	12	10	01		12	12	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

State Discharge Permit

02-DP-0022

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	MEASUREMENT	234,691	284,412	(07)	*****	*****	*****	****	0	Measured	Record
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****	****		Measured	Record
TETRACHLOROETHYLENE 34475 1 0 0	MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
1,1,1-TRICHLOROETHANE 34506 1 0 0	MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
TRICHLOROETHENE 79141 1 0 0	MEASUREMENT	*****	*****	****	*****	0	0	(28)	0	One/ Quarter	Grab
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT	UG/L		One/ Quarter	Grab
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. SS1001 AND 33 U.S.C. SS 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT OF BETWEEN 6 MONTHS AND 5 YEARS.				TFI PHONE			DATE			
James M. Harkins MES Director TYPED OR PRINTED					410	729-8350	13	01	18		
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				AREA CODE	NUMBER	YEAR	MONTH	DAY		

COMMENT AND EXPANATION OF ANY VIOLATIONS (Reference all attachments here)

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(OCTOBER - DECEMBER 2012)

Account No:AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample Number Sample Description
L4319250-1 FINAL 001 GRAB
Received Date/Time/Temp 10/09/12 05:10pm 6.3 C Iced (Y/N): Y
Samp. Date/Time/Temp Sampled by
10/09/12 08:30am NA C Customer

Parameter Method Result RLs Test Date, Time, Analyst

GENERAL CHEMISTRY

BIOCHEMICAL OXYGEN DEMAND (DELAWARE)	SM 5210B	5.00 mg/l	2.00 mg/l	10/10/12 10:30AM	SKJ
TOTAL SUSPENDED SOLIDS (DELAWARE)	SM 2540D	5.40 mg/l	4.00 mg/l	10/11/12 12:00AM	MS3
HEXANE EXTR.-HEM (OIL+GREASE)	1664A HEM	ND mg/l	5.00 mg/l	10/19/12 12:45PM	RHB

GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES

1,1,1-TRICHLOROETHANE	EPA 624	ND ug/l	1.00 ug/l*	10/18/12 01:17AM	EEW
TRICHLOROETHENE	EPA 624	ND ug/l	1.00 ug/l*	10/18/12 01:17AM	EEW
TETRACHLOROETHENE	EPA 624	ND ug/l	1.00 ug/l*	10/18/12 01:17AM	EEW
DIBROMOFLUOROMETHANE	EPA 624	100 %		10/18/12 01:17AM	EEW
TOLUENE-D8 (SURR)	EPA 624	99 %		10/18/12 01:17AM	EEW
4-BROMOFLUOROBENZENE	EPA 624	102 %		10/18/12 01:17AM	EEW

Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.

Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive

MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.

The test results meet all requirements of NELAC unless otherwise specified.

The report shall not be reproduced except in full without the written consent of the laboratory.

Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.

The reported results relate only to the samples.

All samples are collected as "grab" samples unless otherwise identified.

A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.

The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), Kim Billington (Dairy & Food Microbiology), QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223

State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # : 2515238

E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.

* - The "RLs" represents a reporting/quantitation limit. When an "*" is present in the column identified as the "RLs", it is being reported as a Method Detection Limit (MDL).



Account No:AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample Number Sample Description
L4371563-1 BLACK & DECKER 101
Received Date/Time 11/02/12 11:45am

Samp. Date/Time/Temp Sampled by
10/16/12 09:10am NA C Customer

Parameter	Method	Result	RLs	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY				
FECAL COLIFORM-MPN CEL(DELAWARE)	SM 9221E	4.5 MPN/100ml	MPN/100ml	10/16/12 01:55PM SUB

L4371563-1 :

Fecal coliform was analyzed by Chesapeake Environmental Lab, Inc. in Stevensville, MD.

Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.
Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive
MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.
The test results meet all requirements of NELAC unless otherwise specified.
The report shall not be reproduced except in full without the written consent of the laboratory.
Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.
The reported results relate only to the samples.
All samples are collected as "grab" samples unless otherwise identified.
A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.
The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), Kim Billington (Dairy & Food Microbiology);
QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223
State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # :2515238
E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.



Account No:AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample Number Sample Description Smp. Date/Time/Temp Sampled by
L4358770-1 FINAL 001 GRAB 11/06/12 09:07am NA C Customer
Received Date/Time/Temp 11/06/12 05:00pm 2.2 C Iced (Y/N): Y

Parameter Method Result RLs Test Date, Time, Analyst

GENERAL CHEMISTRY

BIOCHEMICAL OXYGEN DEMAND (DELAWARE)	SM 5210B	ND mg/l	2.00 mg/l	11/07/12 09:10AM	SKJ
TOTAL SUSPENDED SOLIDS (DELAWARE)	SM 2540D	4.00 mg/l	4.00 mg/l	11/07/12 12:00AM	MS3
HEXANE EXTR.-HEM (OIL+GREASE)	1664A HEM	ND mg/l	5.00 mg/l	11/14/12 08:30AM	RHB

GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES

1,1,1-TRICHLOROETHANE	EPA 624	ND ug/l	0.260 ug/l*	11/17/12 04:36PM	DSV
TRICHLOROETHENE	EPA 624	ND ug/l	0.340 ug/l*	11/17/12 04:36PM	DSV
TETRACHLOROETHENE	EPA 624	ND ug/l	0.310 ug/l*	11/17/12 04:36PM	DSV
DIBROMOFLUOROMETHANE	EPA 624	120 %		11/17/12 04:36PM	DSV
TOLUENE-D8 (SURR)	EPA 624	103 %		11/17/12 04:36PM	DSV
4-BROMOFLUOROBENZENE	EPA 624	109 %		11/17/12 04:36PM	DSV

L4358770-1 :

For the BOD 5 test on this day, the nutrient blank was 0.45 mg/l, over the limit of <0.40 mg/l. The nutrient blank was acceptable at 0.90 mg/ml DO depletion and all GGA's were acceptable at 175 mg/l, 178 mg/l, 173 mg/l and 185 mg/l.

Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.

Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive

MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.

The test results meet all requirements of NELAC unless otherwise specified.

The report shall not be reproduced except in full without the written consent of the laboratory.

Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.

The reported results relate only to the samples.

All samples are collected as "grab" samples unless otherwise identified.

A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.

The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), Kim Billington (Dairy & Food Microbiology),

QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223

State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # : 2515238

E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.

* - The "RLs" represents a reporting/quantitation limit. When an "" is present in the column identified as the "RLs", it is being reported as a Method Detection Limit (MDL).



Account No:AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample Number Sample Description
L4419487-1 BLACK & DECKER 101
Received Date/Time 12/11/12 11:15am

Samp. Date/Time/Temp Sampled by
11/27/12 09:05am NA C Customer

Parameter	Method	Result	RLs	Test Date, Time, Analyst
ENVIRONMENTAL MICROBIOLOGY				
FECAL COLIFORM-MPN CEL(DELAWARE)	SM 9221E	4.5 MPN/100ml	MPN/100ml	11/27/12 02:02PM SUB

L4419487-1 :

Fecal coliform was analyzed by Chesapeake Environmental Lab, Inc. in Stevensville, MD.

Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.

Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive

MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.

The test results meet all requirements of NELAC unless otherwise specified.

The report shall not be reproduced except in full without the written consent of the laboratory.

Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.

The reported results relate only to the samples.

All samples are collected as "grab" samples unless otherwise identified.

A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.

The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki

Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), Kim Billington (Dairy & Food Microbiology),

QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223

State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # : 2515238

E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.



Account No:AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample Number Sample Description
L4388616-1 FINAL 001 GRAB
Received Date/Time/Temp 12/11/12 05:15pm 2.4 C Iced (Y/N): Y
Samp. Date/Time/Temp 12/11/12 09:08am NA C
Sampled by Customer

Parameter	Method	Result	RLs	Test Date, Time, Analyst
-----------	--------	--------	-----	--------------------------

GENERAL CHEMISTRY

BIOCHEMICAL OXYGEN DEMAND (DELAWARE)	SM 5210B	5.00 mg/l	2.00 mg/l	12/12/12 07:55AM SKJ
TOTAL SUSPENDED SOLIDS (DELAWARE)	SM 2540D	ND mg/l	4.00 mg/l	12/12/12 12:00AM MS3
HEXANE EXTR.-HEM (OIL+GREASE)	1664A HEM	ND mg/l	5.00 mg/l	12/24/12 01:10PM RHB

GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES

1,1,1-TRICHLOROETHANE	EPA 624	ND ug/l	1.00 ug/l	12/19/12 11:48PM DSV
TRICHLOROETHENE	EPA 624	ND ug/l	1.00 ug/l	12/19/12 11:48PM DSV
TETRACHLOROETHENE	EPA 624	ND ug/l	1.00 ug/l	12/19/12 11:48PM DSV
DIBROMOFLUOROMETHANE	EPA 624	95 %		12/19/12 11:48PM DSV
TOLUENE-D8 (SURRE)	EPA 624	100 %		12/19/12 11:48PM DSV
4-BROMOFLUOROBENZENE	EPA 624	99 %		12/19/12 11:48PM DSV

Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.

Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive

MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.

The test results meet all requirements of NELAC unless otherwise specified.

The report shall not be reproduced except in full without the written consent of the laboratory.

Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.

The reported results relate only to the samples.

All samples are collected as "grab" samples unless otherwise identified.

A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.

The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), Kim Billington (Dairy & Food Microbiology),

QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223

State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # : 2515238

E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.



Account No: AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample Number Sample Description Smp. Date/Time/Temp Sampled by
L4371643-1 BLACK & DECKER FINAL 201 11/02/12 09:07am NA C Customer
Received Date/Time/Temp 11/02/12 04:30pm 4.1 C Iced (Y/N): Y

Parameter Method Result RLs Test Date, Time, Analyst

GAS CHROMATOGRAPHY MASS SPECTROMETRY; VOLATILES

1,1,1-TRICHLOROETHANE	EPA 8260B	ND ug/l	0.210 ug/l*	11/12/12 04:08PM JSH
TRICHLOROETHENE	EPA 8260B	ND ug/l	0.250 ug/l*	11/12/12 04:08PM JSH
TETRACHLOROETHENE	EPA 8260B	ND ug/l	0.370 ug/l*	11/12/12 04:08PM JSH
DIBROMOFLUOROMETHANE	EPA 8260B	98 %		11/12/12 04:08PM JSH
TOLUENE-D8 (SURR)	EPA 8260B	103 %		11/12/12 04:08PM JSH
4-BROMOFLUOROBENZENE	EPA 8260B	101 %		11/12/12 04:08PM JSH

Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLs.

Definitions: NEG=negative; POS=positive; COL=colonies; RLs=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive

MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.

The test results meet all requirements of NELAC unless otherwise specified.

The report shall not be reproduced except in full without the written consent of the laboratory.

Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.

The reported results relate only to the samples.

All samples are collected as "grab" samples unless otherwise identified.

A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.

The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki

Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), Kim Billington (Dairy & Food Microbiology),

QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131, NJ PA166, NY 11223

State ID's: CT PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. #: 2515238

E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.

* - The "RLs" represents a reporting/quantitation limit. When an "" is present in the column identified as the "RLs", it is being reported as a Method Detection Limit (MDL).



Account No:AL0341, MARYLAND ENVIRONMENTAL SERVICE A
Project No: AL0341 BLK DECK WWTP, BLACK & DECKER WWTP

P.O. No:

Inv. No: MES_AL0341
PWSID No:

Sample Number Sample Description Samp. Date/Time/Temp Sampled by
L4435559-1 BLACK & DECKER 101 12/18/12 09:01am NA C Customer
Received Date/Time 12/27/12 10:00am

Parameter Method Result RLS Test Date, Time, Analyst

ENVIRONMENTAL MICROBIOLOGY

FECAL COLIFORM-MPN SM 9221E <1.8 MPN/100ml MPN/100ml 12/18/12 02:25PM SUB
CEL(DELAWARE)

L4435559-1 :

Fecal coliform was analyzed by Chesapeake Environmental Lab, Inc. in Stevensville, MD.

Notes:

A result of "ND" indicates that the analyte tested was either not detected or the concentration was below the RLS.
Definitions: NEG=negative; POS=positive; COL=colonies; RLS=laboratory reporting limits; L/A=laboratory accident; TNTC= Too numerous to count; pres=presumptive
MCL= EPA recommended "maximum contaminant level", PLs = Customer-specific permit limits.
The test results meet all requirements of NELAC unless otherwise specified.
The report shall not be reproduced except in full without the written consent of the laboratory.
Unless otherwise specified, the Environmental and Food Chemistry Testing except field parameters were performed by QC Inc. located at 1205 Industrial Blvd., Southampton, PA 18966; Pharmaceutical, Dairy and Food Microbiological tests were performed by QC Inc. located at 702 Electronic Drive, Horsham, PA 19044.
The reported results relate only to the samples.
All samples are collected as "grab" samples unless otherwise identified.
A result marked with "DRY" indicates that the result was calculated and reported on a dry weight basis.
The following personnel or their deputies have approved the results of the tests performed by QC Inc.: Nicki Smith (Environmental & Food Chemistry), Amanda Lukaszewski (Pharmaceutical), Kim Billington (Dairy & Food Microbiology),
QCL Accreditations: Southampton Div: EPA ID PA00018; NELAP ID's: PA 09-00131; NJ PA166, NY 11223
State ID's: CT.PH-0768, DE PA-018, MD 206, SC 89021001; FDA Reg. # : 2515238
E. Rutherford Div: State ID: NJ 02015; Vineland Div: State ID: NJ 06005; Reading Div: State ID: PA 06-03543

Regulatory authorities are assessing substantial fines for testing omissions. Please track your sample collections and results on a weekly, monthly, or quarterly basis to ensure compliance. QC's internet program 'LIVE ACCESS' will provide you with real-time access to collection dates and results. Please contact Customer Service for further information on acquiring LIVE ACCESS.



APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(NOVEMBER 2012)

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING


ANALYTICAL REPORT

TestAmerica Laboratories, Inc.
TestAmerica Chicago
2417 Bond Street
University Park, IL 60484
Tel: (708)534-5200

TestAmerica Job ID: 500-52022-1
Client Project/Site: Black and Decker

For:
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, Pennsylvania 19380

Attn: Mr. Tom Cornuet



Authorized for release by:
11/19/2012 9:33:02 AM

Richard Wright
Project Manager II
richard.wright@testamericainc.com

LINKS

Review your project
results through

Total Access

Have a Question?

**Ask
The
Expert**

Visit us at:
www.testamericainc.com

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

1

2

4

5

6

7

8

9

10

12

13

14

Table of Contents

Cover Page	1
Table of Contents	2
Case Narrative	3
Detection Summary	4
Method Summary	8
Sample Summary	9
Client Sample Results	10
Definitions	62
QC Association	63
Surrogate Summary	64
QC Sample Results	65
Chronicle	78
Certification Summary	83
Chain of Custody	84
Receipt Checklists	87



Case Narrative

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Job ID: 500-52022-1

Laboratory: TestAmerica Chicago

Narrative

Job Narrative
500-52022-1

Comments

No additional comments.

Receipt

The samples were received on 11/3/2012 11:20 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 2.7° C.

GC/MS VOA

Method(s) 8260B: The following analyte(s) recovered outside control limits for the LCS associated with batch 169122: 2-Chlorotoluene and 4-Chlorotoluene. These analytes are not indicative of a systematic problem and were within the Marginal Exceedance Limits; therefore, the results have been reported and qualified.

No other analytical or quality issues were noted.



Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-52022-1

No Detections

Client Sample ID: RFW-1B

Lab Sample ID: 500-52022-2

No Detections

Client Sample ID: RFW-2A

Lab Sample ID: 500-52022-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.65		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-2B

Lab Sample ID: 500-52022-4

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Benzene	0.16	J	0.50	0.074	ug/L	1		8260B	Total/NA
Trichloroethene	0.61		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-7

Lab Sample ID: 500-52022-5

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Benzene	0.23	J	0.50	0.074	ug/L	1		8260B	Total/NA
Trichloroethene	0.50		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-6

Lab Sample ID: 500-52022-6

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.81	J	1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	2.0		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	2.3		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-17

Lab Sample ID: 500-52022-7

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Benzene	1.1		0.50	0.074	ug/L	1		8260B	Total/NA
o-Xylene	0.14	J	0.50	0.068	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-13

Lab Sample ID: 500-52022-8

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.95	J	1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	2.7		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	17		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-3B

Lab Sample ID: 500-52022-9

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.69	J	1.0	0.12	ug/L	1		8260B	Total/NA
Tetrachloroethene	0.54	J	1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-9

Lab Sample ID: 500-52022-10

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	7.1		1.0	0.12	ug/L	1		8260B	Total/NA

TestAmerica Chicago

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-9 (Continued)

Lab Sample ID: 500-52022-10

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	5.5		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	2.7		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: TRIP BLANK

Lab Sample ID: 500-52022-11

No Detections

Client Sample ID: RFW-4A

Lab Sample ID: 500-52022-12

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.77	J	1.0	0.12	ug/L	1		8260B	Total/NA
Chloroform	0.66	J	1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	29		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	20		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-4A DUP

Lab Sample ID: 500-52022-13

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	0.84	J	1.0	0.12	ug/L	1		8260B	Total/NA
Chloroform	0.76	J	1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	29		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	20		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-4B

Lab Sample ID: 500-52022-14

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	4.1		1.0	0.12	ug/L	1		8260B	Total/NA
Chloroform	1.1		1.0	0.20	ug/L	1		8260B	Total/NA
Trichloroethene	34		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	64		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-11B

Lab Sample ID: 500-52022-15

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	2.8		0.50	0.19	ug/L	1		8260B	Total/NA

Client Sample ID: RFW-12B

Lab Sample ID: 500-52022-16

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	1.8		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	73		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	5.0		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-2

Lab Sample ID: 500-52022-17

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	3.5		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	200		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	45		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-3

Lab Sample ID: 500-52022-18

TestAmerica Chicago

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-3 (Continued)

Lab Sample ID: 500-52022-18

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
cis-1,2-Dichloroethene	1.7		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	48		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	1.5		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-4

Lab Sample ID: 500-52022-19

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Tetrachloroethene	19		1.0	0.17	ug/L	1		8260B	Total/NA
Trichloroethene - DL	930		2.5	0.95	ug/L	5		8260B	Total/NA

Client Sample ID: EW-5

Lab Sample ID: 500-52022-20

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	110		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	3.4		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-6

Lab Sample ID: 500-52022-21

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	6.4		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	12		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-7

Lab Sample ID: 500-52022-22

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethane	0.47	J	1.0	0.19	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	5.4		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	3.8		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	8.8		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-8

Lab Sample ID: 500-52022-23

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethane	0.78	J	1.0	0.19	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	24		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	8.0		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	66		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-8 DUP

Lab Sample ID: 500-52022-24

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
1,1-Dichloroethane	0.75	J	1.0	0.19	ug/L	1		8260B	Total/NA
cis-1,2-Dichloroethene	24		1.0	0.12	ug/L	1		8260B	Total/NA
Trichloroethene	8.2		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	67		1.0	0.17	ug/L	1		8260B	Total/NA

Client Sample ID: EW-9

Lab Sample ID: 500-52022-25

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Trichloroethene	0.56		0.50	0.19	ug/L	1		8260B	Total/NA
Tetrachloroethene	110		1.0	0.17	ug/L	1		8260B	Total/NA

TestAmerica Chicago

Detection Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-10

Lab Sample ID: 500-52022-26

Analyte	Result	Qualifier	RL	MDL	Unit	Dil	Fac	D	Method	Prep Type
Tetrachloroethene	0.58	J	1.0	0.17	ug/L	1			8260B	Total/NA



TestAmerica Chicago

Method Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Method	Method Description	Protocol	Laboratory
8260B	VOC	SW846	TAL CHI

Protocol References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200



TestAmerica Chicago

Sample Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
500-52022-1	RFW-1A	Water	11/01/12 09:10	11/03/12 11:20
500-52022-2	RFW-1B	Water	11/01/12 16:00	11/03/12 11:20
500-52022-3	RFW-2A	Water	11/01/12 10:05	11/03/12 11:20
500-52022-4	RFW-2B	Water	11/01/12 10:15	11/03/12 11:20
500-52022-5	RFW-7	Water	11/01/12 10:55	11/03/12 11:20
500-52022-6	RFW-6	Water	11/01/12 12:10	11/03/12 11:20
500-52022-7	RFW-17	Water	11/01/12 12:50	11/03/12 11:20
500-52022-8	RFW-13	Water	11/01/12 14:35	11/03/12 11:20
500-52022-9	RFW-3B	Water	11/01/12 16:05	11/03/12 11:20
500-52022-10	RFW-9	Water	11/01/12 16:45	11/03/12 11:20
500-52022-11	TRIP BLANK	Water	11/01/12 07:00	11/03/12 11:20
500-52022-12	RFW-4A	Water	11/02/12 08:30	11/03/12 11:20
500-52022-13	RFW-4A DUP	Water	11/02/12 08:30	11/03/12 11:20
500-52022-14	RFW-4B	Water	11/02/12 09:00	11/03/12 11:20
500-52022-15	RFW-11B	Water	11/02/12 11:30	11/03/12 11:20
500-52022-16	RFW-12B	Water	11/02/12 12:30	11/03/12 11:20
500-52022-17	EW-2	Water	11/02/12 12:10	11/03/12 11:20
500-52022-18	EW-3	Water	11/02/12 10:00	11/03/12 11:20
500-52022-19	EW-4	Water	11/02/12 10:35	11/03/12 11:20
500-52022-20	EW-5	Water	11/01/12 09:05	11/03/12 11:20
500-52022-21	EW-6	Water	11/01/12 11:40	11/03/12 11:20
500-52022-22	EW-7	Water	11/01/12 11:35	11/03/12 11:20
500-52022-23	EW-8	Water	11/01/12 11:25	11/03/12 11:20
500-52022-24	EW-8 DUP	Water	11/01/12 11:25	11/03/12 11:20
500-52022-25	EW-9	Water	11/01/12 11:15	11/03/12 11:20
500-52022-26	EW-10	Water	11/01/12 10:45	11/03/12 11:20



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-52022-1

Date Collected: 11/01/12 09:10

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 02:47	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 02:47	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 02:47	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 02:47	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 02:47	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 02:47	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 02:47	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 02:47	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 02:47	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 02:47	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 02:47	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 02:47	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 02:47	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 02:47	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 02:47	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 02:47	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 02:47	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 02:47	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 02:47	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 02:47	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 02:47	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 02:47	1
Trichloroethene	<0.50		0.50	0.19	ug/L			11/09/12 02:47	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 02:47	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 02:47	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 02:47	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 02:47	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 02:47	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 02:47	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 02:47	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 02:47	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 02:47	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 02:47	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 02:47	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 02:47	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 02:47	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 02:47	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 02:47	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 02:47	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 02:47	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 02:47	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 02:47	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 02:47	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 02:47	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 02:47	1
1,1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 02:47	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 02:47	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 02:47	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 02:47	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-52022-1

Date Collected: 11/01/12 09:10

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 02:47	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 02:47	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 02:47	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 02:47	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 02:47	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 02:47	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 02:47	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 02:47	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 02:47	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 02:47	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 02:47	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 02:47	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 02:47	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 02:47	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 02:47	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	99		75 - 131					11/09/12 02:47	1
Toluene-d8 (Surr)	93		80 - 120					11/09/12 02:47	1
4-Bromofluorobenzene (Surr)	91		79 - 120					11/09/12 02:47	1
Dibromofluoromethane	96		74 - 123					11/09/12 02:47	1



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-52022-2

Date Collected: 11/01/12 16:00

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 03:13	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 03:13	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 03:13	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 03:13	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 03:13	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 03:13	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 03:13	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 03:13	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 03:13	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 03:13	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 03:13	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 03:13	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 03:13	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 03:13	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 03:13	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 03:13	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 03:13	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 03:13	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 03:13	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 03:13	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 03:13	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 03:13	1
Trichloroethene	<0.50		0.50	0.19	ug/L			11/09/12 03:13	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 03:13	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 03:13	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 03:13	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 03:13	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 03:13	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 03:13	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 03:13	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 03:13	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 03:13	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 03:13	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 03:13	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 03:13	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 03:13	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:13	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 03:13	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 03:13	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 03:13	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 03:13	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 03:13	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 03:13	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:13	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 03:13	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 03:13	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 03:13	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 03:13	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 03:13	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-1B

Lab Sample ID: 500-52022-2

Date Collected: 11/01/12 16:00

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 03:13	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 03:13	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:13	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:13	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 03:13	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 03:13	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 03:13	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 03:13	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 03:13	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 03:13	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 03:13	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 03:13	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 03:13	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 03:13	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 03:13	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	98		75 - 131					11/09/12 03:13	1
Toluene-d8 (Surr)	95		80 - 120					11/09/12 03:13	1
4-Bromofluorobenzene (Surr)	89		79 - 120					11/09/12 03:13	1
Dibromofluoromethane	97		74 - 123					11/09/12 03:13	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-52022-3

Date Collected: 11/01/12 10:05

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 03:39	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 03:39	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 03:39	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 03:39	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 03:39	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 03:39	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 03:39	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 03:39	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 03:39	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 03:39	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 03:39	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 03:39	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 03:39	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 03:39	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 03:39	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 03:39	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 03:39	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 03:39	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 03:39	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 03:39	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 03:39	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 03:39	1
Trichloroethene	0.65		0.50	0.19	ug/L			11/09/12 03:39	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 03:39	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 03:39	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 03:39	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 03:39	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 03:39	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 03:39	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 03:39	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 03:39	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 03:39	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 03:39	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 03:39	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 03:39	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 03:39	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:39	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 03:39	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 03:39	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 03:39	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 03:39	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 03:39	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 03:39	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:39	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 03:39	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 03:39	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 03:39	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 03:39	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 03:39	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-2A

Lab Sample ID: 500-52022-3

Date Collected: 11/01/12 10:05

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 03:39	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 03:39	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:39	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 03:39	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 03:39	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 03:39	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 03:39	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 03:39	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 03:39	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 03:39	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 03:39	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 03:39	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 03:39	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 03:39	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 03:39	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	97		75 - 131					11/09/12 03:39	1
Toluene-d8 (Surr)	92		80 - 120					11/09/12 03:39	1
4-Bromofluorobenzene (Surr)	92		79 - 120					11/09/12 03:39	1
Dibromofluoromethane	95		74 - 123					11/09/12 03:39	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-52022-4

Date Collected: 11/01/12 10:15

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	0.16	J	0.50	0.074	ug/L			11/09/12 04:05	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 04:05	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 04:05	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 04:05	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 04:05	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 04:05	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 04:05	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 04:05	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 04:05	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 04:05	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 04:05	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 04:05	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 04:05	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 04:05	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 04:05	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 04:05	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 04:05	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 04:05	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 04:05	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 04:05	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 04:05	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 04:05	1
Trichloroethene	0.61		0.50	0.19	ug/L			11/09/12 04:05	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 04:05	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 04:05	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 04:05	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 04:05	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 04:05	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 04:05	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 04:05	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 04:05	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 04:05	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 04:05	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 04:05	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 04:05	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 04:05	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:05	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 04:05	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 04:05	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 04:05	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 04:05	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 04:05	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 04:05	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:05	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 04:05	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 04:05	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 04:05	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 04:05	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 04:05	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-2B

Lab Sample ID: 500-52022-4

Date Collected: 11/01/12 10:15

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 04:05	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 04:05	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:05	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:05	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:05	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:05	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 04:05	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:05	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 04:05	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 04:05	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 04:05	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 04:05	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 04:05	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 04:05	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 04:05	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		75 - 131					11/09/12 04:05	1
Toluene-d8 (Surr)	97		80 - 120					11/09/12 04:05	1
4-Bromofluorobenzene (Surr)	92		79 - 120					11/09/12 04:05	1
Dibromofluoromethane	109		74 - 123					11/09/12 04:05	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-7

Lab Sample ID: 500-52022-5

Date Collected: 11/01/12 10:55

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	0.23	J	0.50	0.074	ug/L			11/09/12 04:30	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 04:30	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 04:30	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 04:30	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 04:30	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 04:30	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 04:30	1
1,1-Dichloroethane	<1.0		1.0	0.31	ug/L			11/09/12 04:30	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 04:30	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 04:30	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 04:30	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 04:30	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 04:30	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 04:30	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 04:30	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 04:30	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 04:30	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 04:30	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 04:30	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 04:30	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 04:30	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 04:30	1
Trichloroethene	0.50		0.50	0.19	ug/L			11/09/12 04:30	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 04:30	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 04:30	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 04:30	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 04:30	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 04:30	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 04:30	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 04:30	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 04:30	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 04:30	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 04:30	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 04:30	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 04:30	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 04:30	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:30	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 04:30	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 04:30	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 04:30	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 04:30	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 04:30	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 04:30	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:30	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 04:30	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 04:30	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 04:30	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 04:30	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 04:30	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-7

Lab Sample ID: 500-52022-5

Date Collected: 11/01/12 10:55

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 04:30	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 04:30	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:30	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:30	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:30	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:30	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 04:30	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:30	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 04:30	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 04:30	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 04:30	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 04:30	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 04:30	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 04:30	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 04:30	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		75 - 131					11/09/12 04:30	1
Toluene-d8 (Surr)	99		80 - 120					11/09/12 04:30	1
4-Bromofluorobenzene (Surr)	95		79 - 120					11/09/12 04:30	1
Dibromofluoromethane	106		74 - 123					11/09/12 04:30	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-6

Lab Sample ID: 500-52022-6

Date Collected: 11/01/12 12:10

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 04:56	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 04:56	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 04:56	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 04:56	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 04:56	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 04:56	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 04:56	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 04:56	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 04:56	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 04:56	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 04:56	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 04:56	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 04:56	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 04:56	1
cis-1,2-Dichloroethene	0.81	J	1.0	0.12	ug/L			11/09/12 04:56	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 04:56	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 04:56	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 04:56	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 04:56	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 04:56	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 04:56	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 04:56	1
Trichloroethene	2.0		0.50	0.19	ug/L			11/09/12 04:56	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 04:56	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 04:56	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 04:56	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 04:56	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 04:56	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 04:56	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 04:56	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 04:56	1
Tetrachloroethene	2.3		1.0	0.17	ug/L			11/09/12 04:56	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 04:56	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 04:56	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 04:56	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 04:56	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:56	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 04:56	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 04:56	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 04:56	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 04:56	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 04:56	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 04:56	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:56	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 04:56	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 04:56	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 04:56	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 04:56	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 04:56	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-6

Lab Sample ID: 500-52022-6

Date Collected: 11/01/12 12:10

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 04:56	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 04:56	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:56	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 04:56	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:56	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:56	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 04:56	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 04:56	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 04:56	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 04:56	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 04:56	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 04:56	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 04:56	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 04:56	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 04:56	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	96		75 - 131					11/09/12 04:56	1
Toluene-d8 (Surr)	93		80 - 120					11/09/12 04:56	1
4-Bromofluorobenzene (Surr)	89		79 - 120					11/09/12 04:56	1
Dibromofluoromethane	95		74 - 123					11/09/12 04:56	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-17

Lab Sample ID: 500-52022-7

Date Collected: 11/01/12 12:50

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	1.1		0.50	0.074	ug/L			11/09/12 05:22	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 05:22	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 05:22	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 05:22	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 05:22	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 05:22	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 05:22	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 05:22	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 05:22	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 05:22	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 05:22	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 05:22	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 05:22	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 05:22	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 05:22	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 05:22	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 05:22	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 05:22	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 05:22	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 05:22	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 05:22	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 05:22	1
Trichloroethene	<0.50		0.50	0.19	ug/L			11/09/12 05:22	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 05:22	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 05:22	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 05:22	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 05:22	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 05:22	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 05:22	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 05:22	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 05:22	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 05:22	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 05:22	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 05:22	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 05:22	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 05:22	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:22	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 05:22	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 05:22	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 05:22	1
o-Xylene	0.14	J	0.50	0.068	ug/L			11/09/12 05:22	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 05:22	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 05:22	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:22	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 05:22	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 05:22	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 05:22	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 05:22	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 05:22	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-17

Lab Sample ID: 500-52022-7

Date Collected: 11/01/12 12:50

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 05:22	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 05:22	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:22	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:22	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 05:22	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 05:22	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 05:22	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 05:22	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 05:22	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 05:22	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 05:22	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 05:22	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 05:22	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 05:22	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 05:22	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	100		75 - 131		11/09/12 05:22	1
Toluene-d8 (Surr)	95		80 - 120		11/09/12 05:22	1
4-Bromofluorobenzene (Surr)	94		79 - 120		11/09/12 05:22	1
Dibromofluoromethane	99		74 - 123		11/09/12 05:22	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-13

Lab Sample ID: 500-52022-8

Date Collected: 11/01/12 14:35

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 05:48	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 05:48	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 05:48	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 05:48	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 05:48	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 05:48	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 05:48	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 05:48	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 05:48	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 05:48	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 05:48	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 05:48	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 05:48	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 05:48	1
cis-1,2-Dichloroethene	0.95	J	1.0	0.12	ug/L			11/09/12 05:48	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 05:48	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 05:48	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 05:48	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 05:48	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 05:48	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 05:48	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 05:48	1
Trichloroethene	2.7		0.50	0.19	ug/L			11/09/12 05:48	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 05:48	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 05:48	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 05:48	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 05:48	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 05:48	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 05:48	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 05:48	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 05:48	1
Tetrachloroethene	17		1.0	0.17	ug/L			11/09/12 05:48	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 05:48	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 05:48	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 05:48	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 05:48	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:48	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 05:48	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 05:48	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 05:48	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 05:48	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 05:48	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 05:48	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:48	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 05:48	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 05:48	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 05:48	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 05:48	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 05:48	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-13

Lab Sample ID: 500-52022-8

Date Collected: 11/01/12 14:35

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 05:48	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 05:48	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:48	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 05:48	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 05:48	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 05:48	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 05:48	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 05:48	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 05:48	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 05:48	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 05:48	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 05:48	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 05:48	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 05:48	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 05:48	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	109		75 - 131					11/09/12 05:48	1
Toluene-d8 (Surr)	103		80 - 120					11/09/12 05:48	1
4-Bromofluorobenzene (Surr)	100		79 - 120					11/09/12 05:48	1
Dibromofluoromethane	106		74 - 123					11/09/12 05:48	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-52022-9

Date Collected: 11/01/12 16:05

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 06:14	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 06:14	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 06:14	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 06:14	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 06:14	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 06:14	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 06:14	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 06:14	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 06:14	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 06:14	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 06:14	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 06:14	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 06:14	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 06:14	1
cis-1,2-Dichloroethene	0.69	J	1.0	0.12	ug/L			11/09/12 06:14	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 06:14	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 06:14	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 06:14	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 06:14	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 06:14	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 06:14	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 06:14	1
Trichloroethene	<0.50		0.50	0.19	ug/L			11/09/12 06:14	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 06:14	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 06:14	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 06:14	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 06:14	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 06:14	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 06:14	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 06:14	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 06:14	1
Tetrachloroethene	0.54	J	1.0	0.17	ug/L			11/09/12 06:14	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 06:14	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 06:14	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 06:14	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 06:14	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:14	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 06:14	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 06:14	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 06:14	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 06:14	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 06:14	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 06:14	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:14	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 06:14	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 06:14	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 06:14	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 06:14	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 06:14	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-3B

Lab Sample ID: 500-52022-9

Date Collected: 11/01/12 16:05

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 06:14	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 06:14	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:14	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:14	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 06:14	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 06:14	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 06:14	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 06:14	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 06:14	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 06:14	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 06:14	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 06:14	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 06:14	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 06:14	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 06:14	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	99		75 - 131					11/09/12 06:14	1
Toluene-d8 (Surr)	96		80 - 120					11/09/12 06:14	1
4-Bromofluorobenzene (Surr)	95		79 - 120					11/09/12 06:14	1
Dibromofluoromethane	101		74 - 123					11/09/12 06:14	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-9

Lab Sample ID: 500-52022-10

Date Collected: 11/01/12 16:45

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 06:40	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 06:40	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 06:40	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 06:40	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 06:40	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 06:40	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 06:40	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 06:40	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 06:40	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 06:40	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 06:40	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 06:40	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 06:40	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 06:40	1
cis-1,2-Dichloroethene	7.1		1.0	0.12	ug/L			11/09/12 06:40	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 06:40	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 06:40	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 06:40	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 06:40	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 06:40	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 06:40	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 06:40	1
Trichloroethene	5.5		0.50	0.19	ug/L			11/09/12 06:40	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 06:40	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 06:40	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 06:40	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 06:40	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 06:40	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 06:40	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 06:40	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 06:40	1
Tetrachloroethene	2.7		1.0	0.17	ug/L			11/09/12 06:40	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 06:40	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 06:40	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 06:40	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 06:40	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:40	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 06:40	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 06:40	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 06:40	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 06:40	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 06:40	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 06:40	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:40	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 06:40	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 06:40	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 06:40	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 06:40	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 06:40	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-9

Lab Sample ID: 500-52022-10

Date Collected: 11/01/12 16:45

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 06:40	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 06:40	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:40	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 06:40	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 06:40	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 06:40	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 06:40	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 06:40	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 06:40	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 06:40	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 06:40	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 06:40	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 06:40	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 06:40	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 06:40	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	100		75 - 131		11/09/12 06:40	1
Toluene-d8 (Surr)	96		80 - 120		11/09/12 06:40	1
4-Bromofluorobenzene (Surr)	91		79 - 120		11/09/12 06:40	1
Dibromofluoromethane	99		74 - 123		11/09/12 06:40	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: TRIP BLANK

Lab Sample ID: 500-52022-11

Date Collected: 11/01/12 07:00

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 07:06	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 07:06	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 07:06	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 07:06	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 07:06	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 07:06	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 07:06	1
1,1-Dichloroethane	<1.0		1.0	0.31	ug/L			11/09/12 07:06	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 07:06	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 07:06	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 07:06	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 07:06	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 07:06	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 07:06	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 07:06	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 07:06	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 07:06	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 07:06	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 07:06	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 07:06	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 07:06	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 07:06	1
Trichloroethene	<0.50		0.50	0.19	ug/L			11/09/12 07:06	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 07:06	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 07:06	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 07:06	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 07:06	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 07:06	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 07:06	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 07:06	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 07:06	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 07:06	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 07:06	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 07:06	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 07:06	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 07:06	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 07:06	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 07:06	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 07:06	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 07:06	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 07:06	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 07:06	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 07:06	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 07:06	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 07:06	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 07:06	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 07:06	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 07:06	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 07:06	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: TRIP BLANK

Lab Sample ID: 500-52022-11

Date Collected: 11/01/12 07:00

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 07:06	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 07:06	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 07:06	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 07:06	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 07:06	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 07:06	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 07:06	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 07:06	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 07:06	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 07:06	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 07:06	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 07:06	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 07:06	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 07:06	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 07:06	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	96		75 - 131					11/09/12 07:06	1
Toluene-d8 (Surr)	93		80 - 120					11/09/12 07:06	1
4-Bromofluorobenzene (Surr)	89		79 - 120					11/09/12 07:06	1
Dibromofluoromethane	95		74 - 123					11/09/12 07:06	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-4A

Lab Sample ID: 500-52022-12

Date Collected: 11/02/12 08:30

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 07:32	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 07:32	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 07:32	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 07:32	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 07:32	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 07:32	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 07:32	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 07:32	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 07:32	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 07:32	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 07:32	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 07:32	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 07:32	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 07:32	1
cis-1,2-Dichloroethene	0.77	J	1.0	0.12	ug/L			11/09/12 07:32	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 07:32	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 07:32	1
Chloroform	0.66	J	1.0	0.20	ug/L			11/09/12 07:32	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 07:32	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 07:32	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 07:32	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 07:32	1
Trichloroethene	29		0.50	0.19	ug/L			11/09/12 07:32	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 07:32	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 07:32	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 07:32	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 07:32	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 07:32	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 07:32	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 07:32	1
1,1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 07:32	1
Tetrachloroethene	20		1.0	0.17	ug/L			11/09/12 07:32	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 07:32	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 07:32	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 07:32	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 07:32	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 07:32	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 07:32	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 07:32	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 07:32	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 07:32	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 07:32	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 07:32	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 07:32	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 07:32	1
1,1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 07:32	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 07:32	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 07:32	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 07:32	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-4A

Lab Sample ID: 500-52022-12

Date Collected: 11/02/12 08:30

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 07:32	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 07:32	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 07:32	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 07:32	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 07:32	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 07:32	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 07:32	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 07:32	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 07:32	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 07:32	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 07:32	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 07:32	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 07:32	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 07:32	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 07:32	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		75 - 131					11/09/12 07:32	1
Toluene-d8 (Surr)	101		80 - 120					11/09/12 07:32	1
4-Bromofluorobenzene (Surr)	94		79 - 120					11/09/12 07:32	1
Dibromofluoromethane	100		74 - 123					11/09/12 07:32	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-4A DUP

Lab Sample ID: 500-52022-13

Date Collected: 11/02/12 08:30

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 07:58	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 07:58	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 07:58	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 07:58	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 07:58	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 07:58	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 07:58	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 07:58	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 07:58	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 07:58	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 07:58	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 07:58	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 07:58	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 07:58	1
cis-1,2-Dichloroethene	0.84	J	1.0	0.12	ug/L			11/09/12 07:58	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 07:58	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 07:58	1
Chloroform	0.76	J	1.0	0.20	ug/L			11/09/12 07:58	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 07:58	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 07:58	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 07:58	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 07:58	1
Trichloroethene	29		0.50	0.19	ug/L			11/09/12 07:58	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 07:58	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 07:58	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 07:58	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 07:58	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 07:58	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 07:58	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 07:58	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 07:58	1
Tetrachloroethene	20		1.0	0.17	ug/L			11/09/12 07:58	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 07:58	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 07:58	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 07:58	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 07:58	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 07:58	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 07:58	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 07:58	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 07:58	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 07:58	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 07:58	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 07:58	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 07:58	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 07:58	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 07:58	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 07:58	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 07:58	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 07:58	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-4A DUP

Lab Sample ID: 500-52022-13

Date Collected: 11/02/12 08:30

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 07:58	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 07:58	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 07:58	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 07:58	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 07:58	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 07:58	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 07:58	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 07:58	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 07:58	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 07:58	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 07:58	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 07:58	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 07:58	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 07:58	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 07:58	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		75 - 131					11/09/12 07:58	1
Toluene-d8 (Surr)	100		80 - 120					11/09/12 07:58	1
4-Bromofluorobenzene (Surr)	96		79 - 120					11/09/12 07:58	1
Dibromofluoromethane	103		74 - 123					11/09/12 07:58	1



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-4B

Lab Sample ID: 500-52022-14

Date Collected: 11/02/12 09:00

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 08:24	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 08:24	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 08:24	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 08:24	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 08:24	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 08:24	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 08:24	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 08:24	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 08:24	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 08:24	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 08:24	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 08:24	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 08:24	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 08:24	1
cis-1,2-Dichloroethene	4.1		1.0	0.12	ug/L			11/09/12 08:24	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 08:24	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 08:24	1
Chloroform	1.1		1.0	0.20	ug/L			11/09/12 08:24	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 08:24	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 08:24	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 08:24	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 08:24	1
Trichloroethene	34		0.50	0.19	ug/L			11/09/12 08:24	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 08:24	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 08:24	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 08:24	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 08:24	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 08:24	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 08:24	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 08:24	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 08:24	1
Tetrachloroethene	64		1.0	0.17	ug/L			11/09/12 08:24	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 08:24	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 08:24	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 08:24	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 08:24	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 08:24	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 08:24	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 08:24	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 08:24	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 08:24	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 08:24	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 08:24	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 08:24	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 08:24	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 08:24	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 08:24	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 08:24	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 08:24	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-4B

Lab Sample ID: 500-52022-14

Date Collected: 11/02/12 09:00

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 08:24	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 08:24	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 08:24	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 08:24	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 08:24	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 08:24	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 08:24	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 08:24	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 08:24	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 08:24	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 08:24	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 08:24	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 08:24	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 08:24	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 08:24	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	108		75 - 131					11/09/12 08:24	1
Toluene-d8 (Surr)	100		80 - 120					11/09/12 08:24	1
4-Bromofluorobenzene (Surr)	100		79 - 120					11/09/12 08:24	1
Dibromofluoromethane	106		74 - 123					11/09/12 08:24	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-11B

Lab Sample ID: 500-52022-15

Date Collected: 11/02/12 11:30

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 09:16	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 09:16	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 09:16	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 09:16	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 09:16	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 09:16	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 09:16	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 09:16	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 09:16	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 09:16	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 09:16	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 09:16	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 09:16	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 09:16	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 09:16	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 09:16	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 09:16	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 09:16	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 09:16	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 09:16	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 09:16	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 09:16	1
Trichloroethene	2.8		0.50	0.19	ug/L			11/09/12 09:16	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 09:16	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 09:16	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 09:16	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 09:16	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 09:16	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 09:16	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 09:16	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 09:16	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 09:16	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 09:16	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 09:16	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 09:16	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 09:16	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 09:16	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 09:16	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 09:16	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 09:16	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 09:16	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 09:16	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 09:16	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 09:16	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 09:16	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 09:16	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 09:16	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 09:16	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 09:16	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-11B

Lab Sample ID: 500-52022-15

Date Collected: 11/02/12 11:30

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 09:16	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 09:16	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 09:16	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 09:16	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 09:16	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 09:16	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 09:16	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 09:16	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 09:16	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 09:16	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 09:16	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 09:16	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 09:16	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 09:16	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 09:16	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	103		75 - 131					11/09/12 09:16	1
Toluene-d8 (Surr)	96		80 - 120					11/09/12 09:16	1
4-Bromofluorobenzene (Surr)	91		79 - 120					11/09/12 09:16	1
Dibromofluoromethane	103		74 - 123					11/09/12 09:16	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-12B

Lab Sample ID: 500-52022-16

Date Collected: 11/02/12 12:30

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 13:51	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 13:51	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 13:51	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 13:51	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 13:51	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 13:51	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 13:51	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 13:51	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 13:51	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 13:51	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 13:51	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 13:51	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 13:51	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 13:51	1
cis-1,2-Dichloroethene	1.8		1.0	0.12	ug/L			11/09/12 13:51	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 13:51	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 13:51	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 13:51	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 13:51	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 13:51	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 13:51	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 13:51	1
Trichloroethene	73		0.50	0.19	ug/L			11/09/12 13:51	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 13:51	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 13:51	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 13:51	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 13:51	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 13:51	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 13:51	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 13:51	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 13:51	1
Tetrachloroethene	5.0		1.0	0.17	ug/L			11/09/12 13:51	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 13:51	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 13:51	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 13:51	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 13:51	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 13:51	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 13:51	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 13:51	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 13:51	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 13:51	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 13:51	1
Bromofom	<1.0		1.0	0.28	ug/L			11/09/12 13:51	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 13:51	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 13:51	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 13:51	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 13:51	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 13:51	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 13:51	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-12B

Lab Sample ID: 500-52022-16

Date Collected: 11/02/12 12:30

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 13:51	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 13:51	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 13:51	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 13:51	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 13:51	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 13:51	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 13:51	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 13:51	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 13:51	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 13:51	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 13:51	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 13:51	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 13:51	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 13:51	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 13:51	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	98		75 - 131					11/09/12 13:51	1
Toluene-d8 (Surr)	97		80 - 120					11/09/12 13:51	1
4-Bromofluorobenzene (Surr)	95		79 - 120					11/09/12 13:51	1
Dibromofluoromethane	93		74 - 123					11/09/12 13:51	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-2

Lab Sample ID: 500-52022-17

Date Collected: 11/02/12 12:10

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 21:35	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 21:35	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 21:35	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 21:35	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 21:35	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 21:35	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 21:35	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 21:35	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 21:35	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 21:35	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 21:35	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 21:35	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 21:35	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 21:35	1
cis-1,2-Dichloroethene	3.5		1.0	0.12	ug/L			11/09/12 21:35	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 21:35	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 21:35	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 21:35	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 21:35	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 21:35	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 21:35	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 21:35	1
Trichloroethene	200		0.50	0.19	ug/L			11/09/12 21:35	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 21:35	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 21:35	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 21:35	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 21:35	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 21:35	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 21:35	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 21:35	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 21:35	1
Tetrachloroethene	45		1.0	0.17	ug/L			11/09/12 21:35	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 21:35	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 21:35	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 21:35	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 21:35	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 21:35	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 21:35	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 21:35	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 21:35	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 21:35	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 21:35	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 21:35	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 21:35	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 21:35	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 21:35	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 21:35	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 21:35	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 21:35	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-2

Lab Sample ID: 500-52022-17

Date Collected: 11/02/12 12:10

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 21:35	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 21:35	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 21:35	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 21:35	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 21:35	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 21:35	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 21:35	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 21:35	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 21:35	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 21:35	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 21:35	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 21:35	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 21:35	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 21:35	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 21:35	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	101		75 - 131		11/09/12 21:35	1
Toluene-d8 (Surr)	95		80 - 120		11/09/12 21:35	1
4-Bromofluorobenzene (Surr)	92		79 - 120		11/09/12 21:35	1
Dibromofluoromethane	95		74 - 123		11/09/12 21:35	1



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-3

Lab Sample ID: 500-52022-18

Date Collected: 11/02/12 10:00

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 15:35	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 15:35	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 15:35	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 15:35	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 15:35	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 15:35	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 15:35	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 15:35	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 15:35	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 15:35	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 15:35	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 15:35	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 15:35	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 15:35	1
cis-1,2-Dichloroethene	1.7		1.0	0.12	ug/L			11/09/12 15:35	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 15:35	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 15:35	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 15:35	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 15:35	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 15:35	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 15:35	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 15:35	1
Trichloroethene	48		0.50	0.19	ug/L			11/09/12 15:35	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 15:35	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 15:35	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 15:35	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 15:35	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 15:35	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 15:35	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 15:35	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 15:35	1
Tetrachloroethene	1.5		1.0	0.17	ug/L			11/09/12 15:35	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 15:35	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 15:35	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 15:35	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 15:35	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 15:35	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 15:35	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 15:35	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 15:35	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 15:35	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 15:35	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 15:35	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 15:35	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 15:35	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 15:35	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 15:35	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 15:35	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 15:35	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-3

Lab Sample ID: 500-52022-18

Date Collected: 11/02/12 10:00

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 15:35	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 15:35	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 15:35	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 15:35	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 15:35	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 15:35	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 15:35	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 15:35	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 15:35	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 15:35	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 15:35	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 15:35	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 15:35	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 15:35	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 15:35	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	95		75 - 131		11/09/12 15:35	1
Toluene-d8 (Surr)	90		80 - 120		11/09/12 15:35	1
4-Bromofluorobenzene (Surr)	94		79 - 120		11/09/12 15:35	1
Dibromofluoromethane	90		74 - 123		11/09/12 15:35	1



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-4

Lab Sample ID: 500-52022-19

Date Collected: 11/02/12 10:35

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 22:00	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 22:00	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 22:00	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 22:00	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 22:00	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 22:00	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 22:00	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 22:00	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 22:00	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 22:00	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 22:00	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 22:00	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 22:00	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 22:00	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 22:00	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 22:00	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 22:00	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 22:00	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 22:00	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 22:00	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 22:00	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 22:00	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 22:00	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 22:00	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 22:00	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 22:00	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 22:00	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 22:00	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 22:00	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 22:00	1
Tetrachloroethene	19		1.0	0.17	ug/L			11/09/12 22:00	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 22:00	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 22:00	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 22:00	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 22:00	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 22:00	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 22:00	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 22:00	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 22:00	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 22:00	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 22:00	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 22:00	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 22:00	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 22:00	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 22:00	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 22:00	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 22:00	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 22:00	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 22:00	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-4

Lab Sample ID: 500-52022-19

Date Collected: 11/02/12 10:35

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chlorotoluene	<1.0	*	1.0	0.20	ug/L			11/09/12 22:00	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 22:00	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 22:00	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 22:00	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 22:00	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 22:00	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 22:00	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 22:00	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 22:00	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 22:00	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 22:00	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 22:00	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 22:00	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 22:00	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	92		75 - 131					11/09/12 22:00	1
Toluene-d8 (Surr)	91		80 - 120					11/09/12 22:00	1
4-Bromofluorobenzene (Surr)	91		79 - 120					11/09/12 22:00	1
Dibromofluoromethane	87		74 - 123					11/09/12 22:00	1

Method: 8260B - VOC - DL

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Trichloroethene	930		2.5	0.95	ug/L			11/09/12 16:27	5
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	101		75 - 131					11/09/12 16:27	5
Toluene-d8 (Surr)	96		80 - 120					11/09/12 16:27	5
4-Bromofluorobenzene (Surr)	96		79 - 120					11/09/12 16:27	5
Dibromofluoromethane	98		74 - 123					11/09/12 16:27	5

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-5

Lab Sample ID: 500-52022-20

Date Collected: 11/01/12 09:05

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 22:27	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 22:27	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 22:27	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 22:27	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 22:27	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 22:27	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 22:27	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 22:27	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 22:27	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 22:27	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 22:27	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 22:27	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 22:27	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 22:27	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 22:27	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 22:27	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 22:27	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 22:27	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 22:27	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 22:27	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 22:27	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 22:27	1
Trichloroethene	110		0.50	0.19	ug/L			11/09/12 22:27	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 22:27	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 22:27	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 22:27	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 22:27	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 22:27	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 22:27	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 22:27	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 22:27	1
Tetrachloroethene	3.4		1.0	0.17	ug/L			11/09/12 22:27	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 22:27	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 22:27	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 22:27	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 22:27	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 22:27	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 22:27	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 22:27	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 22:27	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 22:27	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 22:27	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 22:27	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 22:27	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 22:27	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 22:27	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 22:27	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 22:27	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 22:27	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-5

Lab Sample ID: 500-52022-20

Date Collected: 11/01/12 09:05

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 22:27	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 22:27	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 22:27	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 22:27	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 22:27	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 22:27	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 22:27	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 22:27	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 22:27	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 22:27	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 22:27	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 22:27	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 22:27	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 22:27	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 22:27	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	99		75 - 131					11/09/12 22:27	1
Toluene-d8 (Surr)	98		80 - 120					11/09/12 22:27	1
4-Bromofluorobenzene (Surr)	96		79 - 120					11/09/12 22:27	1
Dibromofluoromethane	93		74 - 123					11/09/12 22:27	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-6

Lab Sample ID: 500-52022-21

Date Collected: 11/01/12 11:40

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 18:11	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 18:11	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 18:11	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 18:11	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 18:11	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 18:11	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 18:11	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 18:11	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 18:11	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 18:11	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 18:11	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 18:11	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 18:11	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 18:11	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 18:11	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 18:11	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 18:11	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 18:11	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 18:11	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 18:11	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 18:11	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 18:11	1
Trichloroethene	6.4		0.50	0.19	ug/L			11/09/12 18:11	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 18:11	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 18:11	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 18:11	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 18:11	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 18:11	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 18:11	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 18:11	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 18:11	1
Tetrachloroethene	12		1.0	0.17	ug/L			11/09/12 18:11	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 18:11	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 18:11	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 18:11	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 18:11	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 18:11	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 18:11	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 18:11	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 18:11	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 18:11	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 18:11	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 18:11	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 18:11	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 18:11	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 18:11	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 18:11	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 18:11	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 18:11	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-6

Lab Sample ID: 500-52022-21

Date Collected: 11/01/12 11:40

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 18:11	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 18:11	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 18:11	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 18:11	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 18:11	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 18:11	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 18:11	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 18:11	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 18:11	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 18:11	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 18:11	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 18:11	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 18:11	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 18:11	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 18:11	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	103		75 - 131					11/09/12 18:11	1
Toluene-d8 (Surr)	98		80 - 120					11/09/12 18:11	1
4-Bromofluorobenzene (Surr)	96		79 - 120					11/09/12 18:11	1
Dibromofluoromethane	100		74 - 123					11/09/12 18:11	1



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-7
Date Collected: 11/01/12 11:35
Date Received: 11/03/12 11:20

Lab Sample ID: 500-52022-22
Matrix: Water

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	DII Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 18:38	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 18:38	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 18:38	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 18:38	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 18:38	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 18:38	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 18:38	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 18:38	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 18:38	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 18:38	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 18:38	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 18:38	1
1,1-Dichloroethane	0.47	J	1.0	0.19	ug/L			11/09/12 18:38	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 18:38	1
cis-1,2-Dichloroethene	5.4		1.0	0.12	ug/L			11/09/12 18:38	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 18:38	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 18:38	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 18:38	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 18:38	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 18:38	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 18:38	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 18:38	1
Trichloroethene	3.8		0.50	0.19	ug/L			11/09/12 18:38	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 18:38	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 18:38	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 18:38	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 18:38	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 18:38	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 18:38	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 18:38	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 18:38	1
Tetrachloroethene	8.8		1.0	0.17	ug/L			11/09/12 18:38	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 18:38	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 18:38	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 18:38	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 18:38	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 18:38	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 18:38	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 18:38	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 18:38	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 18:38	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 18:38	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 18:38	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 18:38	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 18:38	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 18:38	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 18:38	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 18:38	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 18:38	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-7

Lab Sample ID: 500-52022-22

Date Collected: 11/01/12 11:35

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 18:38	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 18:38	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 18:38	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 18:38	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 18:38	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 18:38	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 18:38	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 18:38	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 18:38	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 18:38	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 18:38	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 18:38	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 18:38	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 18:38	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 18:38	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		75 - 131					11/09/12 18:38	1
Toluene-d8 (Surr)	99		80 - 120					11/09/12 18:38	1
4-Bromofluorobenzene (Surr)	95		79 - 120					11/09/12 18:38	1
Dibromofluoromethane	97		74 - 123					11/09/12 18:38	1



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-8

Lab Sample ID: 500-52022-23

Date Collected: 11/01/12 11:25

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 19:03	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 19:03	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 19:03	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 19:03	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 19:03	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 19:03	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 19:03	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 19:03	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 19:03	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 19:03	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 19:03	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 19:03	1
1,1-Dichloroethane	0.78	J	1.0	0.19	ug/L			11/09/12 19:03	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 19:03	1
cis-1,2-Dichloroethene	24		1.0	0.12	ug/L			11/09/12 19:03	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 19:03	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 19:03	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 19:03	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 19:03	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 19:03	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 19:03	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 19:03	1
Trichloroethene	8.0		0.50	0.19	ug/L			11/09/12 19:03	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 19:03	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 19:03	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 19:03	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 19:03	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 19:03	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 19:03	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 19:03	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 19:03	1
Tetrachloroethene	66		1.0	0.17	ug/L			11/09/12 19:03	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 19:03	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 19:03	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 19:03	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 19:03	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 19:03	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 19:03	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 19:03	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 19:03	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 19:03	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 19:03	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 19:03	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 19:03	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 19:03	1
1,1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 19:03	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 19:03	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 19:03	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 19:03	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-8

Lab Sample ID: 500-52022-23

Date Collected: 11/01/12 11:25

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 19:03	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 19:03	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 19:03	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 19:03	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 19:03	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 19:03	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 19:03	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 19:03	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 19:03	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 19:03	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 19:03	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 19:03	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 19:03	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 19:03	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 19:03	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	100		75 - 131					11/09/12 19:03	1
Toluene-d8 (Surr)	97		80 - 120					11/09/12 19:03	1
4-Bromofluorobenzene (Surr)	92		79 - 120					11/09/12 19:03	1
Dibromofluoromethane	95		74 - 123					11/09/12 19:03	1



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-8 DUP

Lab Sample ID: 500-52022-24

Date Collected: 11/01/12 11:25

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 19:55	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 19:55	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 19:55	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 19:55	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 19:55	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 19:55	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 19:55	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 19:55	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 19:55	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 19:55	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 19:55	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 19:55	1
1,1-Dichloroethane	0.75	J	1.0	0.19	ug/L			11/09/12 19:55	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 19:55	1
cis-1,2-Dichloroethene	24		1.0	0.12	ug/L			11/09/12 19:55	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 19:55	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 19:55	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 19:55	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 19:55	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 19:55	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 19:55	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 19:55	1
Trichloroethene	8.2		0.50	0.19	ug/L			11/09/12 19:55	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 19:55	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 19:55	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 19:55	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 19:55	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 19:55	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 19:55	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 19:55	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 19:55	1
Tetrachloroethene	67		1.0	0.17	ug/L			11/09/12 19:55	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 19:55	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 19:55	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 19:55	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 19:55	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 19:55	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 19:55	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 19:55	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 19:55	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 19:55	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 19:55	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 19:55	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 19:55	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 19:55	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 19:55	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 19:55	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 19:55	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 19:55	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-8 DUP

Lab Sample ID: 500-52022-24

Date Collected: 11/01/12 11:25

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 19:55	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 19:55	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 19:55	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 19:55	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 19:55	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 19:55	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 19:55	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 19:55	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 19:55	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 19:55	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 19:55	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 19:55	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 19:55	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 19:55	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 19:55	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	103		75 - 131					11/09/12 19:55	1
Toluene-d8 (Surr)	98		80 - 120					11/09/12 19:55	1
4-Bromofluorobenzene (Surr)	96		79 - 120					11/09/12 19:55	1
Dibromofluoromethane	100		74 - 123					11/09/12 19:55	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-9

Lab Sample ID: 500-52022-25

Date Collected: 11/01/12 11:15

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 22:53	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 22:53	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 22:53	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 22:53	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 22:53	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 22:53	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 22:53	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 22:53	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 22:53	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 22:53	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 22:53	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 22:53	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 22:53	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 22:53	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 22:53	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 22:53	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 22:53	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 22:53	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 22:53	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 22:53	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 22:53	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 22:53	1
Trichloroethene	0.56		0.50	0.19	ug/L			11/09/12 22:53	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 22:53	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 22:53	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 22:53	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 22:53	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 22:53	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 22:53	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 22:53	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 22:53	1
Tetrachloroethene	110		1.0	0.17	ug/L			11/09/12 22:53	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 22:53	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 22:53	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 22:53	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 22:53	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 22:53	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 22:53	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 22:53	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 22:53	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 22:53	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 22:53	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 22:53	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 22:53	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 22:53	1
1,1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 22:53	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 22:53	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 22:53	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 22:53	1

TestAmerica Chicago



Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-9

Lab Sample ID: 500-52022-25

Date Collected: 11/01/12 11:15

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 22:53	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 22:53	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 22:53	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 22:53	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 22:53	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 22:53	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 22:53	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 22:53	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 22:53	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 22:53	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 22:53	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 22:53	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 22:53	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 22:53	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 22:53	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	96		75 - 131					11/09/12 22:53	1
Toluene-d8 (Surr)	97		80 - 120					11/09/12 22:53	1
4-Bromofluorobenzene (Surr)	95		79 - 120					11/09/12 22:53	1
Dibromofluoromethane	92		74 - 123					11/09/12 22:53	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-10

Lab Sample ID: 500-52022-26

Date Collected: 11/01/12 10:45

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 21:13	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 21:13	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 21:13	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 21:13	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 21:13	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 21:13	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 21:13	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 21:13	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 21:13	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 21:13	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 21:13	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 21:13	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 21:13	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 21:13	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 21:13	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 21:13	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 21:13	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 21:13	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 21:13	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 21:13	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 21:13	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 21:13	1
Trichloroethene	<0.50		0.50	0.19	ug/L			11/09/12 21:13	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 21:13	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 21:13	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 21:13	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 21:13	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 21:13	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 21:13	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 21:13	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 21:13	1
Tetrachloroethene	0.58	J	1.0	0.17	ug/L			11/09/12 21:13	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 21:13	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 21:13	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 21:13	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 21:13	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 21:13	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 21:13	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 21:13	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 21:13	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 21:13	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 21:13	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 21:13	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 21:13	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 21:13	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 21:13	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 21:13	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 21:13	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 21:13	1

TestAmerica Chicago

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-10

Lab Sample ID: 500-52022-26

Date Collected: 11/01/12 10:45

Matrix: Water

Date Received: 11/03/12 11:20

Method: 8260B - VOC (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 21:13	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 21:13	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 21:13	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 21:13	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 21:13	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 21:13	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 21:13	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 21:13	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 21:13	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 21:13	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 21:13	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 21:13	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 21:13	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 21:13	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 21:13	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	94		75 - 131					11/09/12 21:13	1
Toluene-d8 (Surr)	92		80 - 120					11/09/12 21:13	1
4-Bromofluorobenzene (Surr)	88		79 - 120					11/09/12 21:13	1
Dibromofluoromethane	92		74 - 123					11/09/12 21:13	1

Definitions/Glossary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Qualifiers

GC/MS VOA

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
*	LCS or LCSD exceeds the control limits

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
✱	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CNF	Contains no Free Liquid
DER	Duplicate error ratio (normalized absolute difference)
DL, RA, RE, IN	Indicates a Dilution, Reanalysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision level concentration
EDL	Estimated Detection Limit
EPA	United States Environmental Protection Agency
MDA	Minimum detectable activity
MDC	Minimum detectable concentration
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative error ratio
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

TestAmerica Chicago

QC Association Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

GC/MS VOA

Analysis Batch: 169030

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-52022-1	RFW-1A	Total/NA	Water	8260B	
500-52022-2	RFW-1B	Total/NA	Water	8260B	
500-52022-3	RFW-2A	Total/NA	Water	8260B	
500-52022-4	RFW-2B	Total/NA	Water	8260B	
500-52022-5	RFW-7	Total/NA	Water	8260B	
500-52022-6	RFW-6	Total/NA	Water	8260B	
500-52022-7	RFW-17	Total/NA	Water	8260B	
500-52022-8	RFW-13	Total/NA	Water	8260B	
500-52022-9	RFW-3B	Total/NA	Water	8260B	
500-52022-10	RFW-9	Total/NA	Water	8260B	
500-52022-11	TRIP BLANK	Total/NA	Water	8260B	
500-52022-12	RFW-4A	Total/NA	Water	8260B	
500-52022-13	RFW-4A DUP	Total/NA	Water	8260B	
500-52022-14	RFW-4B	Total/NA	Water	8260B	
500-52022-15	RFW-11B	Total/NA	Water	8260B	
500-52022-15 MS	RFW-11B	Total/NA	Water	8260B	
500-52022-15 MSD	RFW-11B	Total/NA	Water	8260B	
LCS 500-169030/4	Lab Control Sample	Total/NA	Water	8260B	
MB 500-169030/6	Method Blank	Total/NA	Water	8260B	

Analysis Batch: 169122

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-52022-16	RFW-12B	Total/NA	Water	8260B	
500-52022-17	EW-2	Total/NA	Water	8260B	
500-52022-18	EW-3	Total/NA	Water	8260B	
500-52022-19 - DL	EW-4	Total/NA	Water	8260B	
500-52022-19	EW-4	Total/NA	Water	8260B	
500-52022-20	EW-5	Total/NA	Water	8260B	
500-52022-21	EW-6	Total/NA	Water	8260B	
500-52022-22	EW-7	Total/NA	Water	8260B	
500-52022-23	EW-8	Total/NA	Water	8260B	
500-52022-24	EW-8 DUP	Total/NA	Water	8260B	
500-52022-25	EW-9	Total/NA	Water	8260B	
500-52022-26	EW-10	Total/NA	Water	8260B	
500-52022-26 MS	EW-10	Total/NA	Water	8260B	
500-52022-26 MSD	EW-10	Total/NA	Water	8260B	
LCS 500-169122/4	Lab Control Sample	Total/NA	Water	8260B	
MB 500-169122/6	Method Blank	Total/NA	Water	8260B	

TestAmerica Chicago

Surrogate Summary

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Method: 8260B - VOC

Matrix: Water


Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		12DCE (75-131)	TOL (80-120)	BFB (79-120)	DBFM (74-123)
500-52022-1	RFW-1A	99	93	91	96
500-52022-2	RFW-1B	98	95	89	97
500-52022-3	RFW-2A	97	92	92	95
500-52022-4	RFW-2B	106	97	92	109
500-52022-5	RFW-7	106	99	95	106
500-52022-6	RFW-6	96	93	89	95
500-52022-7	RFW-17	100	95	94	99
500-52022-8	RFW-13	109	103	100	106
500-52022-9	RFW-3B	99	96	95	101
500-52022-10	RFW-9	100	96	91	99
500-52022-11	TRIP BLANK	96	93	89	95
500-52022-12	RFW-4A	104	101	94	100
500-52022-13	RFW-4A DUP	106	100	96	103
500-52022-14	RFW-4B	108	100	100	106
500-52022-15	RFW-11B	103	96	91	103
500-52022-15 MS	RFW-11B	100	96	94	102
500-52022-15 MSD	RFW-11B	108	104	103	109
500-52022-16	RFW-12B	98	97	95	93
500-52022-17	EW-2	101	95	92	95
500-52022-18	EW-3	95	90	94	90
500-52022-19 - DL	EW-4	101	96	96	98
500-52022-19	EW-4	92	91	91	87
500-52022-20	EW-5	99	98	96	93
500-52022-21	EW-6	103	98	96	100
500-52022-22	EW-7	102	99	95	97
500-52022-23	EW-8	100	97	92	95
500-52022-24	EW-8 DUP	103	98	96	100
500-52022-25	EW-9	96	97	95	92
500-52022-26	EW-10	94	92	88	92
500-52022-26 MS	EW-10	100	98	97	100
500-52022-26 MSD	EW-10	99	95	94	101
LCS 500-169030/4	Lab Control Sample	98	96	95	97
LCS 500-169122/4	Lab Control Sample	98	96	100	95
MB 500-169030/6	Method Blank	103	102	97	100
MB 500-169122/6	Method Blank	105	101	102	100

Surrogate Legend

12DCE = 1,2-Dichloroethane-d4 (Surr)
TOL = Toluene-d8 (Surr)
BFB = 4-Bromofluorobenzene (Surr)
DBFM = Dibromofluoromethane

TestAmerica Chicago



QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1



Method: 8260B - VOC

Lab Sample ID: MB 500-169030/6
Matrix: Water
Analysis Batch: 169030

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 00:12	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 00:12	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 00:12	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 00:12	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 00:12	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 00:12	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 00:12	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 00:12	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 00:12	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 00:12	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 00:12	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 00:12	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 00:12	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 00:12	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 00:12	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 00:12	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 00:12	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 00:12	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 00:12	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 00:12	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 00:12	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 00:12	1
Trichloroethene	<0.50		0.50	0.19	ug/L			11/09/12 00:12	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 00:12	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 00:12	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 00:12	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 00:12	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 00:12	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 00:12	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 00:12	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 00:12	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 00:12	1
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 00:12	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 00:12	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 00:12	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 00:12	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 00:12	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 00:12	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 00:12	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 00:12	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 00:12	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 00:12	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 00:12	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 00:12	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 00:12	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 00:12	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 00:12	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 00:12	1

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Method: 8260B - VOC (Continued)

Lab Sample ID: MB 500-169030/6
Matrix: Water
Analysis Batch: 169030

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 00:12	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 00:12	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 00:12	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 00:12	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 00:12	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 00:12	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 00:12	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 00:12	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 00:12	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 00:12	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 00:12	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 00:12	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 00:12	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 00:12	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 00:12	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 00:12	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	103		75 - 131		11/09/12 00:12	1
Toluene-d8 (Surr)	102		80 - 120		11/09/12 00:12	1
4-Bromofluorobenzene (Surr)	97		79 - 120		11/09/12 00:12	1
Dibromofluoromethane	100		74 - 123		11/09/12 00:12	1

Lab Sample ID: LCS 500-169030/4
Matrix: Water
Analysis Batch: 169030

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Benzene	50.0	46.4		ug/L		93	74 - 115
Dichlorodifluoromethane	50.0	43.7		ug/L		87	43 - 139
Chloromethane	50.0	42.9		ug/L		86	56 - 144
Vinyl chloride	50.0	47.3		ug/L		95	51 - 149
Bromomethane	50.0	43.2		ug/L		86	47 - 158
Chloroethane	50.0	41.0		ug/L		82	54 - 143
Trichlorofluoromethane	50.0	47.6		ug/L		95	66 - 126
1,1-Dichloroethene	50.0	45.7		ug/L		91	58 - 115
Carbon disulfide	50.0	40.1		ug/L		80	50 - 120
Acetone	50.0	49.2		ug/L		98	41 - 163
Methylene Chloride	50.0	49.4		ug/L		99	63 - 130
trans-1,2-Dichloroethene	50.0	49.1		ug/L		98	74 - 119
1,1-Dichloroethane	50.0	47.5		ug/L		95	66 - 118
2,2-Dichloropropane	50.0	46.1		ug/L		92	70 - 117
cis-1,2-Dichloroethene	50.0	48.8		ug/L		98	75 - 119
Methyl Ethyl Ketone	50.0	48.6		ug/L		97	53 - 140
Bromochloromethane	50.0	49.1		ug/L		98	72 - 119
Chloroform	50.0	49.7		ug/L		99	76 - 117
1,1,1-Trichloroethane	50.0	48.9		ug/L		98	77 - 117
1,1-Dichloropropene	50.0	46.1		ug/L		92	71 - 113

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-169030/4

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 169030

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Carbon tetrachloride	50.0	47.9		ug/L		96	72 - 124
1,2-Dichloroethane	50.0	49.7		ug/L		99	76 - 117
Trichloroethene	50.0	51.3		ug/L		103	75 - 120
1,2-Dichloropropane	50.0	48.3		ug/L		97	77 - 118
Dibromomethane	50.0	50.8		ug/L		102	76 - 120
Bromodichloromethane	50.0	47.2		ug/L		94	79 - 117
cis-1,3-Dichloropropene	53.8	52.0		ug/L		97	71 - 112
methyl isobutyl ketone	50.0	49.9		ug/L		100	59 - 134
Toluene	50.0	47.1		ug/L		94	80 - 120
trans-1,3-Dichloropropene	48.6	48.5		ug/L		100	66 - 116
1,1,2-Trichloroethane	50.0	49.4		ug/L		99	78 - 121
Tetrachloroethene	50.0	49.3		ug/L		99	71 - 120
1,3-Dichloropropane	50.0	49.1		ug/L		98	79 - 114
2-Hexanone	50.0	46.9		ug/L		94	60 - 134
Dibromochloromethane	50.0	48.7		ug/L		97	73 - 120
1,2-Dibromoethane	50.0	50.3		ug/L		101	79 - 120
Chlorobenzene	50.0	45.3		ug/L		91	80 - 120
1,1,1,2-Tetrachloroethane	50.0	48.4		ug/L		97	80 - 120
Ethylbenzene	50.0	46.5		ug/L		93	79 - 115
m&p-Xylene	100	88.5		ug/L		89	78 - 120
o-Xylene	50.0	43.7		ug/L		87	78 - 120
Styrene	50.0	48.2		ug/L		96	80 - 120
Bromoform	50.0	52.8		ug/L		106	64 - 127
Isopropylbenzene	50.0	43.7		ug/L		87	68 - 120
Bromobenzene	50.0	49.5		ug/L		99	80 - 120
1,1,2,2-Tetrachloroethane	50.0	48.8		ug/L		98	78 - 123
1,2,3-Trichloropropane	50.0	49.5		ug/L		99	77 - 119
N-Propylbenzene	50.0	42.5		ug/L		85	77 - 114
2-Chlorotoluene	50.0	43.6		ug/L		87	80 - 120
1,3,5-Trimethylbenzene	50.0	48.2		ug/L		96	83 - 120
4-Chlorotoluene	50.0	43.2		ug/L		86	80 - 120
tert-Butylbenzene	50.0	44.2		ug/L		88	80 - 120
1,2,4-Trimethylbenzene	50.0	47.1		ug/L		94	80 - 120
sec-Butylbenzene	50.0	44.0		ug/L		88	79 - 117
1,3-Dichlorobenzene	50.0	45.0		ug/L		90	80 - 120
p-Isopropyltoluene	50.0	44.2		ug/L		88	77 - 120
1,4-Dichlorobenzene	50.0	48.3		ug/L		97	80 - 120
n-Butylbenzene	50.0	46.1		ug/L		92	78 - 119
1,2-Dichlorobenzene	50.0	47.0		ug/L		94	80 - 120
1,2-Dibromo-3-Chloropropane	50.0	45.7		ug/L		91	53 - 133
1,2,4-Trichlorobenzene	50.0	48.0		ug/L		96	70 - 118
Hexachlorobutadiene	50.0	46.1		ug/L		92	71 - 128
Naphthalene	50.0	52.4		ug/L		105	72 - 127
1,2,3-Trichlorobenzene	50.0	51.1		ug/L		102	74 - 126

Surrogate	LCS LCS		Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	98		75 - 131
Toluene-d8 (Surr)	96		80 - 120

TestAmerica Chicago



QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-169030/4

Matrix: Water

Analysis Batch: 169030

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Surrogate	LCS %Recovery	LCS Qualifier	Limits
4-Bromofluorobenzene (Surr)	95		79 - 120
Dibromofluoromethane	97		74 - 123

Lab Sample ID: 500-52022-15 MS

Matrix: Water

Analysis Batch: 169030

Client Sample ID: RFW-11B

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Benzene	<0.50		50.0	50.5		ug/L		101	74 - 115
Dichlorodifluoromethane	<1.0		50.0	48.8		ug/L		98	43 - 139
Chloromethane	<1.0		50.0	48.9		ug/L		98	56 - 144
Vinyl chloride	<0.50		50.0	53.3		ug/L		107	51 - 149
Bromomethane	<1.0		50.0	46.9		ug/L		94	47 - 158
Chloroethane	<1.0		50.0	43.6		ug/L		87	54 - 143
Trichlorofluoromethane	<1.0		50.0	52.1		ug/L		104	66 - 126
1,1-Dichloroethene	<1.0		50.0	50.8		ug/L		102	58 - 115
Carbon disulfide	<5.0		50.0	44.6		ug/L		89	50 - 120
Acetone	<5.0		50.0	53.4		ug/L		107	41 - 163
Methylene Chloride	<5.0		50.0	54.3		ug/L		109	63 - 130
trans-1,2-Dichloroethene	<1.0		50.0	54.6		ug/L		109	74 - 119
1,1-Dichloroethane	<1.0		50.0	53.5		ug/L		107	66 - 118
2,2-Dichloropropane	<1.0		50.0	49.0		ug/L		98	70 - 117
cis-1,2-Dichloroethene	<1.0		50.0	54.6		ug/L		109	75 - 119
Methyl Ethyl Ketone	<5.0		50.0	57.5		ug/L		115	53 - 140
Bromochloromethane	<1.0		50.0	51.3		ug/L		103	72 - 119
Chloroform	<1.0		50.0	55.9		ug/L		112	76 - 117
1,1,1-Trichloroethane	<1.0		50.0	54.0		ug/L		108	77 - 117
1,1-Dichloropropene	<1.0		50.0	50.3		ug/L		101	71 - 113
Carbon tetrachloride	<1.0		50.0	50.8		ug/L		102	72 - 124
1,2-Dichloroethane	<1.0		50.0	54.0		ug/L		108	76 - 117
Trichloroethene	2.8		50.0	57.9		ug/L		110	75 - 120
1,2-Dichloropropane	<1.0		50.0	53.2		ug/L		106	77 - 118
Dibromomethane	<1.0		50.0	54.4		ug/L		109	76 - 120
Bromodichloromethane	<1.0		50.0	50.4		ug/L		101	79 - 117
cis-1,3-Dichloropropene	<1.0		53.8	55.9		ug/L		104	71 - 112
methyl isobutyl ketone	<5.0		50.0	52.8		ug/L		106	59 - 134
Toluene	<0.50		50.0	51.0		ug/L		102	80 - 120
trans-1,3-Dichloropropene	<1.0		48.6	50.2		ug/L		103	66 - 116
1,1,2-Trichloroethane	<1.0		50.0	53.0		ug/L		106	78 - 121
Tetrachloroethene	<1.0		50.0	52.2		ug/L		104	71 - 120
1,3-Dichloropropane	<1.0		50.0	51.8		ug/L		104	79 - 114
2-Hexanone	<5.0		50.0	52.6		ug/L		105	60 - 134
Dibromochloromethane	<1.0		50.0	53.3		ug/L		107	73 - 120
1,2-Dibromoethane	<1.0		50.0	54.4		ug/L		109	79 - 120
Chlorobenzene	<1.0		50.0	48.4		ug/L		97	80 - 120
1,1,1,2-Tetrachloroethane	<1.0		50.0	52.4		ug/L		105	80 - 120
Ethylbenzene	<0.50		50.0	48.8		ug/L		98	79 - 115
m&p-Xylene	<1.0		100	93.3		ug/L		93	78 - 120

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Method: 8260B - VOC (Continued)

Lab Sample ID: 500-52022-15 MS

Client Sample ID: RFW-11B

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 169030

Analyte	Sample	Sample	Spike	MS MS		Unit	D	%Rec	%Rec.	Limits
	Result	Qualifier		Result	Qualifier					
o-Xylene	<0.50		50.0	46.8		ug/L		94	78 - 120	
Styrene	<1.0		50.0	49.9		ug/L		100	80 - 120	
Bromoform	<1.0		50.0	56.7		ug/L		113	64 - 127	
Isopropylbenzene	<1.0		50.0	49.3		ug/L		99	68 - 120	
Bromobenzene	<1.0		50.0	55.6		ug/L		111	80 - 120	
1,1,2,2-Tetrachloroethane	<1.0		50.0	55.5		ug/L		111	78 - 123	
1,2,3-Trichloropropane	<1.0		50.0	55.2		ug/L		110	77 - 119	
N-Propylbenzene	<1.0		50.0	46.6		ug/L		93	77 - 114	
2-Chlorotoluene	<1.0		50.0	48.8		ug/L		98	80 - 120	
1,3,5-Trimethylbenzene	<1.0		50.0	53.7		ug/L		107	83 - 120	
4-Chlorotoluene	<1.0		50.0	47.5		ug/L		95	80 - 120	
tert-Butylbenzene	<1.0		50.0	50.9		ug/L		102	80 - 120	
1,2,4-Trimethylbenzene	<1.0		50.0	52.2		ug/L		104	80 - 120	
sec-Butylbenzene	<1.0		50.0	49.6		ug/L		99	79 - 117	
1,3-Dichlorobenzene	<1.0		50.0	48.4		ug/L		97	80 - 120	
p-Isopropyltoluene	<1.0		50.0	48.3		ug/L		97	77 - 120	
1,4-Dichlorobenzene	<1.0		50.0	50.8		ug/L		102	80 - 120	
n-Butylbenzene	<1.0		50.0	47.4		ug/L		95	78 - 119	
1,2-Dichlorobenzene	<1.0		50.0	52.7		ug/L		105	80 - 120	
1,2-Dibromo-3-Chloropropane	<2.0		50.0	58.0		ug/L		116	53 - 133	
1,2,4-Trichlorobenzene	<1.0		50.0	49.2		ug/L		98	70 - 118	
Hexachlorobutadiene	<1.0		50.0	54.7		ug/L		109	71 - 128	
Naphthalene	<1.0		50.0	60.6		ug/L		121	72 - 127	
1,2,3-Trichlorobenzene	<1.0		50.0	58.1		ug/L		116	74 - 126	

Surrogate	MS MS		Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	100		75 - 131
Toluene-d8 (Surr)	96		80 - 120
4-Bromofluorobenzene (Surr)	94		79 - 120
Dibromofluoromethane	102		74 - 123

Lab Sample ID: 500-52022-15 MSD

Client Sample ID: RFW-11B

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 169030

Analyte	Sample	Sample	Spike	MSD MSD		Unit	D	%Rec	%Rec.	Limits	RPD	RPD Limit
	Result	Qualifier		Result	Qualifier							
Benzene	<0.50		50.0	50.7		ug/L		101	74 - 115	0	20	
Dichlorodifluoromethane	<1.0		50.0	44.5		ug/L		89	43 - 139	9	20	
Chloromethane	<1.0		50.0	45.6		ug/L		91	56 - 144	7	20	
Vinyl chloride	<0.50		50.0	50.9		ug/L		102	51 - 149	5	20	
Bromomethane	<1.0		50.0	44.1		ug/L		88	47 - 158	6	20	
Chloroethane	<1.0		50.0	42.6		ug/L		85	54 - 143	2	20	
Trichlorofluoromethane	<1.0		50.0	49.7		ug/L		99	66 - 126	5	20	
1,1-Dichloroethene	<1.0		50.0	51.7		ug/L		103	58 - 115	2	20	
Carbon disulfide	<5.0		50.0	45.4		ug/L		91	50 - 120	2	20	
Acetone	<5.0		50.0	56.3		ug/L		113	41 - 163	5	20	
Methylene Chloride	<5.0		50.0	54.6		ug/L		109	63 - 130	0	20	
trans-1,2-Dichloroethene	<1.0		50.0	55.9		ug/L		112	74 - 119	2	20	

TestAmerica Chicago



QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Method: 8260B - VOC (Continued)

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec.	RPD	RPD
	Result	Qualifier	Added	Result	Qualifier				Limits		Limit
1,1-Dichloroethane	<1.0		50.0	55.8		ug/L		112	66 - 118	4	20
2,2-Dichloropropane	<1.0		50.0	49.3		ug/L		99	70 - 117	1	20
cis-1,2-Dichloroethene	<1.0		50.0	56.0		ug/L		112	75 - 119	3	20
Methyl Ethyl Ketone	<5.0		50.0	62.7		ug/L		125	53 - 140	9	20
Bromochloromethane	<1.0		50.0	53.1		ug/L		106	72 - 119	3	20
Chloroform	<1.0		50.0	56.9		ug/L		114	76 - 117	2	20
1,1,1-Trichloroethane	<1.0		50.0	55.0		ug/L		110	77 - 117	2	20
1,1-Dichloropropene	<1.0		50.0	52.1		ug/L		104	71 - 113	3	20
Carbon tetrachloride	<1.0		50.0	51.7		ug/L		103	72 - 124	2	20
1,2-Dichloroethane	<1.0		50.0	54.2		ug/L		108	76 - 117	0	20
Trichloroethene	2.8		50.0	57.7		ug/L		110	75 - 120	0	20
1,2-Dichloropropane	<1.0		50.0	52.4		ug/L		105	77 - 118	1	20
Dibromomethane	<1.0		50.0	56.3		ug/L		113	76 - 120	3	20
Bromodichloromethane	<1.0		50.0	51.7		ug/L		103	79 - 117	3	20
cis-1,3-Dichloropropene	<1.0		53.8	55.9		ug/L		104	71 - 112	0	20
methyl isobutyl ketone	<5.0		50.0	54.6		ug/L		109	59 - 134	3	20
Toluene	<0.50		50.0	50.8		ug/L		102	80 - 120	0	20
trans-1,3-Dichloropropene	<1.0		48.6	51.4		ug/L		106	66 - 116	2	20
1,1,2-Trichloroethane	<1.0		50.0	53.7		ug/L		107	78 - 121	1	20
Tetrachloroethene	<1.0		50.0	54.9		ug/L		110	71 - 120	5	20
1,3-Dichloropropane	<1.0		50.0	55.6		ug/L		111	79 - 114	7	20
2-Hexanone	<5.0		50.0	54.9		ug/L		110	60 - 134	4	20
Dibromochloromethane	<1.0		50.0	56.4		ug/L		113	73 - 120	6	20
1,2-Dibromoethane	<1.0		50.0	54.6		ug/L		109	79 - 120	0	20
Chlorobenzene	<1.0		50.0	50.3		ug/L		101	80 - 120	4	20
1,1,1,2-Tetrachloroethane	<1.0		50.0	54.4		ug/L		109	80 - 120	4	20
Ethylbenzene	<0.50		50.0	51.5		ug/L		103	79 - 115	5	20
m&p-Xylene	<1.0		100	96.7		ug/L		97	78 - 120	3	20
o-Xylene	<0.50		50.0	48.7		ug/L		97	78 - 120	4	20
Styrene	<1.0		50.0	51.9		ug/L		104	80 - 120	4	20
Bromoform	<1.0		50.0	58.9		ug/L		118	64 - 127	4	20
Isopropylbenzene	<1.0		50.0	49.9		ug/L		100	68 - 120	1	20
Bromobenzene	<1.0		50.0	55.3		ug/L		111	80 - 120	0	20
1,1,2,2-Tetrachloroethane	<1.0		50.0	57.1		ug/L		114	78 - 123	3	20
1,2,3-Trichloropropane	<1.0		50.0	56.7		ug/L		113	77 - 119	3	20
N-Propylbenzene	<1.0		50.0	47.1		ug/L		94	77 - 114	1	20
2-Chlorotoluene	<1.0		50.0	49.1		ug/L		98	80 - 120	1	20
1,3,5-Trimethylbenzene	<1.0		50.0	54.3		ug/L		109	83 - 120	1	20
4-Chlorotoluene	<1.0		50.0	47.5		ug/L		95	80 - 120	0	20
tert-Butylbenzene	<1.0		50.0	51.4		ug/L		103	80 - 120	1	20
1,2,4-Trimethylbenzene	<1.0		50.0	52.5		ug/L		105	80 - 120	0	20
sec-Butylbenzene	<1.0		50.0	50.1		ug/L		100	79 - 117	1	20
1,3-Dichlorobenzene	<1.0		50.0	49.6		ug/L		99	80 - 120	2	20
p-Isopropyltoluene	<1.0		50.0	49.2		ug/L		98	77 - 120	2	20
1,4-Dichlorobenzene	<1.0		50.0	52.3		ug/L		105	80 - 120	3	20
n-Butylbenzene	<1.0		50.0	48.6		ug/L		97	78 - 119	2	20
1,2-Dichlorobenzene	<1.0		50.0	53.6		ug/L		107	80 - 120	2	20
1,2-Dibromo-3-Chloropropane	<2.0		50.0	54.4		ug/L		109	53 - 133	6	20

TestAmerica Chicago



QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Method: 8260B - VOC (Continued)

Lab Sample ID: 500-52022-15 MSD

Client Sample ID: RFW-11B

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 169030

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec.	RPD	Limit
	Result	Qualifier	Added	Result	Qualifier				Limits		
1,2,4-Trichlorobenzene	<1.0		50.0	51.3		ug/L		103	70 - 118	4	20
Hexachlorobutadiene	<1.0		50.0	53.6		ug/L		107	71 - 128	2	20
Naphthalene	<1.0		50.0	63.1		ug/L		126	72 - 127	4	20
1,2,3-Trichlorobenzene	<1.0		50.0	58.5		ug/L		117	74 - 126	1	20

Surrogate	MSD	MSD	Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	108		75 - 131
Toluene-d8 (Surr)	104		80 - 120
4-Bromofluorobenzene (Surr)	103		79 - 120
Dibromofluoromethane	109		74 - 123

Lab Sample ID: MB 500-169122/6

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 169122

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Benzene	<0.50		0.50	0.074	ug/L			11/09/12 13:25	1
Dichlorodifluoromethane	<1.0		1.0	0.20	ug/L			11/09/12 13:25	1
Chloromethane	<1.0		1.0	0.18	ug/L			11/09/12 13:25	1
Vinyl chloride	<0.50		0.50	0.10	ug/L			11/09/12 13:25	1
Bromomethane	<1.0		1.0	0.31	ug/L			11/09/12 13:25	1
Chloroethane	<1.0		1.0	0.34	ug/L			11/09/12 13:25	1
Trichlorofluoromethane	<1.0		1.0	0.19	ug/L			11/09/12 13:25	1
1,1-Dichloroethene	<1.0		1.0	0.31	ug/L			11/09/12 13:25	1
Carbon disulfide	<5.0		5.0	0.43	ug/L			11/09/12 13:25	1
Acetone	<5.0		5.0	1.3	ug/L			11/09/12 13:25	1
Methylene Chloride	<5.0		5.0	0.68	ug/L			11/09/12 13:25	1
trans-1,2-Dichloroethene	<1.0		1.0	0.25	ug/L			11/09/12 13:25	1
1,1-Dichloroethane	<1.0		1.0	0.19	ug/L			11/09/12 13:25	1
2,2-Dichloropropane	<1.0		1.0	0.32	ug/L			11/09/12 13:25	1
cis-1,2-Dichloroethene	<1.0		1.0	0.12	ug/L			11/09/12 13:25	1
Methyl Ethyl Ketone	<5.0		5.0	1.5	ug/L			11/09/12 13:25	1
Bromochloromethane	<1.0		1.0	0.40	ug/L			11/09/12 13:25	1
Chloroform	<1.0		1.0	0.20	ug/L			11/09/12 13:25	1
1,1,1-Trichloroethane	<1.0		1.0	0.20	ug/L			11/09/12 13:25	1
1,1-Dichloropropene	<1.0		1.0	0.34	ug/L			11/09/12 13:25	1
Carbon tetrachloride	<1.0		1.0	0.26	ug/L			11/09/12 13:25	1
1,2-Dichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 13:25	1
Trichloroethene	<0.50		0.50	0.19	ug/L			11/09/12 13:25	1
1,2-Dichloropropane	<1.0		1.0	0.20	ug/L			11/09/12 13:25	1
Dibromomethane	<1.0		1.0	0.33	ug/L			11/09/12 13:25	1
Bromodichloromethane	<1.0		1.0	0.17	ug/L			11/09/12 13:25	1
cis-1,3-Dichloropropene	<1.0		1.0	0.18	ug/L			11/09/12 13:25	1
methyl isobutyl ketone	<5.0		5.0	0.33	ug/L			11/09/12 13:25	1
Toluene	<0.50		0.50	0.11	ug/L			11/09/12 13:25	1
trans-1,3-Dichloropropene	<1.0		1.0	0.21	ug/L			11/09/12 13:25	1
1,1,2-Trichloroethane	<1.0		1.0	0.28	ug/L			11/09/12 13:25	1
Tetrachloroethene	<1.0		1.0	0.17	ug/L			11/09/12 13:25	1

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Method: 8260B - VOC (Continued)

Lab Sample ID: MB 500-169122/6

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 169122

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
1,3-Dichloropropane	<1.0		1.0	0.13	ug/L			11/09/12 13:25	1
2-Hexanone	<5.0		5.0	0.56	ug/L			11/09/12 13:25	1
Dibromochloromethane	<1.0		1.0	0.32	ug/L			11/09/12 13:25	1
1,2-Dibromoethane	<1.0		1.0	0.36	ug/L			11/09/12 13:25	1
Chlorobenzene	<1.0		1.0	0.14	ug/L			11/09/12 13:25	1
1,1,1,2-Tetrachloroethane	<1.0		1.0	0.25	ug/L			11/09/12 13:25	1
Ethylbenzene	<0.50		0.50	0.13	ug/L			11/09/12 13:25	1
m&p-Xylene	<1.0		1.0	0.26	ug/L			11/09/12 13:25	1
o-Xylene	<0.50		0.50	0.068	ug/L			11/09/12 13:25	1
Styrene	<1.0		1.0	0.10	ug/L			11/09/12 13:25	1
Bromoform	<1.0		1.0	0.28	ug/L			11/09/12 13:25	1
Isopropylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 13:25	1
Bromobenzene	<1.0		1.0	0.25	ug/L			11/09/12 13:25	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	0.23	ug/L			11/09/12 13:25	1
1,2,3-Trichloropropane	<1.0		1.0	0.45	ug/L			11/09/12 13:25	1
N-Propylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 13:25	1
2-Chlorotoluene	<1.0		1.0	0.21	ug/L			11/09/12 13:25	1
1,3,5-Trimethylbenzene	<1.0		1.0	0.18	ug/L			11/09/12 13:25	1
4-Chlorotoluene	<1.0		1.0	0.20	ug/L			11/09/12 13:25	1
tert-Butylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 13:25	1
1,2,4-Trimethylbenzene	<1.0		1.0	0.14	ug/L			11/09/12 13:25	1
sec-Butylbenzene	<1.0		1.0	0.15	ug/L			11/09/12 13:25	1
1,3-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 13:25	1
p-Isopropyltoluene	<1.0		1.0	0.17	ug/L			11/09/12 13:25	1
1,4-Dichlorobenzene	<1.0		1.0	0.15	ug/L			11/09/12 13:25	1
n-Butylbenzene	<1.0		1.0	0.13	ug/L			11/09/12 13:25	1
1,2-Dichlorobenzene	<1.0		1.0	0.27	ug/L			11/09/12 13:25	1
1,2-Dibromo-3-Chloropropane	<2.0		2.0	0.87	ug/L			11/09/12 13:25	1
1,2,4-Trichlorobenzene	<1.0		1.0	0.31	ug/L			11/09/12 13:25	1
Hexachlorobutadiene	<1.0		1.0	0.26	ug/L			11/09/12 13:25	1
Naphthalene	<1.0		1.0	0.16	ug/L			11/09/12 13:25	1
1,2,3-Trichlorobenzene	<1.0		1.0	0.24	ug/L			11/09/12 13:25	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
1,2-Dichloroethane-d4 (Surr)	105		75 - 131		11/09/12 13:25	1
Toluene-d8 (Surr)	101		80 - 120		11/09/12 13:25	1
4-Bromofluorobenzene (Surr)	102		79 - 120		11/09/12 13:25	1
Dibromofluoromethane	100		74 - 123		11/09/12 13:25	1

Lab Sample ID: LCS 500-169122/4

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 169122

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Dichlorodifluoromethane	50.0	37.5		ug/L		75	43 - 139
Chloromethane	50.0	35.5		ug/L		71	56 - 144
Vinyl chloride	50.0	40.4		ug/L		81	51 - 149

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-169122/4
Matrix: Water
Analysis Batch: 169122

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Bromomethane	50.0	38.2		ug/L		76	47 - 158
Chloroethane	50.0	35.8		ug/L		72	54 - 143
Trichlorofluoromethane	50.0	41.5		ug/L		83	66 - 126
1,1-Dichloroethene	50.0	39.5		ug/L		79	58 - 115
Carbon disulfide	50.0	34.2		ug/L		68	50 - 120
Acetone	50.0	39.0		ug/L		78	41 - 163
Methylene Chloride	50.0	41.3		ug/L		83	63 - 130
trans-1,2-Dichloroethene	50.0	41.7		ug/L		83	74 - 119
1,1-Dichloroethane	50.0	40.6		ug/L		81	66 - 118
2,2-Dichloropropane	50.0	39.9		ug/L		80	70 - 117
cis-1,2-Dichloroethene	50.0	41.5		ug/L		83	75 - 119
Methyl Ethyl Ketone	50.0	44.6		ug/L		89	53 - 140
Bromochloromethane	50.0	39.0		ug/L		78	72 - 119
Chloroform	50.0	42.0		ug/L		84	76 - 117
1,1,1-Trichloroethane	50.0	41.7		ug/L		83	77 - 117
1,1-Dichloropropene	50.0	39.4		ug/L		79	71 - 113
Carbon tetrachloride	50.0	42.0		ug/L		84	72 - 124
1,2-Dichloroethane	50.0	42.5		ug/L		85	76 - 117
Trichloroethene	50.0	44.0		ug/L		88	75 - 120
1,2-Dichloropropane	50.0	40.7		ug/L		81	77 - 118
Dibromomethane	50.0	42.5		ug/L		85	76 - 120
Bromodichloromethane	50.0	39.9		ug/L		80	79 - 117
cis-1,3-Dichloropropene	53.8	44.6		ug/L		83	71 - 112
methyl isobutyl ketone	50.0	41.8		ug/L		84	59 - 134
Toluene	50.0	40.4		ug/L		81	80 - 120
trans-1,3-Dichloropropene	48.6	41.1		ug/L		84	66 - 116
1,1,2-Trichloroethane	50.0	41.7		ug/L		83	78 - 121
Tetrachloroethene	50.0	46.4		ug/L		93	71 - 120
1,3-Dichloropropane	50.0	43.3		ug/L		87	79 - 114
2-Hexanone	50.0	42.6		ug/L		85	60 - 134
Dibromochloromethane	50.0	44.9		ug/L		90	73 - 120
1,2-Dibromoethane	50.0	42.3		ug/L		85	79 - 120
Chlorobenzene	50.0	41.4		ug/L		83	80 - 120
1,1,1,2-Tetrachloroethane	50.0	43.8		ug/L		88	80 - 120
Ethylbenzene	50.0	42.1		ug/L		84	79 - 115
m&p-Xylene	100	80.8		ug/L		81	78 - 120
o-Xylene	50.0	39.7		ug/L		79	78 - 120
Styrene	50.0	43.5		ug/L		87	80 - 120
Bromoform	50.0	48.0		ug/L		96	64 - 127
Isopropylbenzene	50.0	39.5		ug/L		79	68 - 120
Bromobenzene	50.0	42.8		ug/L		86	80 - 120
1,1,2,2-Tetrachloroethane	50.0	42.8		ug/L		86	78 - 123
1,2,3-Trichloropropane	50.0	43.3		ug/L		87	77 - 119
N-Propylbenzene	50.0	38.5		ug/L		77	77 - 114
2-Chlorotoluene	50.0	39.1 *		ug/L		78	80 - 120
1,3,5-Trimethylbenzene	50.0	43.8		ug/L		88	83 - 120
4-Chlorotoluene	50.0	38.8 *		ug/L		78	80 - 120
tert-Butylbenzene	50.0	39.9		ug/L		80	80 - 120

TestAmerica Chicago



QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Method: 8260B - VOC (Continued)

Lab Sample ID: LCS 500-169122/4

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 169122

Analyte	Spike Added	LCS LCS		Unit	D	%Rec	%Rec. Limits
		Result	Qualifier				
1,2,4-Trimethylbenzene	50.0	43.0		ug/L		86	80 - 120
sec-Butylbenzene	50.0	40.0		ug/L		80	79 - 117
1,3-Dichlorobenzene	50.0	40.7		ug/L		81	80 - 120
p-Isopropyltoluene	50.0	40.6		ug/L		81	77 - 120
1,4-Dichlorobenzene	50.0	42.5		ug/L		85	80 - 120
n-Butylbenzene	50.0	42.6		ug/L		85	78 - 119
1,2-Dichlorobenzene	50.0	42.3		ug/L		85	80 - 120
1,2-Dibromo-3-Chloropropane	50.0	43.0		ug/L		86	53 - 133
1,2,4-Trichlorobenzene	50.0	44.1		ug/L		88	70 - 118
Hexachlorobutadiene	50.0	43.3		ug/L		87	71 - 128
Naphthalene	50.0	46.0		ug/L		92	72 - 127
1,2,3-Trichlorobenzene	50.0	46.1		ug/L		92	74 - 126

Surrogate	LCS LCS		Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	98		75 - 131
Toluene-d8 (Surr)	96		80 - 120
4-Bromofluorobenzene (Surr)	100		79 - 120
Dibromofluoromethane	95		74 - 123

Lab Sample ID: 500-52022-26 MS

Client Sample ID: EW-10

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 169122

Analyte	Sample Result	Sample Qualifier	Spike Added	MS MS		Unit	D	%Rec	%Rec. Limits
				Result	Qualifier				
Benzene	<0.50		50.0	47.4		ug/L		95	74 - 115
Dichlorodifluoromethane	<1.0		50.0	42.9		ug/L		86	43 - 139
Chloromethane	<1.0		50.0	42.4		ug/L		85	56 - 144
Vinyl chloride	<0.50		50.0	47.3		ug/L		95	51 - 149
Bromomethane	<1.0		50.0	43.0		ug/L		86	47 - 158
Chloroethane	<1.0		50.0	40.5		ug/L		81	54 - 143
Trichlorofluoromethane	<1.0		50.0	46.0		ug/L		92	66 - 126
1,1-Dichloroethene	<1.0		50.0	47.7		ug/L		95	58 - 115
Carbon disulfide	<5.0		50.0	40.5		ug/L		81	50 - 120
Acetone	<5.0		50.0	49.6		ug/L		99	41 - 163
Methylene Chloride	<5.0		50.0	51.1		ug/L		102	63 - 130
trans-1,2-Dichloroethene	<1.0		50.0	50.8		ug/L		102	74 - 119
1,1-Dichloroethane	<1.0		50.0	49.9		ug/L		100	66 - 118
2,2-Dichloropropane	<1.0		50.0	46.6		ug/L		93	70 - 117
cis-1,2-Dichloroethene	<1.0		50.0	50.2		ug/L		100	75 - 119
Methyl Ethyl Ketone	<5.0		50.0	48.9		ug/L		98	53 - 140
Bromochloromethane	<1.0		50.0	47.5		ug/L		95	72 - 119
Chloroform	<1.0		50.0	51.4		ug/L		103	76 - 117
1,1,1-Trichloroethane	<1.0		50.0	50.3		ug/L		101	77 - 117
1,1-Dichloropropene	<1.0		50.0	47.0		ug/L		94	71 - 113
Carbon tetrachloride	<1.0		50.0	49.5		ug/L		99	72 - 124
1,2-Dichloroethane	<1.0		50.0	50.4		ug/L		101	76 - 117
Trichloroethene	<0.50		50.0	52.8		ug/L		106	75 - 120
1,2-Dichloropropane	<1.0		50.0	49.5		ug/L		99	77 - 118

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Method: 8260B - VOC (Continued)

Lab Sample ID: 500-52022-26 MS

Client Sample ID: EW-10

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 169122

Analyte	Sample	Sample	Spike	MS MS		Unit	D	%Rec	%Rec.	Limits
	Result	Qualifier		Result	Qualifier					
Dibromomethane	<1.0		50.0	51.4		ug/L		103	76 - 120	
Bromodichloromethane	<1.0		50.0	48.6		ug/L		97	79 - 117	
cis-1,3-Dichloropropene	<1.0		53.8	52.9		ug/L		98	71 - 112	
methyl isobutyl ketone	<5.0		50.0	49.8		ug/L		100	59 - 134	
Toluene	<0.50		50.0	48.8		ug/L		98	80 - 120	
trans-1,3-Dichloropropene	<1.0		48.6	47.9		ug/L		98	66 - 116	
1,1,2-Trichloroethane	<1.0		50.0	50.2		ug/L		100	78 - 121	
Tetrachloroethene	0.58	J	50.0	51.9		ug/L		103	71 - 120	
1,3-Dichloropropane	<1.0		50.0	49.8		ug/L		100	79 - 114	
2-Hexanone	<5.0		50.0	48.7		ug/L		97	60 - 134	
Dibromochloromethane	<1.0		50.0	50.9		ug/L		102	73 - 120	
1,2-Dibromoethane	<1.0		50.0	51.5		ug/L		103	79 - 120	
Chlorobenzene	<1.0		50.0	47.1		ug/L		94	80 - 120	
1,1,1,2-Tetrachloroethane	<1.0		50.0	50.1		ug/L		100	80 - 120	
Ethylbenzene	<0.50		50.0	47.6		ug/L		95	79 - 115	
m&p-Xylene	<1.0		100	91.2		ug/L		91	78 - 120	
o-Xylene	<0.50		50.0	45.4		ug/L		91	78 - 120	
Styrene	<1.0		50.0	49.0		ug/L		98	80 - 120	
Bromoform	<1.0		50.0	53.9		ug/L		108	64 - 127	
Isopropylbenzene	<1.0		50.0	45.3		ug/L		91	68 - 120	
Bromobenzene	<1.0		50.0	50.1		ug/L		100	80 - 120	
1,1,1,2-Tetrachloroethane	<1.0		50.0	49.9		ug/L		100	78 - 123	
1,2,3-Trichloropropane	<1.0		50.0	49.5		ug/L		99	77 - 119	
N-Propylbenzene	<1.0		50.0	43.6		ug/L		87	77 - 114	
2-Chlorotoluene	<1.0		50.0	45.3		ug/L		91	80 - 120	
1,3,5-Trimethylbenzene	<1.0		50.0	50.2		ug/L		100	83 - 120	
4-Chlorotoluene	<1.0		50.0	44.8		ug/L		90	80 - 120	
tert-Butylbenzene	<1.0		50.0	46.0		ug/L		92	80 - 120	
1,2,4-Trimethylbenzene	<1.0		50.0	49.3		ug/L		99	80 - 120	
sec-Butylbenzene	<1.0		50.0	45.6		ug/L		91	79 - 117	
1,3-Dichlorobenzene	<1.0		50.0	46.9		ug/L		94	80 - 120	
p-Isopropyltoluene	<1.0		50.0	45.7		ug/L		91	77 - 120	
1,4-Dichlorobenzene	<1.0		50.0	49.7		ug/L		99	80 - 120	
n-Butylbenzene	<1.0		50.0	47.4		ug/L		95	78 - 119	
1,2-Dichlorobenzene	<1.0		50.0	49.2		ug/L		98	80 - 120	
1,2-Dibromo-3-Chloropropane	<2.0		50.0	50.0		ug/L		100	53 - 133	
1,2,4-Trichlorobenzene	<1.0		50.0	49.9		ug/L		100	70 - 118	
Hexachlorobutadiene	<1.0		50.0	47.6		ug/L		95	71 - 128	
Naphthalene	<1.0		50.0	54.1		ug/L		108	72 - 127	
1,2,3-Trichlorobenzene	<1.0		50.0	53.4		ug/L		107	74 - 126	

Surrogate	MS MS		Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	100		75 - 131
Toluene-d8 (Surr)	98		80 - 120
4-Bromofluorobenzene (Surr)	97		79 - 120
Dibromofluoromethane	100		74 - 123

TestAmerica Chicago



QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Method: 8260B - VOC (Continued)

Lab Sample ID: 500-52022-26 MSD

Matrix: Water

Analysis Batch: 169122

Client Sample ID: EW-10

Prep Type: Total/NA

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec.	RPD	RPD
	Result	Qualifier	Added	Result	Qualifier				Limits		Limit
Benzene	<0.50		50.0	42.6		ug/L		85	74 - 115	11	20
Dichlorodifluoromethane	<1.0		50.0	41.1		ug/L		82	43 - 139	4	20
Chloromethane	<1.0		50.0	41.6		ug/L		83	56 - 144	2	20
Vinyl chloride	<0.50		50.0	45.7		ug/L		91	51 - 149	3	20
Bromomethane	<1.0		50.0	39.3		ug/L		79	47 - 158	9	20
Chloroethane	<1.0		50.0	37.0		ug/L		74	54 - 143	9	20
Trichlorofluoromethane	<1.0		50.0	44.5		ug/L		89	66 - 126	3	20
1,1-Dichloroethene	<1.0		50.0	44.0		ug/L		88	58 - 115	8	20
Carbon disulfide	<5.0		50.0	38.1		ug/L		76	50 - 120	6	20
Acetone	<5.0		50.0	47.3		ug/L		95	41 - 163	5	20
Methylene Chloride	<5.0		50.0	47.2		ug/L		94	63 - 130	8	20
trans-1,2-Dichloroethene	<1.0		50.0	47.5		ug/L		95	74 - 119	7	20
1,1-Dichloroethane	<1.0		50.0	46.7		ug/L		93	66 - 118	7	20
2,2-Dichloropropane	<1.0		50.0	44.3		ug/L		89	70 - 117	5	20
cis-1,2-Dichloroethene	<1.0		50.0	46.8		ug/L		94	75 - 119	7	20
Methyl Ethyl Ketone	<5.0		50.0	52.6		ug/L		105	53 - 140	7	20
Bromochloromethane	<1.0		50.0	44.7		ug/L		89	72 - 119	6	20
Chloroform	<1.0		50.0	47.9		ug/L		96	76 - 117	7	20
1,1,1-Trichloroethane	<1.0		50.0	47.3		ug/L		95	77 - 117	6	20
1,1-Dichloropropene	<1.0		50.0	43.8		ug/L		88	71 - 113	7	20
Carbon tetrachloride	<1.0		50.0	44.7		ug/L		89	72 - 124	10	20
1,2-Dichloroethane	<1.0		50.0	46.2		ug/L		92	76 - 117	9	20
Trichloroethene	<0.50		50.0	47.2		ug/L		94	75 - 120	11	20
1,2-Dichloropropane	<1.0		50.0	44.5		ug/L		89	77 - 118	11	20
Dibromomethane	<1.0		50.0	47.5		ug/L		95	76 - 120	8	20
Bromodichloromethane	<1.0		50.0	43.2		ug/L		86	79 - 117	12	20
cis-1,3-Dichloropropene	<1.0		53.8	47.7		ug/L		89	71 - 112	10	20
methyl isobutyl ketone	<5.0		50.0	44.9		ug/L		90	59 - 134	10	20
Toluene	<0.50		50.0	43.3		ug/L		87	80 - 120	12	20
trans-1,3-Dichloropropene	<1.0		48.6	43.6		ug/L		90	66 - 116	9	20
1,1,2-Trichloroethane	<1.0		50.0	44.7		ug/L		89	78 - 121	11	20
Tetrachloroethene	0.58 J		50.0	45.7		ug/L		90	71 - 120	13	20
1,3-Dichloropropane	<1.0		50.0	45.2		ug/L		90	79 - 114	10	20
2-Hexanone	<5.0		50.0	45.8		ug/L		92	60 - 134	6	20
Dibromochloromethane	<1.0		50.0	46.2		ug/L		92	73 - 120	10	20
1,2-Dibromoethane	<1.0		50.0	46.5		ug/L		93	79 - 120	10	20
Chlorobenzene	<1.0		50.0	42.1		ug/L		84	80 - 120	11	20
1,1,1,2-Tetrachloroethane	<1.0		50.0	45.7		ug/L		91	80 - 120	9	20
Ethylbenzene	<0.50		50.0	41.8		ug/L		84	79 - 115	13	20
m&p-Xylene	<1.0		100	80.6		ug/L		81	78 - 120	12	20
o-Xylene	<0.50		50.0	40.6		ug/L		81	78 - 120	11	20
Styrene	<1.0		50.0	43.3		ug/L		87	80 - 120	12	20
Bromoform	<1.0		50.0	49.6		ug/L		99	64 - 127	8	20
Isopropylbenzene	<1.0		50.0	41.3		ug/L		83	68 - 120	9	20
Bromobenzene	<1.0		50.0	46.5		ug/L		93	80 - 120	8	20
1,1,2,2-Tetrachloroethane	<1.0		50.0	46.9		ug/L		94	78 - 123	6	20
1,2,3-Trichloropropane	<1.0		50.0	48.2		ug/L		96	77 - 119	3	20
N-Propylbenzene	<1.0		50.0	39.5		ug/L		79	77 - 114	10	20

TestAmerica Chicago

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Method: 8260B - VOC (Continued)

Lab Sample ID: 500-52022-26 MSD
Matrix: Water
Analysis Batch: 169122

Client Sample ID: EW-10
Prep Type: Total/NA

Analyte	Sample	Sample	Spike	MSD		Unit	D	%Rec	%Rec.	RPD	Limit
	Result	Qualifier		Result	Qualifier				Limits		
2-Chlorotoluene	<1.0	*	50.0	41.4		ug/L		83	80 - 120	9	20
1,3,5-Trimethylbenzene	<1.0		50.0	45.5		ug/L		91	83 - 120	10	20
4-Chlorotoluene	<1.0	*	50.0	40.0		ug/L		80	80 - 120	11	20
tert-Butylbenzene	<1.0		50.0	42.8		ug/L		86	80 - 120	7	20
1,2,4-Trimethylbenzene	<1.0		50.0	43.7		ug/L		87	80 - 120	12	20
sec-Butylbenzene	<1.0		50.0	41.9		ug/L		84	79 - 117	8	20
1,3-Dichlorobenzene	<1.0		50.0	41.8		ug/L		84	80 - 120	11	20
p-Isopropyltoluene	<1.0		50.0	41.4		ug/L		83	77 - 120	10	20
1,4-Dichlorobenzene	<1.0		50.0	44.5		ug/L		89	80 - 120	11	20
n-Butylbenzene	<1.0		50.0	41.6		ug/L		83	78 - 119	13	20
1,2-Dichlorobenzene	<1.0		50.0	44.9		ug/L		90	80 - 120	9	20
1,2-Dibromo-3-Chloropropane	<2.0		50.0	47.0		ug/L		94	53 - 133	6	20
1,2,4-Trichlorobenzene	<1.0		50.0	42.7		ug/L		85	70 - 118	16	20
Hexachlorobutadiene	<1.0		50.0	42.5		ug/L		85	71 - 128	11	20
Naphthalene	<1.0		50.0	50.4		ug/L		101	72 - 127	7	20
1,2,3-Trichlorobenzene	<1.0		50.0	47.3		ug/L		95	74 - 126	12	20
MSD MSD											
Surrogate	%Recovery	Qualifier	Limits								
1,2-Dichloroethane-d4 (Surr)	99		75 - 131								
Toluene-d8 (Surr)	95		80 - 120								
4-Bromofluorobenzene (Surr)	94		79 - 120								
Dibromofluoromethane	101		74 - 123								



Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-1A

Lab Sample ID: 500-52022-1

Date Collected: 11/01/12 09:10

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169030	11/09/12 02:47	BBS	TAL CHI

Client Sample ID: RFW-1B

Lab Sample ID: 500-52022-2

Date Collected: 11/01/12 16:00

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169030	11/09/12 03:13	BBS	TAL CHI

Client Sample ID: RFW-2A

Lab Sample ID: 500-52022-3

Date Collected: 11/01/12 10:05

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169030	11/09/12 03:39	BBS	TAL CHI

Client Sample ID: RFW-2B

Lab Sample ID: 500-52022-4

Date Collected: 11/01/12 10:15

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169030	11/09/12 04:05	BBS	TAL CHI

Client Sample ID: RFW-7

Lab Sample ID: 500-52022-5

Date Collected: 11/01/12 10:55

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169030	11/09/12 04:30	BBS	TAL CHI

Client Sample ID: RFW-6

Lab Sample ID: 500-52022-6

Date Collected: 11/01/12 12:10

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169030	11/09/12 04:56	BBS	TAL CHI

TestAmerica Chicago



Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-17

Lab Sample ID: 500-52022-7

Date Collected: 11/01/12 12:50

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169030	11/09/12 05:22	BBS	TAL CHI

Client Sample ID: RFW-13

Lab Sample ID: 500-52022-8

Date Collected: 11/01/12 14:35

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169030	11/09/12 05:48	BBS	TAL CHI

Client Sample ID: RFW-3B

Lab Sample ID: 500-52022-9

Date Collected: 11/01/12 16:05

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169030	11/09/12 06:14	BBS	TAL CHI

Client Sample ID: RFW-9

Lab Sample ID: 500-52022-10

Date Collected: 11/01/12 16:45

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169030	11/09/12 06:40	BBS	TAL CHI

Client Sample ID: TRIP BLANK

Lab Sample ID: 500-52022-11

Date Collected: 11/01/12 07:00

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169030	11/09/12 07:06	BBS	TAL CHI

Client Sample ID: RFW-4A

Lab Sample ID: 500-52022-12

Date Collected: 11/02/12 08:30

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169030	11/09/12 07:32	BBS	TAL CHI

TestAmerica Chicago



Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: RFW-4A DUP

Lab Sample ID: 500-52022-13

Date Collected: 11/02/12 08:30

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169030	11/09/12 07:58	BBS	TAL CHI

Client Sample ID: RFW-4B

Lab Sample ID: 500-52022-14

Date Collected: 11/02/12 09:00

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169030	11/09/12 08:24	BBS	TAL CHI

Client Sample ID: RFW-11B

Lab Sample ID: 500-52022-15

Date Collected: 11/02/12 11:30

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169030	11/09/12 09:16	BBS	TAL CHI

Client Sample ID: RFW-12B

Lab Sample ID: 500-52022-16

Date Collected: 11/02/12 12:30

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169122	11/09/12 13:51	LM	TAL CHI

Client Sample ID: EW-2

Lab Sample ID: 500-52022-17

Date Collected: 11/02/12 12:10

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169122	11/09/12 21:35	LM	TAL CHI

Client Sample ID: EW-3

Lab Sample ID: 500-52022-18

Date Collected: 11/02/12 10:00

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169122	11/09/12 15:35	LM	TAL CHI

TestAmerica Chicago



Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-4
Date Collected: 11/02/12 10:35
Date Received: 11/03/12 11:20

Lab Sample ID: 500-52022-19
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B	DL	5	169122	11/09/12 16:27	LM	TAL CHI
Total/NA	Analysis	8260B		1	169122	11/09/12 22:00	LM	TAL CHI

Client Sample ID: EW-5
Date Collected: 11/01/12 09:05
Date Received: 11/03/12 11:20

Lab Sample ID: 500-52022-20
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169122	11/09/12 22:27	LM	TAL CHI

Client Sample ID: EW-6
Date Collected: 11/01/12 11:40
Date Received: 11/03/12 11:20

Lab Sample ID: 500-52022-21
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169122	11/09/12 18:11	LM	TAL CHI

Client Sample ID: EW-7
Date Collected: 11/01/12 11:35
Date Received: 11/03/12 11:20

Lab Sample ID: 500-52022-22
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169122	11/09/12 18:38	LM	TAL CHI

Client Sample ID: EW-8
Date Collected: 11/01/12 11:25
Date Received: 11/03/12 11:20

Lab Sample ID: 500-52022-23
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169122	11/09/12 19:03	LM	TAL CHI

Client Sample ID: EW-8 DUP
Date Collected: 11/01/12 11:25
Date Received: 11/03/12 11:20

Lab Sample ID: 500-52022-24
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169122	11/09/12 19:55	LM	TAL CHI

TestAmerica Chicago



Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Client Sample ID: EW-9

Lab Sample ID: 500-52022-25

Date Collected: 11/01/12 11:15

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169122	11/09/12 22:53	LM	TAL CHI

Client Sample ID: EW-10

Lab Sample ID: 500-52022-26

Date Collected: 11/01/12 10:45

Matrix: Water

Date Received: 11/03/12 11:20

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	8260B		1	169122	11/09/12 21:13	LM	TAL CHI

Laboratory References:

TAL CHI = TestAmerica Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200



Certification Summary

Client: Weston Solutions, Inc.
 Project/Site: Black and Decker

TestAmerica Job ID: 500-52022-1

Laboratory: TestAmerica Chicago

All certifications held by this laboratory are listed. Not all certifications are applicable to this report.

Authority	Program	EPA Region	Certification ID	Expiration Date
Alabama	State Program	4	40461	04-30-13
California	NELAC	9	01132CA	04-30-13
Georgia	State Program	4	N/A	04-30-13
Georgia	State Program	4	939	04-30-13
Hawaii	State Program	9	N/A	04-30-13
Illinois	NELAC	5	100201	04-30-13
Indiana	State Program	5	C-IL-02	04-30-13
Iowa	State Program	7	82	05-01-14
Kansas	NELAC	7	E-10161	10-31-13
Kentucky	State Program	4	90023	12-31-12
Kentucky (UST)	State Program	4	66	04-11-13
L-A-B	DoD ELAP		L2304	01-06-13
L-A-B	ISO/IEC 17025		L2304	01-06-13
Louisiana	NELAC	6	30720	06-30-13
Massachusetts	State Program	1	M-IL035	06-30-13
Mississippi	State Program	4	N/A	04-30-13
North Carolina DENR	State Program	4	291	12-31-12
North Dakota	State Program	8	R-194	04-30-13
Oklahoma	State Program	6	8908	08-31-13
South Carolina	State Program	4	77001	04-30-13
Texas	NELAC	6	T104704252-09-TX	02-28-13
USDA	Federal		P330-12-00038	02-06-15
Virginia	NELAC	3	460142	06-14-13
Wisconsin	State Program	5	999580010	08-31-13
Wyoming	State Program	8	8TMS-Q	04-30-13



Chain of Custody Record

Client Information		Sample:		Lab PM:		Carrier Tracking No(s):		COC No:	
Client Contact: Mr. Tom Cornuet		Phone:		Wright, Richard C				500-17807-10127.3	
Company: Weston Solutions, Inc.				E-Mail: richard.wright@testamericainc.com				Page: Page 3 of 4	
Address: 1400 Weston Way PO BOX 2653		Due Date Requested:		Analysis Requested		Job #: 500-52022		Preservation Codes: A - HCL M - Hexane B - NaOH N - None C - Zn Acetate O - AsNaO2 D - Nitric Acid P - Na2O4S E - NaHSO4 Q - Na2SO3 F - MeOH R - Na2S2SO3 G - Amchlor S - H2SO4 H - Ascorbic Acid T - TSP Dodecahydrate I - Ice U - Acetone J - Di Water V - MCAA K - EDTA W - ph 4-5 L - EDA Z - other (specify)	
City: West Chester		TAT Requested (days):							
State, Zip: PA, 19380									
Phone: 610-701-7360(Tel) 610-701-7401(Fax)		PO #: 50357							
Email: tom.cornuet@westonsolutions.com		WO #: 02501.004.004.0200		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		Total Number of Containers	
Project Name: Black and Decker		Project #: 50000227		VOC					
Site:		SSOW#:						Other:	
Sample Identification		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (Water, Solid, On-water, etc.)	
								Special Instructions/Note:	
17	EW-2	11/2/12	1210	G	W				
18	EW-3	I	1000	I	I				
19	EW-4	I	1025	I	I				
20	EW-5	11/2/12	905	I	I				
21	EW-6	I	1140	I	I				
22	EW-7	I	1135	I	I				
23	EW-8	I	1125	I	I				
24	EW-8 Dup	I	1125	I	I				
25	EW-9	I	1115	I	I				
26	EW-10	I	1045	I	I				
Possible Hazard Identification					Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)				
<input type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant <input type="checkbox"/> Poison B <input type="checkbox"/> Unknown <input type="checkbox"/> Radiological					<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months				
Deliverable Requested: I, II, III, IV, Other (specify)					Special Instructions/QC Requirements:				
Empty Kit Relinquished by:		Date:		Time:		Method of Shipment:			
Relinquished by: [Signature]		Date/Time: 11/2/12 1630		Company:		Received by: [Signature]		Date/Time: 11/3/12 1120	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Custody Seals Intact: <input type="checkbox"/> Yes <input type="checkbox"/> No		Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks:					



Login Sample Receipt Checklist

Client: Weston Solutions, Inc.

Job Number: 500-52022-1

Login Number: 52022

List Source: TestAmerica Chicago

List Number: 1

Creator: Lunt, Jeff T

Question	Answer	Comment
Radioactivity wasn't checked or is \leq background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	2.7
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	



TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.
TestAmerica Savannah
5102 LaRoche Avenue
Savannah, GA 31404
Tel: (912)354-7858

TestAmerica Job ID: 680-84406-1
Client Project/Site: Black & Decker

For:
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
West Chester, Pennsylvania 19380

Attn: Greg Flasinski



Authorized for release by:
11/9/2012 3:56:48 PM

Lisa Harvey
Project Manager II
lisa.harvey@testamericainc.com

LINKS

Review your project
results through
Total Access

Have a Question?
**Ask
The
Expert**

Visit us at:
www.testamericainc.com

The test results in this report meet all 2003 NELAC and 2009 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

1

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

Case Narrative

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Job ID: 680-84406-1

Laboratory: TestAmerica Savannah

Narrative

CASE NARRATIVE

Client: Weston Solutions, Inc.

Project: Black & Decker

Report Number: 680-84406-1

With the exceptions noted as flags or footnotes, standard analytical protocols were followed in the analysis of the samples and no problems were encountered or anomalies observed. In addition all laboratory quality control samples were within established control limits, with any exceptions noted below. Each sample was analyzed to achieve the lowest possible reporting limit within the constraints of the method. In some cases, due to interference or analytes present at high concentrations, samples were diluted. For diluted samples, the reporting limits are adjusted relative to the dilution required.

Calculations are performed before rounding to avoid round-off errors in calculated results.

All holding times were met and proper preservation noted for the methods performed on these samples, unless otherwise detailed in the individual sections below.

RECEIPT

The samples were received on 11/03/2012; the samples arrived in good condition, properly preserved and on ice. The temperature of the coolers at receipt was 4.0 C.

VOLATILE ORGANIC COMPOUNDS (GC-MS)

Samples Trip Blank (680-84406-1), RFW-21 (680-84406-2), RFW-20 (680-84406-3), HAMP 22 (680-84406-4) and HAMP 23 (680-84406-5) were analyzed for Volatile organic Compounds (GC-MS) in accordance with EPA Method 524.2. The samples were analyzed on 11/06/2012.

Method(s) 524.2: A full list spike was utilized for this method. Due to the large number of spiked analytes, there is a high probability that one or more analytes will recover outside acceptance limits. The laboratory's SOP allows for three analytes to recover outside criteria for this method when a full list spike is utilized. The LCSD associated with batch 255503 had one analytes outside control limits; therefore, re-extraction/re-analysis was not performed. These results have been reported and qualified.

Sample Summary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
680-84406-1	Trip Blank	Water	11/01/12 07:00	11/03/12 09:20
680-84406-2	RFW-21	Water	11/01/12 07:23	11/03/12 09:20
680-84406-3	RFW-20	Water	11/01/12 15:00	11/03/12 09:20
680-84406-4	HAMP 22	Water	11/02/12 09:40	11/03/12 09:20
680-84406-5	HAMP 23	Water	11/02/12 09:45	11/03/12 09:20

Method Summary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1


Method	Method Description	Protocol	Laboratory
524.2	Volatile Organic Compounds (GC/MS)	EPA-DW	TAL SAV

Protocol References:

EPA-DW = "Methods For The Determination Of Organic Compounds In Drinking Water", EPA/600/4-88/039, December 1988 And Its Supplements.

Laboratory References:

TAL SAV = TestAmerica Savannah, 5102 LaRoche Avenue, Savannah, GA 31404, TEL (912)354-7858



Definitions/Glossary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Qualifiers

GC/MS VOA

Qualifier	Qualifier Description
.	LCS or LCSD exceeds the control limits
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CNF	Contains no Free Liquid
DL, RA, RE, IN	Indicates a Dilution, Reanalysis, Re-extraction, or additional Initial metals/anion analysis of the sample
EDL	Estimated Detection Limit
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RL	Reporting Limit
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
MDA	Minimum detectable activity
MDC	Minimum detectable concentration
RER	Relative error ratio
DER	Duplicate error ratio (normalized absolute difference)
DLC	Decision level concentration
RL	Reporting Limit or Requested Limit (Radiochemistry only)

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-84406-1

Date Collected: 11/01/12 07:00

Matrix: Water

Date Received: 11/03/12 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			11/06/12 21:45	1
Benzene	<0.50		0.50	0.18	ug/L			11/06/12 21:45	1
Bromobenzene	<0.50		0.50	0.42	ug/L			11/06/12 21:45	1
Bromoform	<0.50		0.50	0.39	ug/L			11/06/12 21:45	1
Bromomethane	<1.0		1.0	0.45	ug/L			11/06/12 21:45	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			11/06/12 21:45	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			11/06/12 21:45	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			11/06/12 21:45	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			11/06/12 21:45	1
Chloroethane	<1.0		1.0	0.33	ug/L			11/06/12 21:45	1
Chloroform	<0.50		0.50	0.29	ug/L			11/06/12 21:45	1
Chloromethane	<0.50		0.50	0.32	ug/L			11/06/12 21:45	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			11/06/12 21:45	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			11/06/12 21:45	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			11/06/12 21:45	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			11/06/12 21:45	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			11/06/12 21:45	1
Dibromomethane	<0.50		0.50	0.38	ug/L			11/06/12 21:45	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			11/06/12 21:45	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			11/06/12 21:45	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			11/06/12 21:45	1
Dichlorobromomethane	<1.0		1.0	0.54	ug/L			11/06/12 21:45	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			11/06/12 21:45	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			11/06/12 21:45	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			11/06/12 21:45	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			11/06/12 21:45	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			11/06/12 21:45	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			11/06/12 21:45	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			11/06/12 21:45	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			11/06/12 21:45	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			11/06/12 21:45	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			11/06/12 21:45	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			11/06/12 21:45	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			11/06/12 21:45	1
Freon 113	<0.50		0.50	0.15	ug/L			11/06/12 21:45	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			11/06/12 21:45	1
2-Hexanone	<10		10	5.0	ug/L			11/06/12 21:45	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			11/06/12 21:45	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			11/06/12 21:45	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			11/06/12 21:45	1
2-Butanone (MEK)	<10		10	5.0	ug/L			11/06/12 21:45	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			11/06/12 21:45	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			11/06/12 21:45	1
Naphthalene	<1.0		1.0	0.43	ug/L			11/06/12 21:45	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 21:45	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 21:45	1
o-Xylene	<0.50		0.50	0.27	ug/L			11/06/12 21:45	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			11/06/12 21:45	1
Styrene	<0.50		0.50	0.28	ug/L			11/06/12 21:45	1
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			11/06/12 21:45	1
tert-Butyl alcohol	<2.0		2.0	1.6	ug/L			11/06/12 21:45	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-84406-1

Date Collected: 11/01/12 07:00

Matrix: Water

Date Received: 11/03/12 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			11/06/12 21:45	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			11/06/12 21:45	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			11/06/12 21:45	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			11/06/12 21:45	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			11/06/12 21:45	1
Toluene	<0.50		0.50	0.23	ug/L			11/06/12 21:45	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			11/06/12 21:45	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			11/06/12 21:45	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			11/06/12 21:45	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			11/06/12 21:45	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			11/06/12 21:45	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			11/06/12 21:45	1
Trichloroethene	<0.50		0.50	0.37	ug/L			11/06/12 21:45	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			11/06/12 21:45	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			11/06/12 21:45	1
Trihalomethanes, Total	<0.50		0.50	0.29	ug/L			11/06/12 21:45	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 21:45	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			11/06/12 21:45	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			11/06/12 21:45	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			11/06/12 21:45	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	98		70 - 130		11/06/12 21:45	1
1,2-Dichlorobenzene-d4	91		70 - 130		11/06/12 21:45	1

Client Sample ID: RFW-21

Lab Sample ID: 680-84406-2

Date Collected: 11/01/12 07:23

Matrix: Water

Date Received: 11/03/12 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			11/06/12 22:11	1
Benzene	<0.50		0.50	0.18	ug/L			11/06/12 22:11	1
Bromobenzene	<0.50		0.50	0.42	ug/L			11/06/12 22:11	1
Bromoform	<0.50		0.50	0.39	ug/L			11/06/12 22:11	1
Bromomethane	<1.0		1.0	0.45	ug/L			11/06/12 22:11	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			11/06/12 22:11	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			11/06/12 22:11	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			11/06/12 22:11	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			11/06/12 22:11	1
Chloroethane	<1.0		1.0	0.33	ug/L			11/06/12 22:11	1
Chloroform	<0.50		0.50	0.29	ug/L			11/06/12 22:11	1
Chloromethane	<0.50		0.50	0.32	ug/L			11/06/12 22:11	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			11/06/12 22:11	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			11/06/12 22:11	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			11/06/12 22:11	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			11/06/12 22:11	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			11/06/12 22:11	1
Dibromomethane	<0.50		0.50	0.38	ug/L			11/06/12 22:11	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			11/06/12 22:11	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			11/06/12 22:11	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Client Sample ID: RFW-21

Lab Sample ID: 680-84406-2

Date Collected: 11/01/12 07:23

Matrix: Water

Date Received: 11/03/12 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			11/06/12 22:11	1
Dichlorobromomethane	<1.0		1.0	0.54	ug/L			11/06/12 22:11	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			11/06/12 22:11	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			11/06/12 22:11	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			11/06/12 22:11	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			11/06/12 22:11	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			11/06/12 22:11	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			11/06/12 22:11	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			11/06/12 22:11	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			11/06/12 22:11	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			11/06/12 22:11	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			11/06/12 22:11	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			11/06/12 22:11	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			11/06/12 22:11	1
Freon 113	<0.50		0.50	0.15	ug/L			11/06/12 22:11	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			11/06/12 22:11	1
2-Hexanone	<10		10	5.0	ug/L			11/06/12 22:11	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			11/06/12 22:11	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			11/06/12 22:11	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			11/06/12 22:11	1
2-Butanone (MEK)	<10		10	5.0	ug/L			11/06/12 22:11	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			11/06/12 22:11	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			11/06/12 22:11	1
Naphthalene	<1.0		1.0	0.43	ug/L			11/06/12 22:11	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 22:11	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 22:11	1
o-Xylene	<0.50		0.50	0.27	ug/L			11/06/12 22:11	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			11/06/12 22:11	1
Styrene	<0.50		0.50	0.28	ug/L			11/06/12 22:11	1
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			11/06/12 22:11	1
tert-Butyl alcohol	<2.0		2.0	1.6	ug/L			11/06/12 22:11	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			11/06/12 22:11	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			11/06/12 22:11	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			11/06/12 22:11	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			11/06/12 22:11	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			11/06/12 22:11	1
Toluene	<0.50		0.50	0.23	ug/L			11/06/12 22:11	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			11/06/12 22:11	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			11/06/12 22:11	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			11/06/12 22:11	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			11/06/12 22:11	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			11/06/12 22:11	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			11/06/12 22:11	1
Trichloroethene	<0.50		0.50	0.37	ug/L			11/06/12 22:11	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			11/06/12 22:11	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			11/06/12 22:11	1
Trihalomethanes, Total	<0.50		0.50	0.29	ug/L			11/06/12 22:11	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 22:11	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			11/06/12 22:11	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			11/06/12 22:11	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			11/06/12 22:11	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Client Sample ID: RFW-21

Lab Sample ID: 680-84406-2

Date Collected: 11/01/12 07:23

Matrix: Water

Date Received: 11/03/12 09:20

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	94		70 - 130		11/06/12 22:11	1
1,2-Dichlorobenzene-d4	96		70 - 130		11/06/12 22:11	1

Client Sample ID: RFW-20

Lab Sample ID: 680-84406-3

Date Collected: 11/01/12 15:00

Matrix: Water

Date Received: 11/03/12 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			11/06/12 22:38	1
Benzene	<0.50		0.50	0.18	ug/L			11/06/12 22:38	1
Bromobenzene	<0.50		0.50	0.42	ug/L			11/06/12 22:38	1
Bromoform	<0.50		0.50	0.39	ug/L			11/06/12 22:38	1
Bromomethane	<1.0		1.0	0.45	ug/L			11/06/12 22:38	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			11/06/12 22:38	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			11/06/12 22:38	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			11/06/12 22:38	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			11/06/12 22:38	1
Chloroethane	<1.0		1.0	0.33	ug/L			11/06/12 22:38	1
Chloroform	<0.50		0.50	0.29	ug/L			11/06/12 22:38	1
Chloromethane	<0.50		0.50	0.32	ug/L			11/06/12 22:38	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			11/06/12 22:38	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			11/06/12 22:38	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			11/06/12 22:38	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			11/06/12 22:38	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			11/06/12 22:38	1
Dibromomethane	<0.50		0.50	0.38	ug/L			11/06/12 22:38	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			11/06/12 22:38	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			11/06/12 22:38	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			11/06/12 22:38	1
Dichlorobromomethane	<1.0		1.0	0.54	ug/L			11/06/12 22:38	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			11/06/12 22:38	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			11/06/12 22:38	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			11/06/12 22:38	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			11/06/12 22:38	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			11/06/12 22:38	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			11/06/12 22:38	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			11/06/12 22:38	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			11/06/12 22:38	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			11/06/12 22:38	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			11/06/12 22:38	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			11/06/12 22:38	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			11/06/12 22:38	1
Freon 113	<0.50		0.50	0.15	ug/L			11/06/12 22:38	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			11/06/12 22:38	1
2-Hexanone	<10		10	5.0	ug/L			11/06/12 22:38	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			11/06/12 22:38	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			11/06/12 22:38	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			11/06/12 22:38	1
2-Butanone (MEK)	<10		10	5.0	ug/L			11/06/12 22:38	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			11/06/12 22:38	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			11/06/12 22:38	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Client Sample ID: RFW-20

Lab Sample ID: 680-84406-3

Date Collected: 11/01/12 15:00

Matrix: Water

Date Received: 11/03/12 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Naphthalene	<1.0		1.0	0.43	ug/L			11/06/12 22:38	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 22:38	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 22:38	1
o-Xylene	<0.50		0.50	0.27	ug/L			11/06/12 22:38	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			11/06/12 22:38	1
Styrene	<0.50		0.50	0.28	ug/L			11/06/12 22:38	1
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			11/06/12 22:38	1
tert-Butyl alcohol	<2.0		2.0	1.6	ug/L			11/06/12 22:38	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			11/06/12 22:38	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			11/06/12 22:38	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			11/06/12 22:38	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			11/06/12 22:38	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			11/06/12 22:38	1
Toluene	<0.50		0.50	0.23	ug/L			11/06/12 22:38	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			11/06/12 22:38	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			11/06/12 22:38	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			11/06/12 22:38	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			11/06/12 22:38	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			11/06/12 22:38	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			11/06/12 22:38	1
Trichloroethene	0.50		0.50	0.37	ug/L			11/06/12 22:38	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			11/06/12 22:38	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			11/06/12 22:38	1
Trihalomethanes, Total	<0.50		0.50	0.29	ug/L			11/06/12 22:38	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 22:38	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			11/06/12 22:38	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			11/06/12 22:38	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			11/06/12 22:38	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	102		70 - 130					11/06/12 22:38	1
1,2-Dichlorobenzene-d4	97		70 - 130					11/06/12 22:38	1

Client Sample ID: HAMP 22

Lab Sample ID: 680-84406-4

Date Collected: 11/02/12 09:40

Matrix: Water

Date Received: 11/03/12 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			11/06/12 23:05	1
Benzene	<0.50		0.50	0.18	ug/L			11/06/12 23:05	1
Bromobenzene	<0.50		0.50	0.42	ug/L			11/06/12 23:05	1
Bromoform	<0.50		0.50	0.39	ug/L			11/06/12 23:05	1
Bromomethane	<1.0		1.0	0.45	ug/L			11/06/12 23:05	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			11/06/12 23:05	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			11/06/12 23:05	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			11/06/12 23:05	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			11/06/12 23:05	1
Chloroethane	<1.0		1.0	0.33	ug/L			11/06/12 23:05	1
Chloroform	0.51		0.50	0.29	ug/L			11/06/12 23:05	1
Chloromethane	<0.50		0.50	0.32	ug/L			11/06/12 23:05	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Client Sample ID: HAMP 22

Lab Sample ID: 680-84406-4

Date Collected: 11/02/12 09:40

Matrix: Water

Date Received: 11/03/12 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			11/06/12 23:05	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			11/06/12 23:05	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			11/06/12 23:05	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			11/06/12 23:05	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			11/06/12 23:05	1
Dibromomethane	<0.50		0.50	0.38	ug/L			11/06/12 23:05	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			11/06/12 23:05	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			11/06/12 23:05	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			11/06/12 23:05	1
Dichlorobromomethane	<1.0		1.0	0.54	ug/L			11/06/12 23:05	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			11/06/12 23:05	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			11/06/12 23:05	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			11/06/12 23:05	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			11/06/12 23:05	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			11/06/12 23:05	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			11/06/12 23:05	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			11/06/12 23:05	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			11/06/12 23:05	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			11/06/12 23:05	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			11/06/12 23:05	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			11/06/12 23:05	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			11/06/12 23:05	1
Freon 113	<0.50		0.50	0.15	ug/L			11/06/12 23:05	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			11/06/12 23:05	1
2-Hexanone	<10		10	5.0	ug/L			11/06/12 23:05	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			11/06/12 23:05	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			11/06/12 23:05	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			11/06/12 23:05	1
2-Butanone (MEK)	<10		10	5.0	ug/L			11/06/12 23:05	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			11/06/12 23:05	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			11/06/12 23:05	1
Naphthalene	<1.0		1.0	0.43	ug/L			11/06/12 23:05	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 23:05	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 23:05	1
o-Xylene	<0.50		0.50	0.27	ug/L			11/06/12 23:05	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			11/06/12 23:05	1
Styrene	<0.50		0.50	0.28	ug/L			11/06/12 23:05	1
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			11/06/12 23:05	1
tert-Butyl alcohol	<2.0		2.0	1.6	ug/L			11/06/12 23:05	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			11/06/12 23:05	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			11/06/12 23:05	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			11/06/12 23:05	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			11/06/12 23:05	1
Tetrachloroethene	0.34	J	0.50	0.30	ug/L			11/06/12 23:05	1
Toluene	<0.50		0.50	0.23	ug/L			11/06/12 23:05	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			11/06/12 23:05	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			11/06/12 23:05	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			11/06/12 23:05	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			11/06/12 23:05	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			11/06/12 23:05	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			11/06/12 23:05	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Client Sample ID: HAMP 22

Lab Sample ID: 680-84406-4

Date Collected: 11/02/12 09:40

Matrix: Water

Date Received: 11/03/12 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Trichloroethene	<0.50		0.50	0.37	ug/L			11/06/12 23:05	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			11/06/12 23:05	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			11/06/12 23:05	1
Trihalomethanes, Total	0.51		0.50	0.29	ug/L			11/06/12 23:05	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 23:05	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			11/06/12 23:05	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			11/06/12 23:05	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			11/06/12 23:05	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	98		70 - 130					11/06/12 23:05	1
1,2-Dichlorobenzene-d4	88		70 - 130					11/06/12 23:05	1

Client Sample ID: HAMP 23

Lab Sample ID: 680-84406-5

Date Collected: 11/02/12 09:45

Matrix: Water

Date Received: 11/03/12 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			11/06/12 23:32	1
Benzene	<0.50		0.50	0.18	ug/L			11/06/12 23:32	1
Bromobenzene	<0.50		0.50	0.42	ug/L			11/06/12 23:32	1
Bromoform	<0.50		0.50	0.39	ug/L			11/06/12 23:32	1
Bromomethane	<1.0		1.0	0.45	ug/L			11/06/12 23:32	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			11/06/12 23:32	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			11/06/12 23:32	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			11/06/12 23:32	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			11/06/12 23:32	1
Chloroethane	<1.0		1.0	0.33	ug/L			11/06/12 23:32	1
Chloroform	<0.50		0.50	0.29	ug/L			11/06/12 23:32	1
Chloromethane	<0.50		0.50	0.32	ug/L			11/06/12 23:32	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			11/06/12 23:32	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			11/06/12 23:32	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			11/06/12 23:32	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			11/06/12 23:32	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			11/06/12 23:32	1
Dibromomethane	<0.50		0.50	0.38	ug/L			11/06/12 23:32	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			11/06/12 23:32	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			11/06/12 23:32	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			11/06/12 23:32	1
Dichlorobromomethane	<1.0		1.0	0.54	ug/L			11/06/12 23:32	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			11/06/12 23:32	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			11/06/12 23:32	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			11/06/12 23:32	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			11/06/12 23:32	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			11/06/12 23:32	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			11/06/12 23:32	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			11/06/12 23:32	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			11/06/12 23:32	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			11/06/12 23:32	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			11/06/12 23:32	1

Client Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Client Sample ID: HAMP 23

Lab Sample ID: 680-84406-5

Date Collected: 11/02/12 09:45

Matrix: Water

Date Received: 11/03/12 09:20

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Ethylbenzene	<0.50		0.50	0.12	ug/L			11/06/12 23:32	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			11/06/12 23:32	1
Freon 113	<0.50		0.50	0.15	ug/L			11/06/12 23:32	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			11/06/12 23:32	1
2-Hexanone	<10		10	5.0	ug/L			11/06/12 23:32	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			11/06/12 23:32	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			11/06/12 23:32	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			11/06/12 23:32	1
2-Butanone (MEK)	<10		10	5.0	ug/L			11/06/12 23:32	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			11/06/12 23:32	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			11/06/12 23:32	1
Naphthalene	<1.0		1.0	0.43	ug/L			11/06/12 23:32	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 23:32	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 23:32	1
o-Xylene	<0.50		0.50	0.27	ug/L			11/06/12 23:32	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			11/06/12 23:32	1
Styrene	<0.50		0.50	0.28	ug/L			11/06/12 23:32	1
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			11/06/12 23:32	1
tert-Butyl alcohol	<2.0		2.0	1.6	ug/L			11/06/12 23:32	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			11/06/12 23:32	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			11/06/12 23:32	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			11/06/12 23:32	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			11/06/12 23:32	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			11/06/12 23:32	1
Toluene	<0.50		0.50	0.23	ug/L			11/06/12 23:32	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			11/06/12 23:32	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			11/06/12 23:32	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			11/06/12 23:32	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			11/06/12 23:32	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			11/06/12 23:32	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			11/06/12 23:32	1
Trichloroethene	<0.50		0.50	0.37	ug/L			11/06/12 23:32	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			11/06/12 23:32	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			11/06/12 23:32	1
Trihalomethanes, Total	<0.50		0.50	0.29	ug/L			11/06/12 23:32	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 23:32	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			11/06/12 23:32	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			11/06/12 23:32	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			11/06/12 23:32	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene	94		70 - 130					11/06/12 23:32	1
1,2-Dichlorobenzene-d4	95		70 - 130					11/06/12 23:32	1

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Lab Sample ID: MB 680-255503/5

Matrix: Water

Analysis Batch: 255503

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<10		10	5.0	ug/L			11/06/12 17:18	1
Benzene	<0.50		0.50	0.18	ug/L			11/06/12 17:18	1
Bromobenzene	<0.50		0.50	0.42	ug/L			11/06/12 17:18	1
Bromoform	<0.50		0.50	0.39	ug/L			11/06/12 17:18	1
Bromomethane	<1.0		1.0	0.45	ug/L			11/06/12 17:18	1
Carbon tetrachloride	<0.50		0.50	0.22	ug/L			11/06/12 17:18	1
Chlorobenzene	<0.50		0.50	0.27	ug/L			11/06/12 17:18	1
Chlorobromomethane	<0.50		0.50	0.30	ug/L			11/06/12 17:18	1
Chlorodibromomethane	<0.50		0.50	0.43	ug/L			11/06/12 17:18	1
Chloroethane	<1.0		1.0	0.33	ug/L			11/06/12 17:18	1
Chloroform	<0.50		0.50	0.29	ug/L			11/06/12 17:18	1
Chloromethane	<0.50		0.50	0.32	ug/L			11/06/12 17:18	1
2-Chlorotoluene	<0.50		0.50	0.17	ug/L			11/06/12 17:18	1
4-Chlorotoluene	<0.50		0.50	0.16	ug/L			11/06/12 17:18	1
cis-1,2-Dichloroethene	<0.50		0.50	0.37	ug/L			11/06/12 17:18	1
cis-1,3-Dichloropropene	<0.50		0.50	0.32	ug/L			11/06/12 17:18	1
1,2-Dibromo-3-Chloropropane	<0.50		0.50	0.30	ug/L			11/06/12 17:18	1
Dibromomethane	<0.50		0.50	0.38	ug/L			11/06/12 17:18	1
1,2-Dichlorobenzene	<0.50		0.50	0.17	ug/L			11/06/12 17:18	1
1,3-Dichlorobenzene	<0.50		0.50	0.14	ug/L			11/06/12 17:18	1
1,4-Dichlorobenzene	<0.50		0.50	0.18	ug/L			11/06/12 17:18	1
Dichlorobromomethane	<1.0		1.0	0.54	ug/L			11/06/12 17:18	1
Dichlorodifluoromethane	<0.50		0.50	0.34	ug/L			11/06/12 17:18	1
1,1-Dichloroethane	<0.50		0.50	0.39	ug/L			11/06/12 17:18	1
1,2-Dichloroethane	<0.50		0.50	0.17	ug/L			11/06/12 17:18	1
1,1-Dichloroethene	<0.50		0.50	0.32	ug/L			11/06/12 17:18	1
1,2-Dichloropropane	<0.50		0.50	0.45	ug/L			11/06/12 17:18	1
1,3-Dichloropropane	<0.50		0.50	0.43	ug/L			11/06/12 17:18	1
2,2-Dichloropropane	<0.50		0.50	0.31	ug/L			11/06/12 17:18	1
1,1-Dichloropropene	<0.50		0.50	0.19	ug/L			11/06/12 17:18	1
1,3-Dichloropropene, Total	<0.50		0.50	0.32	ug/L			11/06/12 17:18	1
Diisopropyl ether	<0.50		0.50	0.28	ug/L			11/06/12 17:18	1
Ethylbenzene	<0.50		0.50	0.12	ug/L			11/06/12 17:18	1
Ethylene Dibromide	<0.50		0.50	0.20	ug/L			11/06/12 17:18	1
Freon 113	<0.50		0.50	0.15	ug/L			11/06/12 17:18	1
Hexachlorobutadiene	<0.50		0.50	0.26	ug/L			11/06/12 17:18	1
2-Hexanone	<10		10	5.0	ug/L			11/06/12 17:18	1
Isopropylbenzene	<0.50		0.50	0.15	ug/L			11/06/12 17:18	1
4-Isopropyltoluene	<0.50		0.50	0.21	ug/L			11/06/12 17:18	1
Methylene Chloride	<0.50		0.50	0.36	ug/L			11/06/12 17:18	1
2-Butanone (MEK)	<10		10	5.0	ug/L			11/06/12 17:18	1
4-Methyl-2-pentanone (MIBK)	<10		10	5.0	ug/L			11/06/12 17:18	1
m-Xylene & p-Xylene	<0.50		0.50	0.42	ug/L			11/06/12 17:18	1
Naphthalene	<1.0		1.0	0.43	ug/L			11/06/12 17:18	1
n-Butylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 17:18	1
N-Propylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 17:18	1
o-Xylene	<0.50		0.50	0.27	ug/L			11/06/12 17:18	1
sec-Butylbenzene	<0.50		0.50	0.14	ug/L			11/06/12 17:18	1
Styrene	<0.50		0.50	0.28	ug/L			11/06/12 17:18	1

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 680-255503/5
Matrix: Water
Analysis Batch: 255503

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Tert-amyl methyl ether	<0.50		0.50	0.20	ug/L			11/06/12 17:18	1
tert-Butyl alcohol	<2.0		2.0	1.6	ug/L			11/06/12 17:18	1
tert-Butylbenzene	<0.50		0.50	0.14	ug/L			11/06/12 17:18	1
Tert-butyl ethyl ether	<0.50		0.50	0.26	ug/L			11/06/12 17:18	1
1,1,1,2-Tetrachloroethane	<0.50		0.50	0.16	ug/L			11/06/12 17:18	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	0.18	ug/L			11/06/12 17:18	1
Tetrachloroethene	<0.50		0.50	0.30	ug/L			11/06/12 17:18	1
Toluene	<0.50		0.50	0.23	ug/L			11/06/12 17:18	1
trans-1,2-Dichloroethene	<0.50		0.50	0.24	ug/L			11/06/12 17:18	1
trans-1,3-Dichloropropene	<0.50		0.50	0.48	ug/L			11/06/12 17:18	1
1,2,3-Trichlorobenzene	<0.50		0.50	0.14	ug/L			11/06/12 17:18	1
1,2,4-Trichlorobenzene	<0.50		0.50	0.18	ug/L			11/06/12 17:18	1
1,1,1-Trichloroethane	<0.50		0.50	0.27	ug/L			11/06/12 17:18	1
1,1,2-Trichloroethane	<0.50		0.50	0.22	ug/L			11/06/12 17:18	1
Trichloroethene	<0.50		0.50	0.37	ug/L			11/06/12 17:18	1
Trichlorofluoromethane	<0.50		0.50	0.23	ug/L			11/06/12 17:18	1
1,2,3-Trichloropropane	<0.50		0.50	0.18	ug/L			11/06/12 17:18	1
Trihalomethanes, Total	<0.50		0.50	0.29	ug/L			11/06/12 17:18	1
1,2,4-Trimethylbenzene	<0.50		0.50	0.17	ug/L			11/06/12 17:18	1
1,3,5-Trimethylbenzene	<0.50		0.50	0.16	ug/L			11/06/12 17:18	1
Vinyl chloride	<0.50		0.50	0.33	ug/L			11/06/12 17:18	1
Xylenes, Total	<0.50		0.50	0.27	ug/L			11/06/12 17:18	1

Surrogate	MB MB		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
4-Bromofluorobenzene	95		70 - 130		11/06/12 17:18	1
1,2-Dichlorobenzene-d4	95		70 - 130		11/06/12 17:18	1

Lab Sample ID: LCS 680-255503/3
Matrix: Water
Analysis Batch: 255503

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS	LCS	Unit	D	%Rec	%Rec. Limits
		Result	Qualifier				
Acetone	40.0	43.8		ug/L		110	70 - 130
Benzene	20.0	17.4		ug/L		87	70 - 130
Bromobenzene	20.0	19.8		ug/L		99	70 - 130
Bromoform	20.0	14.5		ug/L		72	70 - 130
Bromomethane	20.0	25.3		ug/L		127	70 - 130
Carbon tetrachloride	20.0	19.7		ug/L		98	70 - 130
Chlorobenzene	20.0	19.3		ug/L		97	70 - 130
Chlorobromomethane	20.0	19.0		ug/L		95	70 - 130
Chlorodibromomethane	20.0	17.9		ug/L		89	70 - 130
Chloroethane	20.0	14.4		ug/L		72	70 - 130
Chloroform	20.0	19.8		ug/L		99	70 - 130
Chloromethane	20.0	15.1		ug/L		75	70 - 130
2-Chlorotoluene	20.0	20.4		ug/L		102	70 - 130
4-Chlorotoluene	20.0	21.0		ug/L		105	70 - 130
cis-1,2-Dichloroethene	20.0	18.2		ug/L		91	70 - 130
cis-1,3-Dichloropropene	20.0	18.6		ug/L		93	70 - 130
1,2-Dibromo-3-Chloropropane	20.0	16.1		ug/L		80	70 - 130

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 680-255503/3

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 255503

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Dibromomethane	20.0	19.1		ug/L		96	70 - 130
1,2-Dichlorobenzene	20.0	21.0		ug/L		105	70 - 130
1,3-Dichlorobenzene	20.0	20.6		ug/L		103	70 - 130
1,4-Dichlorobenzene	20.0	21.1		ug/L		106	70 - 130
Dichlorobromomethane	20.0	18.4		ug/L		92	70 - 130
Dichlorodifluoromethane	20.0	24.0		ug/L		120	70 - 130
1,1-Dichloroethane	20.0	19.2		ug/L		96	70 - 130
1,2-Dichloroethane	20.0	21.5		ug/L		107	70 - 130
1,1-Dichloroethene	20.0	19.4		ug/L		97	70 - 130
1,2-Dichloropropane	20.0	18.0		ug/L		90	70 - 130
1,3-Dichloropropane	20.0	18.5		ug/L		92	70 - 130
2,2-Dichloropropane	20.0	19.7		ug/L		98	70 - 130
1,1-Dichloropropene	20.0	19.6		ug/L		98	70 - 130
1,3-Dichloropropene, Total	40.0	36.1		ug/L		90	70 - 130
Diisopropyl ether	16.0	15.6		ug/L		98	70 - 130
Ethylbenzene	20.0	20.2		ug/L		101	70 - 130
Ethylene Dibromide	20.0	18.3		ug/L		92	70 - 130
Freon 113	16.0	16.3		ug/L		102	70 - 130
Hexachlorobutadiene	20.0	19.8		ug/L		99	70 - 130
2-Hexanone	40.0	39.3		ug/L		98	70 - 130
Isopropylbenzene	20.0	22.4		ug/L		112	70 - 130
4-Isopropyltoluene	20.0	21.8		ug/L		109	70 - 130
Methylene Chloride	20.0	16.7		ug/L		83	70 - 130
2-Butanone (MEK)	40.0	36.1		ug/L		90	70 - 130
4-Methyl-2-pentanone (MIBK)	40.0	38.5		ug/L		96	70 - 130
m-Xylene & p-Xylene	40.0	40.2		ug/L		100	70 - 130
Naphthalene	20.0	17.7		ug/L		89	70 - 130
n-Butylbenzene	20.0	20.5		ug/L		102	70 - 130
N-Propylbenzene	20.0	20.7		ug/L		104	70 - 130
o-Xylene	20.0	19.5		ug/L		98	70 - 130
sec-Butylbenzene	20.0	21.2		ug/L		106	70 - 130
Styrene	20.0	20.4		ug/L		102	70 - 130
Tert-amyl methyl ether	16.0	15.5		ug/L		97	70 - 130
tert-Butyl alcohol	80.0	67.9		ug/L		85	70 - 130
tert-Butylbenzene	20.0	21.7		ug/L		109	70 - 130
Tert-butyl ethyl ether	16.0	15.4		ug/L		96	70 - 130
1,1,1,2-Tetrachloroethane	20.0	18.4		ug/L		92	70 - 130
1,1,1,2,2-Tetrachloroethane	20.0	16.9		ug/L		84	70 - 130
Tetrachloroethene	20.0	20.5		ug/L		102	70 - 130
Toluene	20.0	19.0		ug/L		95	70 - 130
trans-1,2-Dichloroethene	20.0	18.3		ug/L		92	70 - 130
trans-1,3-Dichloropropene	20.0	17.5		ug/L		87	70 - 130
1,2,3-Trichlorobenzene	20.0	19.0		ug/L		95	70 - 130
1,2,4-Trichlorobenzene	20.0	19.4		ug/L		97	70 - 130
1,1,1-Trichloroethane	20.0	20.6		ug/L		103	70 - 130
1,1,2-Trichloroethane	20.0	17.8		ug/L		89	70 - 130
Trichloroethene	20.0	19.3		ug/L		97	70 - 130
Trichlorofluoromethane	20.0	22.6		ug/L		113	70 - 130
1,2,3-Trichloropropane	20.0	19.0		ug/L		95	70 - 130
Trihalomethanes, Total	80.0	70.6		ug/L		88	70 - 130

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 680-255503/3

Matrix: Water

Analysis Batch: 255503

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
1,2,4-Trimethylbenzene	20.0	21.3		ug/L		107	70 - 130
1,3,5-Trimethylbenzene	20.0	21.6		ug/L		108	70 - 130
Vinyl chloride	20.0	17.2		ug/L		86	70 - 130
Xylenes, Total	60.0	59.7		ug/L		100	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
4-Bromofluorobenzene	100		70 - 130
1,2-Dichlorobenzene-d4	106		70 - 130

Lab Sample ID: LCSD 680-255503/4

Matrix: Water

Analysis Batch: 255503

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Acetone	40.0	45.8		ug/L		115	70 - 130	5	30
Benzene	20.0	18.2		ug/L		91	70 - 130	4	30
Bromobenzene	20.0	20.2		ug/L		101	70 - 130	2	30
Bromoform	20.0	15.2		ug/L		76	70 - 130	5	30
Bromomethane	20.0	26.5		ug/L		132	70 - 130	4	30
Carbon tetrachloride	20.0	19.7		ug/L		99	70 - 130	0	30
Chlorobenzene	20.0	19.5		ug/L		97	70 - 130	1	30
Chlorobromomethane	20.0	20.0		ug/L		100	70 - 130	5	30
Chlorodibromomethane	20.0	18.0		ug/L		90	70 - 130	1	30
Chloroethane	20.0	14.6		ug/L		73	70 - 130	1	30
Chloroform	20.0	19.9		ug/L		99	70 - 130	0	30
Chloromethane	20.0	15.3		ug/L		76	70 - 130	1	30
2-Chlorotoluene	20.0	20.8		ug/L		104	70 - 130	2	30
4-Chlorotoluene	20.0	21.4		ug/L		107	70 - 130	2	30
cis-1,2-Dichloroethene	20.0	19.0		ug/L		95	70 - 130	4	30
cis-1,3-Dichloropropene	20.0	18.9		ug/L		95	70 - 130	2	30
1,2-Dibromo-3-Chloropropane	20.0	16.7		ug/L		83	70 - 130	3	30
Dibromomethane	20.0	19.5		ug/L		98	70 - 130	2	30
1,2-Dichlorobenzene	20.0	20.4		ug/L		102	70 - 130	3	30
1,3-Dichlorobenzene	20.0	20.9		ug/L		104	70 - 130	1	30
1,4-Dichlorobenzene	20.0	20.2		ug/L		101	70 - 130	4	30
Dichlorobromomethane	20.0	18.3		ug/L		92	70 - 130	0	30
Dichlorodifluoromethane	20.0	24.0		ug/L		120	70 - 130	0	30
1,1-Dichloroethane	20.0	19.9		ug/L		99	70 - 130	3	30
1,2-Dichloroethane	20.0	21.9		ug/L		109	70 - 130	2	30
1,1-Dichloroethene	20.0	19.8		ug/L		99	70 - 130	2	30
1,2-Dichloropropane	20.0	18.7		ug/L		94	70 - 130	4	30
1,3-Dichloropropane	20.0	18.6		ug/L		93	70 - 130	0	30
2,2-Dichloropropane	20.0	19.8		ug/L		99	70 - 130	0	30
1,1-Dichloropropene	20.0	19.4		ug/L		97	70 - 130	1	30
1,3-Dichloropropene, Total	40.0	37.1		ug/L		93	70 - 130	3	30
Diisopropyl ether	16.0	16.6		ug/L		104	70 - 130	6	30
Ethylbenzene	20.0	20.4		ug/L		102	70 - 130	1	30
Ethylene Dibromide	20.0	19.1		ug/L		95	70 - 130	4	30
Freon 113	16.0	16.7		ug/L		104	70 - 130	2	30

QC Sample Results

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 680-255503/4

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 255503

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Hexachlorobutadiene	20.0	20.1		ug/L		101	70 - 130	1	30
2-Hexanone	40.0	41.5		ug/L		104	70 - 130	6	30
Isopropylbenzene	20.0	22.8		ug/L		114	70 - 130	2	30
4-Isopropyltoluene	20.0	22.0		ug/L		110	70 - 130	1	30
Methylene Chloride	20.0	18.4		ug/L		92	70 - 130	10	30
2-Butanone (MEK)	40.0	38.4		ug/L		96	70 - 130	6	30
4-Methyl-2-pentanone (MIBK)	40.0	40.6		ug/L		101	70 - 130	5	30
m-Xylene & p-Xylene	40.0	40.7		ug/L		102	70 - 130	1	30
Naphthalene	20.0	18.1		ug/L		90	70 - 130	2	30
n-Butylbenzene	20.0	20.8		ug/L		104	70 - 130	2	30
N-Propylbenzene	20.0	21.1		ug/L		106	70 - 130	2	30
o-Xylene	20.0	19.5		ug/L		98	70 - 130	0	30
sec-Butylbenzene	20.0	21.5		ug/L		107	70 - 130	1	30
Styrene	20.0	20.6		ug/L		103	70 - 130	1	30
Tert-amyl methyl ether	16.0	15.7		ug/L		98	70 - 130	1	30
tert-Butyl alcohol	80.0	71.8		ug/L		90	70 - 130	6	30
tert-Butylbenzene	20.0	21.9		ug/L		109	70 - 130	1	30
Tert-butyl ethyl ether	16.0	16.4		ug/L		102	70 - 130	6	30
1,1,1,2-Tetrachloroethane	20.0	18.8		ug/L		94	70 - 130	2	30
1,1,1,2,2-Tetrachloroethane	20.0	16.7		ug/L		83	70 - 130	1	30
Tetrachloroethene	20.0	20.5		ug/L		102	70 - 130	0	30
Toluene	20.0	19.1		ug/L		96	70 - 130	1	30
trans-1,2-Dichloroethene	20.0	18.1		ug/L		91	70 - 130	1	30
trans-1,3-Dichloropropene	20.0	18.1		ug/L		91	70 - 130	4	30
1,2,3-Trichlorobenzene	20.0	18.8		ug/L		94	70 - 130	1	30
1,2,4-Trichlorobenzene	20.0	18.3		ug/L		92	70 - 130	6	30
1,1,1-Trichloroethane	20.0	21.0		ug/L		105	70 - 130	2	30
1,1,2-Trichloroethane	20.0	18.0		ug/L		90	70 - 130	1	30
Trichloroethene	20.0	19.7		ug/L		99	70 - 130	2	30
Trichlorofluoromethane	20.0	24.0		ug/L		120	70 - 130	6	30
1,2,3-Trichloropropane	20.0	19.3		ug/L		97	70 - 130	2	30
Trihalomethanes, Total	80.0	71.4		ug/L		89	70 - 130	1	30
1,2,4-Trimethylbenzene	20.0	21.1		ug/L		105	70 - 130	1	30
1,3,5-Trimethylbenzene	20.0	21.8		ug/L		109	70 - 130	1	30
Vinyl chloride	20.0	17.2		ug/L		86	70 - 130	0	30
Xylenes, Total	60.0	60.2		ug/L		100	70 - 130	1	30

Surrogate	LCSD LCSD		Limits
	%Recovery	Qualifier	
4-Bromofluorobenzene	104		70 - 130
1,2-Dichlorobenzene-d4	104		70 - 130

QC Association Summary

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

GC/MS VOA

Analysis Batch: 255503

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
680-84406-1	Trip Blank	Total/NA	Water	524.2	
680-84406-2	RFW-21	Total/NA	Water	524.2	
680-84406-3	RFW-20	Total/NA	Water	524.2	
680-84406-4	HAMP 22	Total/NA	Water	524.2	
680-84406-5	HAMP 23	Total/NA	Water	524.2	
LCS 680-255503/3	Lab Control Sample	Total/NA	Water	524.2	
LCSD 680-255503/4	Lab Control Sample Dup	Total/NA	Water	524.2	
MB 680-255503/5	Method Blank	Total/NA	Water	524.2	

Lab Chronicle

Client: Weston Solutions, Inc.
Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-84406-1

Date Collected: 11/01/12 07:00

Matrix: Water

Date Received: 11/03/12 09:20

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	5 mL	5 mL	255503	11/06/12 21:45	AGM	TAL SAV

Client Sample ID: RFW-21

Lab Sample ID: 680-84406-2

Date Collected: 11/01/12 07:23

Matrix: Water

Date Received: 11/03/12 09:20

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	5 mL	5 mL	255503	11/06/12 22:11	AGM	TAL SAV

Client Sample ID: RFW-20

Lab Sample ID: 680-84406-3

Date Collected: 11/01/12 15:00

Matrix: Water

Date Received: 11/03/12 09:20

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	5 mL	5 mL	255503	11/06/12 22:38	AGM	TAL SAV

Client Sample ID: HAMP 22

Lab Sample ID: 680-84406-4

Date Collected: 11/02/12 09:40

Matrix: Water

Date Received: 11/03/12 09:20

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	5 mL	5 mL	255503	11/06/12 23:05	AGM	TAL SAV

Client Sample ID: HAMP 23

Lab Sample ID: 680-84406-5

Date Collected: 11/02/12 09:45

Matrix: Water

Date Received: 11/03/12 09:20

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	524.2		1	5 mL	5 mL	255503	11/06/12 23:32	AGM	TAL SAV

Laboratory References:

TAL SAV = TestAmerica Savannah, 5102 LaRoche Avenue, Savannah, GA 31404, TEL (912)354-7858

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

TestAmerica Savannah
5102 LaRoche Avenue
Savannah, GA 31404

Website: www.testamericainc.com
Phone: (912) 354-7858
Fax: (912) 352-0165

Alternate Laboratory Name/Location

Phone:
Fax:

PROJECT REFERENCE Black & Decker	PROJECT NO. 02501.004004.0700	PROJECT LOCATION (STATE) MD	MATRIX TYPE	REQUIRED ANALYSIS										PAGE	OF				
TAL (LAB) PROJECT MANAGER LISA HARVEY	P.O. NUMBER	CONTRACT NO.	COMPOSITE (C) OR GRAB (G) INDICATE AQUEOUS (WATER) SOLID OR SEMISOLID AIR NONAQUEOUS LIQUID (OIL, SOLVENT, ...)	VOC	HCl	PRESERVATIVE												STANDARD REPORT DELIVERY	<input type="radio"/>
CLIENT (SITE) PM Tom Carnot	CLIENT PHONE 610.701.3770	CLIENT FAX																DATE DUE	
CLIENT NAME Weston Solutions	CLIENT E-MAIL																	EXPEDITED REPORT DELIVERY (SURCHARGE)	<input type="radio"/>
CLIENT ADDRESS 1400 Weston Way West Chester PA																		DATE DUE	
COMPANY CONTRACTING THIS WORK (if applicable)																		NUMBER OF COOLERS SUBMITTED PER SHIPMENT:	

SAMPLE		SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	SOLID OR SEMISOLID	AIR	NONAQUEOUS LIQUID (OIL, SOLVENT, ...)	NUMBER OF CONTAINERS SUBMITTED										REMARKS		
DATE	TIME							1	2	3	4	5	6	7	8	9	10		11	12
11/1/12	0700	Trip Blank																		
11/1/12	723	RFW-21																		
11/1/12	1500	RFW-20																		
11/2/12	940	HAMP 22																		
11/2/12	945	HAMP 23																		

RELINQUISHED BY: (SIGNATURE) <i>[Signature]</i>	DATE 11/2/12	TIME 1630	RELINQUISHED BY: (SIGNATURE) F	DATE	TIME	RELINQUISHED BY: (SIGNATURE)	DATE	TIME
RECEIVED BY: (SIGNATURE) Fed EX	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME

LABORATORY USE ONLY								
RECEIVED FOR LABORATORY BY: (SIGNATURE) Beth A Doughty	DATE 11/3/12	TIME 0920	CUSTODY INTACT YES <input type="radio"/> NO <input type="radio"/>	CUSTODY SEAL NO.	SAVANNAH LOG NO. 1080-84406	LABORATORY REMARKS Temp 4.0°C		

Page 21 of 23

11/9/2012



Login Sample Receipt Checklist

Client: Weston Solutions, Inc.

Job Number: 680-84406-1

Login Number: 84406

List Source: TestAmerica Savannah

List Number: 1

Creator: Daughtry, Beth

Question	Answer	Comment
Radioactivity wasn't checked or is \leq background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	N/A	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

Certification Summary

Client: Weston Solutions, Inc.
 Project/Site: Black & Decker

TestAmerica Job ID: 680-84406-1

Laboratory: TestAmerica Savannah

All certifications held by this laboratory are listed. Not all certifications are applicable to this report.

Authority	Program	EPA Region	Certification ID	Expiration Date
A2LA	DoD ELAP		0399-01	02-28-13
A2LA	ISO/IEC 17025		399.01	02-28-13
Alabama	State Program	4	41450	06-30-13
Alaska (UST)	State Program	10	UST-104	06-19-13
Arkansas DEQ	State Program	6	88-0692	02-01-13
California	NELAC	9	3217CA	07-31-13
Colorado	State Program	8	N/A	12-31-12
Connecticut	State Program	1	PH-0161	03-31-13
Florida	NELAC	4	EB7052	06-30-13
GA Dept. of Agriculture	State Program	4	N/A	12-31-12
Georgia	State Program	4	N/A	06-30-13
Georgia	State Program	4	803	06-30-13
Guam	State Program	9	09-005r	04-17-13
Hawaii	State Program	9	N/A	06-30-13
Illinois	NELAC	5	200022	11-30-12
Indiana	State Program	5	N/A	06-30-13
Iowa	State Program	7	353	07-01-13
Kentucky	State Program	4	90084	12-31-12
Kentucky (UST)	State Program	4	18	02-28-13
Louisiana	NELAC	6	30690	06-30-13
Louisiana	NELAC	6	LA100015	12-31-12
Maine	State Program	1	GA00006	08-16-14
Maryland	State Program	3	250	12-31-12
Massachusetts	State Program	1	M-GA006	06-30-13
Michigan	State Program	5	9925	06-30-13
Mississippi	State Program	4	N/A	06-30-13
Montana	State Program	8	CERT0081	12-31-12
Nebraska	State Program	7	TestAmerica-Savannah	06-30-13
New Jersey	NELAC	2	GA769	06-30-13
New Mexico	State Program	6	N/A	06-30-13
New York	NELAC	2	10842	04-01-13
North Carolina DENR	State Program	4	269	12-31-13
North Carolina DHHS	State Program	4	13701	07-31-13
Oklahoma	State Program	6	9984	08-31-13
Pennsylvania	NELAC	3	68-00474	06-30-13
Puerto Rico	State Program	2	GA00006	01-01-13
Rhode Island	State Program	1	LAO00244	12-30-12
South Carolina	State Program	4	98001	06-30-13
Tennessee	State Program	4	TN02961	06-30-13
Texas	NELAC	6	T104704185-08-TX	11-30-12
USDA	Federal		SAV 3-04	04-07-14
Vermont	State Program	1	87052	11-16-12
Virginia	NELAC	3	460161	06-14-13
Washington	State Program	10	C1794	06-10-13
West Virginia	State Program	3	9950C	12-31-12
West Virginia DEP	State Program	3	94	06-30-13
Wisconsin	State Program	5	999819810	08-31-13
Wyoming	State Program	8	8TMS-Q	06-30-13