

Quarterly Groundwater Monitoring Report

Prepared for
Black & Decker (U.S.) Inc.

Hampstead, Maryland

April 2006

Prepared by

WESTON SOLUTIONS, INC.
West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 1st Quarter 2006	2-2
Table 2-2 Groundwater Elevation Data – 1st Quarter 2006	2-3
Table 2-3 Effluent Characteristics Summary – 1st Quarter 2006	2-4
Table 2-4 Summary of Groundwater Analytical Results - February 2006.....	2-5
Table 3-1 Treatment System Maintenance Activities – 1st Quarter 2006.....	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of January through March 2006.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of January through March 2006, the extraction wells were pumping at an average combined rate of approximately 182 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of January through March 2006 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of January through March 2006, approximately 37 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (62 %) and tetrachloroethene (PCE) (38 %). Analytical results of the groundwater collected at the inlet to the air stripper for the period of January through March 2006 are included in Appendix C.

A summary of the analytical results from the first quarter (February 2006) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 1st Quarter 2006
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
January 2006	6,686,728
February 2006	6,248,297
March 2006	6,852,072

Table 2-2
Groundwater Elevation Data - 1st Quarter 2006
Black & Decker
Hampstead, Maryland

WELL NO.	TOC ELEV.	TOTAL DEPTH	1/19/2006		2/27/2006		3/17/2006	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NA	DRY	NA	DRY	NA
EW-2	849.21	110	89.74	759.47	95.10	754.11	94.26	754.95
EW-3	846.64	118	94.61	752.03	97.31	749.33	96.86	749.78
EW-4	858.01	97.5	NA	NA	NA	NA	NA	NA
EW-5	864.17	98	84.40	779.77	84.88	779.29	85.10	779.07
EW-6	831.98	115	87.96	744.02	88.47	743.51	89.70	742.28
EW-7	818.38	78	44.97	773.41	47.31	771.07	47.83	770.55
EW-8	811.13	98	48.03	763.10	49.11	762.02	49.96	761.17
EW-9	811.35	141	101.40	709.95	100.05	711.30	101.30	710.05
EW-10	807.74	NA	44.03	763.71	45.87	761.87	45.69	762.05
RFW-1A	864.37	78	51.43	812.94	50.16	814.21	51.41	812.96
RFW-1B	864.23	200	51.46	812.77	50.24	813.99	50.46	813.77
RFW-2A	857.41	35	16.01	841.40	12.64	844.77	12.70	844.71
RFW-2B	857.73	75	16.43	841.30	13.28	844.45	13.21	844.52
RFW-3B	839.21	153	32.27	806.94	29.33	809.88	27.67	811.54
RFW-4A	830.37	62	37.33	793.04	36.28	794.09	36.29	794.08
RFW-4B	830.37	120	37.21	793.16	36.11	794.26	36.13	794.24
RFW-5A	817.50	30	DRY	NA	DRY	NA	DRY	NA
RFW-6	785.04	120	3.48	781.56	3.74	781.30	4.12	780.92
RFW-7	805.14	29	7.71	797.43	5.68	799.46	6.34	798.80
RFW-8	860.07	56	DRY	NA	DRY	NA	DRY	NA
RFW-9	862.02	49	25.64	836.38	24.76	837.26	25.03	836.99
RFW-10	852.06	58	DRY	NA	DRY	NA	DRY	NA
RFW-11A	849.32	72	NA	NA	NA	NA	NA	NA
RFW-11B	849.62	116	71.47	778.15	69.54	780.08	70.17	779.45
RFW-12B	844.87	264	54.30	790.57	53.86	791.01	53.61	791.26
RFW-13	849.11	150	61.40	787.71	62.60	786.51	62.47	786.64
RFW-14B	812.39	281	35.86	776.53	34.71	777.68	35.13	777.26
RFW-16	856.14	41	DRY	NA	DRY	NA	DRY	NA
RFW-17	834.66	60.5	27.60	807.06	25.83	808.83	25.92	808.74
RFW-20	842.49	142	31.99	810.50	33.71	808.78	33.37	809.12
RFW-21	832.65	102	22.50	810.15	21.20	811.45	21.03	811.62
PH-7	805.94	89	23.08	782.86	23.78	782.16	24.06	781.88
PH-9	814.94	98	37.46	777.48	38.11	776.83	38.30	776.64
PH-11	820.68	78	43.01	777.67	42.88	777.80	43.19	777.49
PH-12	828.35	87	43.29	785.06	43.35	785.00	43.43	784.92
B-3	803.02	83	NA	NA	NA	NA	NA	NA
Amoco	842.29	NA	NA	NA	NA	NA	NA	NA
Hamp. Town #22	804.96	NA	31.40	773.56	27.63	777.33	27.13	777.83
Pembroke #1	NA	NA	10.94	NA	NA	NA	10.98	NA
Pembroke #2	NA	NA	NA	NA	NA	NA	NA	NA
N. Houcks. Rd.	NA	NA	9.87	NA	NA	NA	10.73	NA
E. Century St.	NA	NA	27.40	NA	NA	NA	23.84	NA
Lwr. Beckleys. Rd.	NA	NA	55.49	NA	NA	NA	53.31	NA

NA - Not Available/Not Accessible

Table 2-3
Effluent Characteristics Summary - 1st Quarter 2006
Black & Decker
Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				January 2006	February 2006	March 2006	
001	FLOW	average	MGD	NA	0.246	0.250	0.181
		maximum	MGD	NA	0.487	0.630	0.247
	1,1,1-Trichloroethane	ug/l	5	< 5	< 5	< 5	
	Tetrachloroethylene	ug/l	5	< 5	< 5	< 5	
	Trichloroethylene	ug/l	5	< 5	< 5	< 5	
	Total Residual Chlorine	mg/l	< 0.1	< 0.1	< 0.1	< 0.1	
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		quarterly average	mg/l	10	NR	NR	< 5
	pH	minimum	STD	6.0	6.10	6.10	6.10
		maximum	STD	8.5	6.70	6.70	7.20
BOD		mg/l	15	< 2	< 2	< 2	
TSS	maximum	mg/l	30	< 2.5	3.5	2.8	
	quarterly average	mg/l	20	NR	NR	2.5	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.217	0.251	0.251
		maximum	MGD	NA	0.256	0.275	0.275
	Fecal Coliform	MPN/100ml	200	< 2	< 2	< 2	
201 (Monitoring Point)	FLOW	average	MGD	NA	0.216	0.215	0.221
		maximum	MGD	NA	0.248	0.239	0.247
	1,1,1-Trichloroethane	ug/l	NA	< 5	< 5	< 5	
	Tetrachloroethylene	ug/l	NA	< 5	< 5	< 5	
	Trichloroethylene	ug/l	NA	< 5	< 5	< 5	

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

Table 2-4
 Summary of Groundwater Analytical Results - February 2006
 Black & Decker
 Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4 (5)	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 DUP	EW-10
Chloromethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Acetone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3.6	1.7	5 U	1 U	1 U	8	23	1.5	1.3	1 U
Chloroform	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	5 U	1.2	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	520	170	1200	260	11	7.2	12	2.2	2.2	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	25 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	63	5	26	7.8	19	13	73	310	310	9.1
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	5 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

DUP = Duplicate sample
 NS = Not sampled
 (2.5) = Dilution factor.

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
 J = Indicates an estimated value.
 B = Indicates that the analyte was found in the associated blank as well as in the sample.

Table 2-4
Summary of Groundwater Analytical Results - February 2006
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4B	RFW-4B (DUP)	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	5 U	1 U	NS	1 U	NS
Acetone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	1 U	5 U	NS	1 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	1 U	5 U	NS	1 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.5	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.3	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	9.3	1.2	4.5	4.4	NS	1.4	1 U	NS	14	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	1 U	5 U	NS	1 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	2.1	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	5 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	5 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	1.3	2	1.2	41	13	13	NS	8.8	4.3	NS	22	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	1 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	1 U	NS
Tetrachloroethene	ug/L	1.2	1 U	1 U	1 U	4.7	40	37	36	NS	6.9	1 U	NS	6.9	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

DUP = Duplicate sample
 NS = Not sampled
 (2.5) = Dilution factor.

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
 J = Indicates an estimated value.
 B = Indicates that the analyte was found in the associated blank as well as in the sample.

Table 2-4
Summary of Groundwater Analytical Results - February 2006
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	RFW-20	RFW-21	Town #22	Town #23	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U
Methylene Chloride	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	10 U	10 U	10 U	10 U	5 U	5 U	5 U	NS	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	NA	NA	NA	NA	5 U	5 U	5 U	NS	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	6	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	10 U	10 U	10 U	10 U	5 U	5 U	5 U	NS	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Trichloroethene	ug/L	NS	27	630	16	NS	1.1	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	10 U	10 U	10 U	10 U	5 U	5 U	5 U	NS	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	10 U	10 U	10 U	10 U	5 U	5 U	5 U	NS	5 U
Tetrachloroethene	ug/L	NS	1 U	48	41	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	0.5 U	0.5 U	0.5 U	0.5 U	1 U	1 U	1 U	NS	1 U

DUP = Duplicate sample
NS = Not sampled
(2.5) = Dilution factor.

Note: Samples from wells RFW-20&21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division. Samples from all of the other wells are analyzed with USEPA Method U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from well EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (January through March 2006) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 1st Quarter 2006
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
March 2006	The pump motor on EW - 5 shorted out. A new pump and motor were installed. The well was down for 6 days. The well is back online.

4. RECOMMENDATIONS

For the reporting period of January through March 2006, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(JANUARY - MARCH 2006)

MONTH / YEAR

JAN. 2006

BLACK & DECKER
AIR STRIPPER # 2
OPERATING RECORD

PAST MONTH READING

79636248

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	S	1241	790 19024	↑	28083	281785
2	M			377850		
3	T	1240	79396878	261529	28083	28225
4	W	1235	79598407	204980	28107	28225
5	T	1235	79803387	184939	28131	28225
6	F	1050	79988326	↑	28153	28225
7	S					
8				598238		
9	M	1325	80586564	198429	28227	28225
10	T	1300	80784993	224230	28227	28249
11	W	1340	81009223	225454	28227	28274
12	T	1405	81234677	195841	28227	28298
13	F	1115	81430518	↑	28227	28319
14						
15				282892		
16	M	1255	82113410	242055	28227	28393
17	T	1610	82355465	201116	28253	28393
18	W	1250	82556581	239118	28275	28393
19	T	1440	82795699	↑	28301	28393
20	F					
21						
22				880854		
23	M	1340	83676553	222615	28346	28393
24	T	1340	83849168	208218	28396	28417
25	W	1205	84109386	243241	28396	28439
26	T	1420	84350627	171021	28396	28465
27	F	0845	84521648	↑	28396	28484
28						
29				705483		
30	M	1240	85227131	230269	28396	28560
31	T	1325	85457400	248356	28421	28560
Total				6686728		
Average				215701		

NEXT MONTH READING 85705754

DATE 2-1-06

Month / Year

Feb. 2006

Black & Decker
Air Stripper # 2
Operating Record

Past Month Reading

85457400

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	W	1410	85705756	188059	28447	28560
2	T	1320	85893915	221887	28468	28560
3	F	1210	86115702	↑	28492	28560
4						
5						
6	M	1140	86782459	6666756 222833	28563	28560
7	T	1130	87005291	235867	28563	28584
8	W	1245	87241158	238400	28563	28609
9	T	1420	87479558	197484	28563	28635
10	F	1330	87677042	↑	28563	28656
11						
12						
13	M	1325	88368470	691428 230463	28563	28730
14	T	1405	88598933	207019	28588	28730
15	W	1215	88805952	235611	28610	28730
16	T	1330	89041563	217376	28635	28730
17	F	1245	89258939	↑	28658	28730
18						
19						
20	M	1230	89430652	671713 221039	28730	28730
21	T	1205	90151691	234918	28730	28753
22	W	1310	90386609	217825	28730	28778
23	T	1225	90604434	228846	28730	28801
24	F	1250	90833280	↑	28730	28826
25						
26						
27	M	1210	91503384	670109 238982	28730	28897
28	T	1340	91742371	211682	28756	28847
29						
30						
31						
Total				6248297		
Average				215459		

Next Month Reading 91954053

Date 3-1-06

Month / Year

Mar. 2006

**Black & Decker
Air Stripper # 2
Operating Record**

Past Month Reading

91742371

Date	Day	Time	Integ. Reading	GPD	Pump # 11	Pump # 12
1	W	1215	91954053	239852	28778	28897
2	T	1345	92193905	216084	28804	28897
3	F	1345	92409989	↑	28827	28897
4						
5				667634		
6	M	1155	93077623	231267	28898	28897
7	T	1230	93308890	211730	28898	28922
8	W	1105	93520620	220789	28898	28944
9	T	1035	93741409	247305	28898	28968
10	F	1250	93988714	↑	28898	28994
11						
12				696995		
13	M	1510	94685609	187309	28898	29069
14	T	1105	94872998	244795	28918	29069
15	W	1310	95117793	211653	28944	29069
16	T	1145	95329446	225937	28966	29069
17	F	1145	9555383	↑	28990	29069
18						
19				669172		
20	M	1055	96224555	237552	29062	29069
21	T	1220	96462107	244277	29062	29094
22	W	1415	96706384	210422	29062	29120
23	T	1240	96916806	215584	29062	29142
24	F	1235	97132390	↑	29062	29165
25						
26				613530		
27	M	1055	97745920	218067	29062	29236
28	T	1320	97963987	177584	29088	29236
29	W	1050	98141571	212090	29110	29236
30	T	1235	98353667	226563	29135	29236
31	F	1430	98580230	225875		
Total				6852072		
Average						

3-27 = #5 well off at panel. Pump Motor burnt up. 25th

Next Month Reading 99257856

Date 4/3/06

**APPENDIX B
DISCHARGE MONITORING REPORTS
(JANUARY- MARCH 2006)**

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881	001
PERMIT NUMBER	DISCHARGE NUMBER
(2-16)	(17-19)

FORM APPROVED
 OMB No. 2040-0004

MONITORING PERIOD					
FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
2006	01	01	06	01	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW	SAMPLE MEASUREMENT	0.246	0.487	MGD				0	Measured/Recorded	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT						Measured/Recorded	
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT					<5	ppb	0	1/MONTH GRAB	
	PERMIT REQUIREMENT					5			1/MONTH GRAB	
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT					<5	ppb	0	1/MONTH GRAB	
	PERMIT REQUIREMENT					5			1/MONTH GRAB	
TRICHLOROETHYLENE	SAMPLE MEASUREMENT					<5	ppb	0	1/MONTH GRAB	
	PERMIT REQUIREMENT					5			1/MONTH GRAB	
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT					<0.1	mg/l	0	1/MONTH GRAB	
	PERMIT REQUIREMENT					0.011	0.019		1/MONTH GRAB	
OIL & GREASE	SAMPLE MEASUREMENT					<5	mg/l	0	1/MONTH GRAB	
	PERMIT REQUIREMENT					10	<5		1/MONTH GRAB	
pH	SAMPLE MEASUREMENT				6.10	6.70		0	2/WEEK GRAB	
	PERMIT REQUIREMENT				6.00	8.50			2/WEEK GRAB	

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Michael A. Clark
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: 410-374-9025
 DATE: 06 | 02 | 02
 AREA CODE-NUMBER: 410-374-9025
 YEAR | MO | DAY: 06 | 02 | 02

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**

ADDRESS: **555 13th Street., NW**

Suite 420E

Washington, DC 20004

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED

OMB No.2040-0004

MD0001881
PERMIT NUMBER

(2-16)

001
DISCHARGE NUMBER

(17-19)

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	2006	01	01		06	01	31

(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUALITY OR CONCENTRATION (4 Card Only) (38-45)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
BOD	SAMPLE MEASUREMENT								0	1/MONTH	GRAB
	PERMIT REQUIREMENT							mg/l		1/MONTH	GRAB
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT								0	1/MONTH	GRAB
	PERMIT REQUIREMENT					20	30	mg/l		1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
Principal
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Reddick
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: 410-374-9025
DATE: 06 | 02 | 02
AREA CODE-NUMBER: 410-374-9025
YEAR | MO | DAY: 06 | 02 | 02

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PAGE 2 OF 2

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881 **101**
 PERMIT NUMBER DISCHARGE NUMBER
 (2-16) (17-19)

FORM APPROVED
 OMB No. 2040-0004

MONITORING PERIOD								
FROM			TO					
YEAR	MO	DAY	YEAR	MO	DAY			
2006	01	01	06	01	31			
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)			

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	QUANTITY OR LOADING (3 Card Only) (46-53)			QUALITY OR CONCENTRATION (4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.217	0.256	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record	
FECAL COLIFORM	SAMPLE MEASUREMENT					<2		MPN/100ml	0	1/WEEK GRAB	
	PERMIT REQUIREMENT					200				1/WEEK GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN. AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Middle

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **410-374-9025**
 DATE **06 | 02 | 02**
 AREA CODE-NUMBER YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**

ADDRESS: **555 13th Street., NW**

Suite 420E

Washington, DC 20004

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
PERMIT NUMBER

201
DISCHARGE NUMBER

(2-16)

(17-19)

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	2006	01	01		06	01	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

FORM APPROVED

OMB No.2040-0004

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.216	0.248	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
Principal
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN. AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Weddler
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: 410-374-9025
DATE: 06 | 02 | 02
AREA CODE-NUMBER: YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER
 (2-16)

001
 DISCHARGE NUMBER
 (17-19)

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2006	02	01	06	02	28
(20-21)	(22-23)	(24-25)	(28-27)	(28-29)	(30-31)

FORM APPROVED
 OMB No.2040-0004

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) (46-53) QUANTITY OR LOADING (54-61)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.250	0.630	MGD					0	Measured/Recorded	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Measured/Recorded	
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						5			1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						5			1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						5			1/MONTH	GRAB
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT						<0.1	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					0.011	0.019			1/MONTH	GRAB
OIL & GREASE	SAMPLE MEASUREMENT						<5	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					10	<5			1/MONTH	GRAB
pH	SAMPLE MEASUREMENT				6.10		6.70	STD	0	2WEEK	GRAB
	PERMIT REQUIREMENT				6.00		8.50			2WEEK	GRAB

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER

Michael A. Clark
 Principal

TYPED OR PRINTED

CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Weddell

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

410-374-9025

AREA CODE-NUMBER

DATE

06 | 03 | 01

YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

FORM APPROVED
OMB No.2040-0004

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

DISCHARGE MONITORING REPORT (DMR)

MD0001881 **001**
 PERMIT NUMBER DISCHARGE NUMBER
 (2-16) (17-19)

MONITORING PERIOD

FROM: YEAR **2006** MO **02** DAY **01** TO: YEAR **06** MO **02** DAY **28**
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
BOD	SAMPLE MEASUREMENT							<2	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT							15		1/MONTH	GRAB	
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT							3.5	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					20	30	1/MONTH		GRAB		
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
	SAMPLE MEASUREMENT											
	PERMIT REQUIREMENT											
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER									TELEPHONE	DATE		
Michael A. Clark Principal TYPED OR PRINTED									410-374-9025	06 03 01		
CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)									Signature of Principal Executive Officer or Authorized Agent OFFICER OR AUTHORIZED AGENT		AREA CODE-NUMBER	YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: BTR CAPITAL GROUP

ADDRESS: 555 13th Street., NW

Suite 420E

Washington, DC 20004

FACILITY: Hampstead, Maryland 21074

LOCATION: CARROLL COUNTY

MD0001881
PERMIT NUMBER
(2-16)

101
DISCHARGE NUMBER
(17-18)

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2006	02	01	06	02	28
(20-21)	(22-23)	(24-25)	(26-27)	(28-28)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) (46-53) QUANTITY OR LOADING (54-61)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.251	0.275	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							Cont Measure/Record	
FECAL COLIFORM	SAMPLE MEASUREMENT						<2	MPN/100ml	0	1/WEEK GRAB	
	PERMIT REQUIREMENT						200			1/WEEK GRAB	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
Principal
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Weddell

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: 410-374-9025
DATE: 06 | 03 | 01
AREA CODE-NUMBER: 410-374-9025
YEAR | MO | DAY: 06 | 03 | 01

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER
 (2-18)

201
 DISCHARGE NUMBER
 (17-18)

MONITORING PERIOD					
FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
2006	02	01	06	02	28
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

FORM APPROVED
 OMB No.2040-0004

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.215	0.239	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT						<5	ppb	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						N/A			1/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1919. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						TELEPHONE		DATE	
Michael A. Clark Principal TYPED OR PRINTED								 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		410-374-9025	
COMMENT AND EXPLANATION OF ANY VIOLATIONS								AREA CODE-NUMBER		YEAR MO DAY	

(Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881 **001**
 PERMIT NUMBER DISCHARGE NUMBER

FORM APPROVED
 OMB No.2040-0004

MONITORING PERIOD
 FROM YEAR 2006 MO 03 DAY 01 TO YEAR 06 MO 03 DAY 31

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (46-53) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)		
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS					
FLOW	SAMPLE MEASUREMENT	0.181	0.247	MGD					0	Measured/Recorded			
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT										
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT					<5		ppb	0	1/MONTH	GRAB		
	PERMIT REQUIREMENT					5				1/MONTH	GRAB		
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT					<5		ppb	0	1/MONTH	GRAB		
	PERMIT REQUIREMENT					5				1/MONTH	GRAB		
TRICHLOROETHYLENE	SAMPLE MEASUREMENT					<5		ppb	0	1/MONTH	GRAB		
	PERMIT REQUIREMENT					5				1/MONTH	GRAB		
TOTAL RESIDUAL CHLORINE	SAMPLE MEASUREMENT					<0.1		mg/l	0	1/MONTH	GRAB		
	PERMIT REQUIREMENT					0.011	0.019			1/MONTH	GRAB		
OIL & GREASE	SAMPLE MEASUREMENT					<5	<5	mg/l	0	1/MONTH	GRAB		
	PERMIT REQUIREMENT					10	<5			1/MONTH	GRAB		
pH	SAMPLE MEASUREMENT				6.10		7.20	STD	0	2/WEEK	GRAB		
	PERMIT REQUIREMENT				6.00		8.50			2/WEEK	GRAB		
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)									TELEPHONE	DATE	
Michael A. Clark Principal											 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	410-374-9025	06 04 04
TYPED OR PRINTED												AREA CODE-NUMBER	YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.

EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

(REPLACES EPA FORM T-40 WHICH MAY NOT BE USED.)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004

FACILITY: **Hampstead, Maryland 21074**

LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

(2-16)

(17-19)

MONITORING PERIOD

FROM YEAR 2006 MO 03 DAY 01 TO YEAR 06 MO 03 DAY 31

(20-21)

(22-23)

(24-25)

(26-27)

(28-29)

(30-31)

NOTE: Read instructions before completing this form.

FORM APPROVED
 OMB No.2040-0004

PARAMETER (32-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (48-53)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
BOD	SAMPLE MEASUREMENT							mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT						<2				
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT					2.8	2.5	mg/l	0	1/MONTH	GRAB
	PERMIT REQUIREMENT					20	30				
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Earl Weddle
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: 410-374-9025
 DATE: 06 | 04 | 04
 AREA CODE-NUMBER: 410-374-9025
 YEAR | MO | DAY: 06 | 04 | 04

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

*Averages for TSS and Oil & Grease are reported quarterly.
 EPA Form 3320-1 (Rev. 9-88) Previous edition to be used until supply is exhausted.

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)
 NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street, NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

FORM APPROVED
 OMB No. 2040-0004

MD0001881
 PERMIT NUMBER
101
 DISCHARGE NUMBER

MONITORING PERIOD
 FROM YEAR **2006** MO **03** DAY **01** TO YEAR **06** MO **03** DAY **31**

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (48-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW	SAMPLE MEASUREMENT	0.251	0.275	MGD				0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT							
FECAL COLIFORM	SAMPLE MEASUREMENT					<2	MPN/ 100ml	0	1/WEEK	GRAB
	PERMIT REQUIREMENT					200				
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER: **Michael A. Clark**
 Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT: *Earl Weddell*

TELEPHONE: **410-374-9025**
 AREA CODE-NUMBER

DATE: **06 | 04 | 04**
 YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS
 (Reference all attachments here)

PERMITTEE NAME/ADDRESS: (Include Facility Name/Location if different)

NAME: **BTR CAPITAL GROUP**
 ADDRESS: **555 13th Street., NW**
Suite 420E
Washington, DC 20004
 FACILITY: **Hampstead, Maryland 21074**
 LOCATION: **CARROLL COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

MD0001881 **201**
 PERMIT NUMBER DISCHARGE NUMBER

(2-18) (17-19)

MONITORING PERIOD
 FROM YEAR MO DAY TO YEAR MO DAY
2006 03 01 06 03 31

FORM APPROVED
 OMB No.2040-0004

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.221	0.247	MGD					0	Cont Measure/Record	
	PERMIT REQUIREMENT	NO LIMIT	NO LIMIT								
1,1,1-TRICHLOROETHANE	SAMPLE MEASUREMENT					<5		ppb	0	1/MONTH GRAB	
	PERMIT REQUIREMENT					N/A					
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT					<5		ppb	0	1/MONTH GRAB	
	PERMIT REQUIREMENT					N/A					
TRICHLOROETHYLENE	SAMPLE MEASUREMENT					<5		ppb	0	1/MONTH GRAB	
	PERMIT REQUIREMENT					N/A					
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Michael A. Clark
Principal
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREON, AND BASED ON MY INQUIRY OF THESE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Ernie Weddell
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE DATE
410-374-9025 **06 | 04 | 04**
 AREA CODE-NUMBER YEAR | MO | DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS
 (Reference all attachments here)

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(JANUARY - MARCH 2006)



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 2

Client:	BTR Hampstead, Inc.	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0601078	Lab ID:	0601078-002
Project:	Hampstead-Monthly	Collection Date:	1/4/2006 11:27
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method:	Prep. Date:	Prep Analyst	NA	NA	NA
Chloromethane	< 10	10	µg/L	1/6/2006	14:19
Vinyl chloride	< 10	10	µg/L	1/6/2006	14:19
Bromomethane	< 10	10	µg/L	1/6/2006	14:19
Chloroethane	< 10	10	µg/L	1/6/2006	14:19
Acrolein	< 100	100	µg/L	1/6/2006	14:19
1,1-Dichloroethene	< 5.0	5.0	µg/L	1/6/2006	14:19
Methylene chloride	< 5.0	5.0	µg/L	1/6/2006	14:19
Acrylonitrile	< 100	100	µg/L	1/6/2006	14:19
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	1/6/2006	14:19
1,1-Dichloroethane	< 5.0	5.0	µg/L	1/6/2006	14:19
Chloroform	< 5.0	5.0	µg/L	1/6/2006	14:19
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	1/6/2006	14:19
Carbon tetrachloride	< 5.0	5.0	µg/L	1/6/2006	14:19
Benzene	< 5.0	5.0	µg/L	1/6/2006	14:19
1,2-Dichloroethane	< 5.0	5.0	µg/L	1/6/2006	14:19
Trichloroethene	160	5.0	µg/L	1/6/2006	14:19
1,2-Dichloropropane	< 5.0	5.0	µg/L	1/6/2006	14:19
Bromodichloromethane	< 5.0	5.0	µg/L	1/6/2006	14:19
2-Chloroethyl vinyl ether	< 10	10	µg/L	1/6/2006	14:19
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	1/6/2006	14:19
Toluene	< 5.0	5.0	µg/L	1/6/2006	14:19
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	1/6/2006	14:19
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	1/6/2006	14:19
Tetrachloroethene	99	5.0	µg/L	1/6/2006	14:19
Dibromochloromethane	< 5.0	5.0	µg/L	1/6/2006	14:19
Chlorobenzene	< 5.0	5.0	µg/L	1/6/2006	14:19
Ethylbenzene	< 5.0	5.0	µg/L	1/6/2006	14:19
Bromoform	< 5.0	5.0	µg/L	1/6/2006	14:19
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	1/6/2006	14:19
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	1/6/2006	14:19
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	1/6/2006	14:19



Microbac

www.microbac.com

Microbac Laboratories, Inc. Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 3

Client:	BTR Hampstead, Inc.	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0601078	Lab ID:	0601078-002
Project:	Hampstead-Monthly	Collection Date:	1/4/2006 11:27
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	1/6/2006 14:19



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 4

Client:	BTR Hampstead, Inc.	Client Sample ID:	Outfall 201 (Post)
Report No:	0601078		
Project:	Hampstead-Monthly	Lab ID:	0601078-003
Matrix:	WASTEWATER	Collection Date:	1/4/2006 11:26

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
VOLATILE ORGANIC COMPOUNDS (EPA 624)				Analyst: MLS
Prep. Method: <u>NA</u>	Prep. Date: <u>NA</u>	Prep Analyst <u>NA</u>		
<i>note: Result for 2-Chloroethyl vinyl ether estimated due to matrix spike recovery out of acceptance limits.</i>				
Chloromethane	< 10	10	µg/L	1/6/2006 14:53
Vinyl chloride	< 10	10	µg/L	1/6/2006 14:53
Bromomethane	< 10	10	µg/L	1/6/2006 14:53
Chloroethane	< 10	10	µg/L	1/6/2006 14:53
Acrolein	< 100	100	µg/L	1/6/2006 14:53
1,1-Dichloroethene	< 5.0	5.0	µg/L	1/6/2006 14:53
Methylene chloride	< 5.0	5.0	µg/L	1/6/2006 14:53
Acrylonitrile	< 100	100	µg/L	1/6/2006 14:53
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	1/6/2006 14:53
1,1-Dichloroethane	< 5.0	5.0	µg/L	1/6/2006 14:53
Chloroform	< 5.0	5.0	µg/L	1/6/2006 14:53
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	1/6/2006 14:53
Carbon tetrachloride	< 5.0	5.0	µg/L	1/6/2006 14:53
Benzene	< 5.0	5.0	µg/L	1/6/2006 14:53
1,2-Dichloroethane	< 5.0	5.0	µg/L	1/6/2006 14:53
Trichloroethene	< 5.0	5.0	µg/L	1/6/2006 14:53
1,2-Dichloropropane	< 5.0	5.0	µg/L	1/6/2006 14:53
Bromodichloromethane	< 5.0	5.0	µg/L	1/6/2006 14:53
2-Chloroethyl vinyl ether	< 10	10	µg/L	1/6/2006 14:53
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	1/6/2006 14:53
Toluene	< 5.0	5.0	µg/L	1/6/2006 14:53
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	1/6/2006 14:53
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	1/6/2006 14:53
Tetrachloroethene	< 5.0	5.0	µg/L	1/6/2006 14:53
Dibromochloromethane	< 5.0	5.0	µg/L	1/6/2006 14:53
Chlorobenzene	< 5.0	5.0	µg/L	1/6/2006 14:53
Ethylbenzene	< 5.0	5.0	µg/L	1/6/2006 14:53
Bromoform	< 5.0	5.0	µg/L	1/6/2006 14:53
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	1/6/2006 14:53
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	1/6/2006 14:53
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	1/6/2006 14:53



Microbac

www.microbac.com

Microbac Laboratories, Inc. Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.gascoyne.com

Test Results

Page 5

Client:	BTR Hampstead, Inc.	Client Sample ID:	Outfall 201 (Post)
Report No:	0601078	Lab ID:	0601078-003
Project:	Hampstead-Monthly	Collection Date:	1/4/2006 11:26
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	1/6/2006 14:53



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 2

Client:	BTR Hampstead, Inc.	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0602011		
Project:	Hampstead-Quarterly	Lab ID:	0602011-002
Matrix:	WASTEWATER	Collection Date:	2/1/2006 9:05

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
----------	--------------	-----------------	-------	--------------------

VOLATILE ORGANIC COMPOUNDS (EPA 624)

Analyst: MLS

Prep. Method: NA

Prep. Date: NA

Prep Analyst NA

note: Result for 2-Chloroethyl vinyl ether estimated due to matrix spike recovery out of acceptance limits.

Chloromethane	< 10	10	µg/L	2/6/2006 13:54
Vinyl chloride	< 10	10	µg/L	2/6/2006 13:54
Bromomethane	< 10	10	µg/L	2/6/2006 13:54
Chloroethane	< 10	10	µg/L	2/6/2006 13:54
Acrolein	< 100	100	µg/L	2/6/2006 13:54
1,1-Dichloroethene	< 5.0	5.0	µg/L	2/6/2006 13:54
Methylene chloride	< 5.0	5.0	µg/L	2/6/2006 13:54
Acrylonitrile	< 100	100	µg/L	2/6/2006 13:54
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	2/6/2006 13:54
1,1-Dichloroethane	< 5.0	5.0	µg/L	2/6/2006 13:54
Chloroform	< 5.0	5.0	µg/L	2/6/2006 13:54
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	2/6/2006 13:54
Carbon tetrachloride	< 5.0	5.0	µg/L	2/6/2006 13:54
Benzene	< 5.0	5.0	µg/L	2/6/2006 13:54
1,2-Dichloroethane	< 5.0	5.0	µg/L	2/6/2006 13:54
Trichloroethene	120	5.0	µg/L	2/6/2006 13:54
1,2-Dichloropropane	< 5.0	5.0	µg/L	2/6/2006 13:54
Bromodichloromethane	< 5.0	5.0	µg/L	2/6/2006 13:54
2-Chloroethyl vinyl ether	< 10	10	µg/L	2/6/2006 13:54
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	2/6/2006 13:54
Toluene	< 5.0	5.0	µg/L	2/6/2006 13:54
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	2/6/2006 13:54
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	2/6/2006 13:54
Tetrachloroethene	79	5.0	µg/L	2/6/2006 13:54
Dibromochloromethane	< 5.0	5.0	µg/L	2/6/2006 13:54
Chlorobenzene	< 5.0	5.0	µg/L	2/6/2006 13:54
Ethylbenzene	< 5.0	5.0	µg/L	2/6/2006 13:54
Bromoform	< 5.0	5.0	µg/L	2/6/2006 13:54
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	2/6/2006 13:54
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	2/6/2006 13:54
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	2/6/2006 13:54



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

Test Results

Page 3

Client:	BTR Hampstead, Inc.	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0602011		
Project:	Hampstead-Quarterly	Lab ID:	0602011-002
Matrix:	WASTEWATER	Collection Date:	2/1/2006 9:05

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	2/6/2006 13:54



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 4

Client: BTR Hampstead, Inc. Client Sample ID: Outfall 201 (Post)
 Report No: 0602011
 Project: Hampstead-Quarterly Lab ID: 0602011-003
 Matrix: WASTEWATER Collection Date: 2/1/2006 9:06

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed	
VOLATILE ORGANIC COMPOUNDS (EPA 624)					
Prep. Method: <u>NA</u>	Prep. Date: <u>NA</u>		Prep Analyst	<u>NA</u>	
				Analyst: MLS	
Chloromethane	< 10	10	µg/L	2/3/2006	22:52
Vinyl chloride	< 10	10	µg/L	2/3/2006	22:52
Bromomethane	< 10	10	µg/L	2/3/2006	22:52
Chloroethane	< 10	10	µg/L	2/3/2006	22:52
Acrolein	< 100	100	µg/L	2/3/2006	22:52
1,1-Dichloroethene	< 5.0	5.0	µg/L	2/3/2006	22:52
Methylene chloride	< 5.0	5.0	µg/L	2/3/2006	22:52
Acrylonitrile	< 100	100	µg/L	2/3/2006	22:52
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	2/3/2006	22:52
1,1-Dichloroethane	< 5.0	5.0	µg/L	2/3/2006	22:52
Chloroform	< 5.0	5.0	µg/L	2/3/2006	22:52
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	2/3/2006	22:52
Carbon tetrachloride	< 5.0	5.0	µg/L	2/3/2006	22:52
Benzene	< 5.0	5.0	µg/L	2/3/2006	22:52
1,2-Dichloroethane	< 5.0	5.0	µg/L	2/3/2006	22:52
Trichloroethene	< 5.0	5.0	µg/L	2/3/2006	22:52
1,2-Dichloropropane	< 5.0	5.0	µg/L	2/3/2006	22:52
Bromodichloromethane	< 5.0	5.0	µg/L	2/3/2006	22:52
2-Chloroethyl vinyl ether	< 10	10	µg/L	2/3/2006	22:52
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	2/3/2006	22:52
Toluene	< 5.0	5.0	µg/L	2/3/2006	22:52
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	2/3/2006	22:52
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	2/3/2006	22:52
Tetrachloroethene	< 5.0	5.0	µg/L	2/3/2006	22:52
Dibromochloromethane	< 5.0	5.0	µg/L	2/3/2006	22:52
Chlorobenzene	< 5.0	5.0	µg/L	2/3/2006	22:52
Ethylbenzene	< 5.0	5.0	µg/L	2/3/2006	22:52
Bromoform	< 5.0	5.0	µg/L	2/3/2006	22:52
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	2/3/2006	22:52
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	2/3/2006	22:52
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	2/3/2006	22:52



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

Test Results

Page 5

Client:	BTR Hampstead, Inc.	Client Sample ID:	Outfall 201 (Post)
Report No:	0602011		
Project:	Hampstead-Quarterly	Lab ID:	0602011-003
Matrix:	WASTEWATER	Collection Date:	2/1/2006 9:06

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	2/3/2006 22:52



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 4

Client:	BTR Hampstead, Inc.	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0603018	Lab ID:	0603018-002
Project:	Hampstead-Monthly	Collection Date:	3/1/2006 10:19
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
VOLATILE ORGANIC COMPOUNDS (EPA 624)				Analyst: MLS
Prep. Method: <u>NA</u>	Prep. Date: <u>NA</u>	Prep Analyst: <u>NA</u>		
<i>note: Large SO2 peak detected in sample may interfere with chloromethane.</i>				
Chloromethane	< 10	10	µg/L	3/6/2006 22:35
Vinyl chloride	< 10	10	µg/L	3/6/2006 22:35
Bromomethane	< 10	10	µg/L	3/6/2006 22:35
Chloroethane	< 10	10	µg/L	3/6/2006 22:35
Acrolein	< 100	100	µg/L	3/6/2006 22:35
1,1-Dichloroethene	< 5.0	5.0	µg/L	3/6/2006 22:35
Methylene chloride	< 5.0	5.0	µg/L	3/6/2006 22:35
Acrylonitrile	< 100	100	µg/L	3/6/2006 22:35
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	3/6/2006 22:35
1,1-Dichloroethane	< 5.0	5.0	µg/L	3/6/2006 22:35
Chloroform	< 5.0	5.0	µg/L	3/6/2006 22:35
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	3/6/2006 22:35
Carbon tetrachloride	< 5.0	5.0	µg/L	3/6/2006 22:35
Benzene	< 5.0	5.0	µg/L	3/6/2006 22:35
1,2-Dichloroethane	< 5.0	5.0	µg/L	3/6/2006 22:35
Trichloroethene	130	5.0	µg/L	3/6/2006 22:35
1,2-Dichloropropane	< 5.0	5.0	µg/L	3/6/2006 22:35
Bromodichloromethane	< 5.0	5.0	µg/L	3/6/2006 22:35
2-Chloroethyl vinyl ether	< 10	10	µg/L	3/6/2006 22:35
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	3/6/2006 22:35
Toluene	< 5.0	5.0	µg/L	3/6/2006 22:35
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	3/6/2006 22:35
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	3/6/2006 22:35
Tetrachloroethene	77	5.0	µg/L	3/6/2006 22:35
Dibromochloromethane	< 5.0	5.0	µg/L	3/6/2006 22:35
Chlorobenzene	< 5.0	5.0	µg/L	3/6/2006 22:35
Ethylbenzene	< 5.0	5.0	µg/L	3/6/2006 22:35
Bromoform	< 5.0	5.0	µg/L	3/6/2006 22:35
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	3/6/2006 22:35
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	3/6/2006 22:35
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	3/6/2006 22:35



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800
Fax: 410-633-6553
www.microbac.com

Test Results

Page 5

Client:	BTR Hampstead, Inc.	Client Sample ID:	Air Stripper 2 (Pre)
Report No:	0603018	Lab ID:	0603018-002
Project:	Hampstead-Monthly	Collection Date:	3/1/2006 10:19
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	3/6/2006 22:35



Microbac Laboratories, Inc.

Gascoyne Division

Phone: 410-633-1800
 Fax: 410-633-6553
 www.microbac.com

2101 Van Deman Street • Baltimore, MD 21224

Test Results

Page 6

Client: BTR Hampstead, Inc. Client Sample ID: Outfall 201 (Post)
 Report No: 0603018
 Project: Hampstead-Monthly Lab ID: 0603018-003
 Matrix: WASTEWATER Collection Date: 3/1/2006 10:18

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
VOLATILE ORGANIC COMPOUNDS (EPA 624)				
Prep. Method: <u>NA</u>	Prep. Date: <u>NA</u>		Prep Analyst <u>NA</u>	Analyst: <u>MLS</u>
Chloromethane	< 10	10	µg/L	3/6/2006 23:10
Vinyl chloride	< 10	10	µg/L	3/6/2006 23:10
Bromomethane	< 10	10	µg/L	3/6/2006 23:10
Chloroethane	< 10	10	µg/L	3/6/2006 23:10
Acrolein	< 100	100	µg/L	3/6/2006 23:10
1,1-Dichloroethene	< 5.0	5.0	µg/L	3/6/2006 23:10
Methylene chloride	< 5.0	5.0	µg/L	3/6/2006 23:10
Acrylonitrile	< 100	100	µg/L	3/6/2006 23:10
trans-1,2-Dichloroethene	< 5.0	5.0	µg/L	3/6/2006 23:10
1,1-Dichloroethane	< 5.0	5.0	µg/L	3/6/2006 23:10
Chloroform	< 5.0	5.0	µg/L	3/6/2006 23:10
1,1,1-Trichloroethane	< 5.0	5.0	µg/L	3/6/2006 23:10
Carbon tetrachloride	< 5.0	5.0	µg/L	3/6/2006 23:10
Benzene	< 5.0	5.0	µg/L	3/6/2006 23:10
1,2-Dichloroethane	< 5.0	5.0	µg/L	3/6/2006 23:10
Trichloroethene	< 5.0	5.0	µg/L	3/6/2006 23:10
1,2-Dichloropropane	< 5.0	5.0	µg/L	3/6/2006 23:10
Bromodichloromethane	< 5.0	5.0	µg/L	3/6/2006 23:10
2-Chloroethyl vinyl ether	< 10	10	µg/L	3/6/2006 23:10
cis-1,3-Dichloropropene	< 5.0	5.0	µg/L	3/6/2006 23:10
Toluene	< 5.0	5.0	µg/L	3/6/2006 23:10
trans-1,3-Dichloropropene	< 5.0	5.0	µg/L	3/6/2006 23:10
1,1,2-Trichloroethane	< 5.0	5.0	µg/L	3/6/2006 23:10
Tetrachloroethene	< 5.0	5.0	µg/L	3/6/2006 23:10
Dibromochloromethane	< 5.0	5.0	µg/L	3/6/2006 23:10
Chlorobenzene	< 5.0	5.0	µg/L	3/6/2006 23:10
Ethylbenzene	< 5.0	5.0	µg/L	3/6/2006 23:10
Bromoform	< 5.0	5.0	µg/L	3/6/2006 23:10
1,1,2,2-Tetrachloroethane	< 5.0	5.0	µg/L	3/6/2006 23:10
1,3-Dichlorobenzene	< 5.0	5.0	µg/L	3/6/2006 23:10
1,4-Dichlorobenzene	< 5.0	5.0	µg/L	3/6/2006 23:10



Microbac Laboratories, Inc.

Gascoyne Division

2101 Van Deman Street • Baltimore, MD 21224

Phone: 410-633-1800

Fax: 410-633-6553

www.microbac.com

Test Results

Page 7

Client:	BTR Hampstead, Inc.	Client Sample ID:	Outfall 201 (Post)
Report No:	0603018	Lab ID:	0603018-003
Project:	Hampstead-Monthly	Collection Date:	3/1/2006 10:18
Matrix:	WASTEWATER		

Analyses	Test Results	Reporting Limit	Units	Date/Time Analyzed
1,2-Dichlorobenzene	< 5.0	5.0	µg/L	3/6/2006 23:10

**APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(FEBRUARY 2006)**

STL Chicago
2417 Bond Street
University Park, IL 60466

Tel: 708 534 5200 Fax: 708 534 5211
www.stl-inc.com

SEVERN TRENT LABORATORIES
ANALYTICAL REPORT

JOB NUMBER: 244715

Prepared For:

Weston Solutions, Inc.
Building 5-2
1400 Weston Way
West Chester, PA 19380-1499

Project: Black & Decker - MD

Attention: Tom Cornuet

Date: 03/15/2006

Signature

Name: Richard C. Wright

Title: Project Manager

E-Mail: rwright@stl-inc.com

Date

3/15/06

STL Chicago
2417 Bond Street
University Park, IL 60466

PHONE: (708) 534-5200
FAX...: (708) 534-5211

This Report Contains (110) Pages

Severn Trent Laboratories Chicago
GC/MS Case Narrative

Weston Solutions
Black and Decker
JOB Number: 244715
VOA DATA:

1. All of the samples were analyzed within the 14-day hold time from the date of collection.
2. All Method Blank target compounds were below reporting limits.
3. The LCS (Laboratory Control Samples) had all five-controlled spike recoveries within the in-house generated QC limits.
4. Matrix Spike/Matrix Spike Duplicate analyses were not performed on this sample set.
5. The volatile samples had all surrogate recoveries within the in-house generated QC limits.
6. The water samples were prepared using Method 5030 and analyzed following SW846 Method 8260B and 8000B. All calibration criteria are met per method or SOP (for minimum R values for certain compounds). The low point in the initial calibration verifies the base reporting limits. The target compounds were quantitated using the initial calibration.
7. The volatile samples had all internal standard areas and retention times within the SOP acceptance limits as compared to the corresponding calibration verification standard.
8. The water samples were analyzed using a 10-mL purge volume. An initial dilution was required on sample 3 due to sample matrix. Secondary dilutions for target compounds were required on samples 1, 2, 3, 4, 8, 9, and 23. The results and reporting limits were adjusted to account for the dilution performed.



John Nagel
GC/MS Dept.

3-13-06
Date

STL Chicago is part of Severn Trent Laboratories, Inc.

SAMPLE INFORMATION
Date: 03/15/2006

Job Number.: 244715
Customer...: Weston Solutions, Inc.
Attn.....: Tom Cornuet

Project Number.....: 20005711
Customer Project ID.....: BLACK AND DECKER
Project Description.....: Black & Decker - MD

Laboratory Sample ID	Customer Sample ID	Sample Matrix	Date Sampled	Time Sampled	Date Received	Time Received
244715-1	EW-2	Water	02/28/2006	09:45	03/02/2006	10:10
244715-2	EW-3	Water	02/28/2006	10:00	03/02/2006	10:10
244715-3	EW-4	Water	02/28/2006	12:10	03/02/2006	10:10
244715-4	EW-5	Water	02/28/2006	11:15	03/02/2006	10:10
244715-5	EW-6	Water	02/27/2006	13:35	03/02/2006	10:10
244715-6	EW-7	Water	02/27/2006	13:40	03/02/2006	10:10
244715-7	EW-8	Water	02/27/2006	13:45	03/02/2006	10:10
244715-8	EW-9	Water	02/27/2006	13:55	03/02/2006	10:10
244715-9	EW-9 DUP	Water	02/27/2006	13:55	03/02/2006	10:10
244715-10	EW-10	Water	02/27/2006	14:05	03/02/2006	10:10
244715-11	RFW-1A	Water	02/27/2006	09:00	03/02/2006	10:10
244715-12	RFW-1B	Water	02/28/2006	08:30	03/02/2006	10:10
244715-13	RFW-2A	Water	02/27/2006	08:00	03/02/2006	10:10
244715-14	RFW-2B	Water	02/27/2006	08:20	03/02/2006	10:10
244715-15	RFW-3B	Water	02/28/2006	08:15	03/02/2006	10:10
244715-16	RFW-4A	Water	02/28/2006	07:30	03/02/2006	10:10
244715-17	RFW-4B	Water	02/28/2006	08:00	03/02/2006	10:10
244715-18	RFW-4B DUP	Water	02/28/2006	08:00	03/02/2006	10:10
244715-19	RFW-6	Water	02/28/2006	07:45	03/02/2006	10:10
244715-20	RFW-7	Water	02/27/2006	09:50	03/02/2006	10:10
244715-21	RFW-9	Water	02/28/2006	12:00	03/02/2006	10:10
244715-22	RFW-11B	Water	02/28/2006	12:30	03/02/2006	10:10
244715-23	RFW-12B	Water	02/28/2006	08:50	03/02/2006	10:10
244715-24	RFW-13	Water	02/27/2006	14:25	03/02/2006	10:10
244715-25	RFW-17	Water	02/27/2006	10:45	03/02/2006	10:10
244715-26	TRIP BLANK	Water	02/27/2006	08:00	03/02/2006	10:10

STL Chicago is part of Severn Trent Laboratories, Inc.

SAMPLE INFORMATION
Date:

Job Number.: 244715

Customer...: Weston Solutions, Inc.

Attn.....: Tom Cornuet

Project Number.....: 20005711

Customer Project ID....: BLACK AND DECKER

Project Description....: Black & Decker - MD

Laboratory Sample ID	Customer Sample ID	Sample Matrix	Date Sampled	Time Sampled	Date Received	Time Received
244715-27	LEISTER-1	Water	02/27/2006	17:15	03/02/2006	10:10
244715-28	LEISTER-DAIRY	Water	02/27/2006	17:20	03/02/2006	10:10

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-2
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 09:45
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-1
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	cis-1,2-Dichloroethene	3.6	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Trichloroethene	520	U		1.3	10	10.00000	ug/L	175148	D1	03/07/06 1609	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1544	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175148		03/07/06 1544	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-2
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 09:45
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-1
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Tetrachloroethene	63			0.18	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175148		03/07/06 1544	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1544	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1544	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

TEST METHOD		PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
<p>Job Number: 244715 LABORATORY TEST RESULTS Date: 03/15/2006</p> <p>CUSTOMER: Weston Solutions, Inc. PROJECT: BLACK AND DECKER ATTN: Tom Cornuet</p> <p>Customer Sample ID: EW-2 Laboratory Sample ID: 244715-1 Date Sampled.....: 02/28/2006 Date Received.....: 03/02/2006 Time Sampled.....: 09:45 Time Received.....: 10:10 Sample Matrix.....: Water</p>													
		n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1544	jd n
		1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1544	jd n
		1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175148		03/07/06 1544	jd n
		1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1544	jd n
		Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1544	jd n
		Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175148		03/07/06 1544	jd n
		1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175148		03/07/06 1544	jd n

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-3
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 10:00
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-2
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	cis-1,2-Dichloroethene	1.7	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Trichloroethene	170	U		1.3	10	10.0000	ug/L	175148	01	03/07/06 1658	jd
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1634	jd
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175148		03/07/06 1634	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS												
Job Number: 244715								Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: EW-3 Date Sampled.....: 02/28/2006 Time Sampled.....: 10:00 Sample Matrix.....: Water						Laboratory Sample ID: 244715-2 Date Received.....: 03/02/2006 Time Received.....: 10:10						
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	Tetrachloroethane	5.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS												
Job Number: 244715								Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: EW-3 Date Sampled.....: 02/28/2006 Time Sampled.....: 10:00 Sample Matrix.....: Water						Laboratory Sample ID: 244715-2 Date Received.....: 03/02/2006 Time Received.....: 10:10						
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175148		03/07/06 1634	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-4
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 12:10
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-3
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	5.0	U		0.60	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Chloromethane	5.0	U		1.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Vinyl chloride	5.0	U		0.80	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Bromomethane	5.0	U		3.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Chloroethane	5.0	U		1.6	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Trichlorofluoromethane	5.0	U		0.70	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,1-Dichloroethane	5.0	U		1.2	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Carbon disulfide	25	U		0.75	25	5.00000	ug/L	175148		03/07/06 1723	jdj
	Acetone	25	U		7.0	25	5.00000	ug/L	175148		03/07/06 1723	jdj
	Methylene chloride	5.0	U		1.2	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	trans-1,2-Dichloroethene	5.0	U		1.4	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,1-Dichloroethane	5.0	U		0.75	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	2,2-Dichloropropane	5.0	U		0.85	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	cis-1,2-Dichloroethene	5.0	U		1.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	2-Butanone (MEK)	25	U		5.0	25	5.00000	ug/L	175148		03/07/06 1723	jdj
	Bromochloromethane	5.0	U		1.4	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Chloroform	5.0	U		0.70	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,1,1-Trichloroethane	5.0	U		0.85	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,1-Dichloropropene	5.0	U		1.9	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Carbon tetrachloride	5.0	U		1.7	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Benzene	5.0	U		1.2	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2-Dichloroethane	5.0	U		1.2	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Trichloroethene	1200	U		6.5	50	50.00000	ug/L	175148	D1	03/07/06 1748	jdj
	1,2-Dichloropropane	5.0	U		0.95	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Dibromomethane	5.0	U		1.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Bromodichloromethane	5.0	U		1.1	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	cis-1,3-Dichloropropene	5.0	U		0.75	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	4-Methyl-2-pentanone (MIBK)	25	U		4.6	25	5.00000	ug/L	175148		03/07/06 1723	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-4
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 12:10
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-3
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	5.0	U		0.90	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	trans-1,3-Dichloropropene	5.0	U		0.80	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,1,2-Trichloroethane	5.0	U		1.2	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Tetrachloroethane	26			0.90	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,3-Dichloropropane	5.0	U		1.1	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	2-Hexanone	25	U		5.0	25	5.00000	ug/L	175148		03/07/06 1723	jdj
	Dibromochloromethane	5.0	U		1.1	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2-Dibromoethane (EDB)	5.0	U		1.6	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Chlorobenzene	5.0	U		0.75	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,1,1,2-Tetrachloroethane	5.0	U		1.6	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Ethylbenzene	5.0	U		1.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	m&p-Xylenes	10	U		1.8	10	5.00000	ug/L	175148		03/07/06 1723	jdj
	o-Xylene	5.0	U		0.95	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Styrene	5.0	U		0.90	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Bromoform	5.0	U		1.6	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Isopropylbenzene	5.0	U		1.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Bromobenzene	5.0	U		1.1	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,1,2,2-Tetrachloroethane	5.0	U		1.7	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2,3-Trichloropropane	5.0	U		1.8	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	n-Propylbenzene	5.0	U		0.80	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	2-Chlorotoluene	5.0	U		0.80	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,3,5-Trimethylbenzene	5.0	U		0.90	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	4-Chlorotoluene	5.0	U		0.90	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	tert-Butylbenzene	5.0	U		0.80	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2,4-Trimethylbenzene	5.0	U		1.3	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	sec-Butylbenzene	5.0	U		0.95	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,3-Dichlorobenzene	5.0	U		1.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	p-Isopropyltoluene	5.0	U		1.4	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,4-Dichlorobenzene	5.0	U		1.2	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS						Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-4 Date Sampled.....: 02/28/2006 Time Sampled.....: 12:10 Sample Matrix.....: Water			Laboratory Sample ID: 244715-3 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	5.0	U		1.8	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2-Dichlorobenzene	5.0	U		1.4	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2-Dibromo-3-chloropropane	5.0	U		2.0	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2,4-Trichlorobenzene	5.0	U		1.8	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Hexachlorobutadiene	5.0	U		1.8	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	Naphthalene	5.0	U		1.8	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj
	1,2,3-Trichlorobenzene	5.0	U		2.2	5.0	5.00000	ug/L	175148		03/07/06 1723	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-5
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 11:15
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-4
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,1-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	trans-1,2-Dichloroethane	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	cis-1,2-Dichloroethane	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,1,1-Trichloroethane	1.2	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Trichloroethane	260	U		1.3	10	10.0000	ug/L	175148	D1	03/07/06 1837	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175148		03/07/06 1812	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-5
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 11:15
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-4
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Tetrachloroethene	7.8	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS							Date: 03/15/2006			
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-5 Date Sampled.....: 02/28/2006 Time Sampled.....: 11:15 Sample Matrix.....: Water			Laboratory Sample ID: 244715-4 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175148		03/07/06 1812	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS						Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-6 Date Sampled.....: 02/27/2006 Time Sampled.....: 13:35 Sample Matrix.....: Water			Laboratory Sample ID: 244715-5 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Trichloroethene	11	U		0.13	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175148		03/07/06 1903	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-6
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 13:35
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-5
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	Tetrachloroethane	19			0.18	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1903	jdn

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS						Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-6 Date Sampled.....: 02/27/2006 Time Sampled.....: 13:35 Sample Matrix.....: Water			Laboratory Sample ID: 244715-5 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175148		03/07/06 1903	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-7
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 13:40
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-6
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	cis-1,2-Dichloroethene	8.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Trichloroethene	7.2	U		0.13	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1928	jd
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175148		03/07/06 1928	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-7
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 13:40
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-6
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Tetrachloroethane	13			0.18	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS						Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-7 Date Sampled.....: 02/27/2006 Time Sampled.....: 13:40 Sample Matrix.....: Water			Laboratory Sample ID: 244715-6 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175148		03/07/06 1928	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-8
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 13:45
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-7
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	cis-1,2-Dichloroethene	23	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Trichloroethene	12	U		0.13	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175148		03/07/06 1952	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-8
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 13:45
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-7
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Tetrachloroethane	73			0.18	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175148		03/07/06 1952	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS						Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-8 Date Sampled.....: 02/27/2006 Time Sampled.....: 13:45 Sample Matrix.....: Water			Laboratory Sample ID: 244715-7 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175148		03/07/06 1952	jd
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175148		03/07/06 1952	jd
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175148		03/07/06 1952	jd
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1952	jd
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175148		03/07/06 1952	jd
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175148		03/07/06 1952	jd
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175148		03/07/06 1952	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS							Date: 03/15/2006			
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-9 Date Sampled.....: 02/27/2006 Time Sampled.....: 13:55 Sample Matrix.....: Water			Laboratory Sample ID: 244715-8 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	cis-1,2-Dichloroethene	1.5	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Trichloroethene	2.2	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 1308	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-9
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 13:55
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-8
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Tetrachloroethane	310			1.8	10	10.0000	ug/L	175552	D1	03/08/06 1333	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 1308	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1308	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1308	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS												
Job Number: 244715								Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: EW-9 Date Sampled.....: 02/27/2006 Time Sampled.....: 13:55 Sample Matrix.....: Water						Laboratory Sample ID: 244715-8 Date Received.....: 03/02/2006 Time Received.....: 10:10						
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0		U	0.35	1.0	1.00000	ug/L	175552		03/08/06 1308	jdj
	1,2-Dichlorobenzene	1.0		U	0.29	1.0	1.00000	ug/L	175552		03/08/06 1308	jdj
	1,2-Dibromo-3-chloropropane	1.0		U	0.41	1.0	1.00000	ug/L	175552		03/08/06 1308	jdj
	1,2,4-Trichlorobenzene	1.0		U	0.36	1.0	1.00000	ug/L	175552		03/08/06 1308	jdj
	Hexachlorobutadiene	1.0		U	0.36	1.0	1.00000	ug/L	175552		03/08/06 1308	jdj
	Naphthalene	1.0		U	0.37	1.0	1.00000	ug/L	175552		03/08/06 1308	jdj
	1,2,3-Trichlorobenzene	1.0		U	0.43	1.0	1.00000	ug/L	175552		03/08/06 1308	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS							Date: 03/15/2006			
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-9 DUP Date Sampled.....: 02/27/2006 Time Sampled.....: 13:55 Sample Matrix.....: Water			Laboratory Sample ID: 244715-9 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	cis-1,2-Dichloroethene	1.3	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Trichloroethene	2.2	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 1358	jd

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-9 DUP
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 13:55
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-9
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Tetrachloroethene	310			1.8	10	10.0000	ug/L	175552	D1	03/08/06 1423	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 1358	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1358	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1358	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS						Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-9 DUP Date Sampled.....: 02/27/2006 Time Sampled.....: 13:55 Sample Matrix.....: Water			Laboratory Sample ID: 244715-9 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1358	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1358	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175552		03/08/06 1358	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1358	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1358	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175552		03/08/06 1358	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175552		03/08/06 1358	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-10
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 14:05
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-10
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 1447	jdn

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: EW-10
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 14:05
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-10
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Tetrachloroethane	9.1	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1447	jdn

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS						Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: EW-10 Date Sampled.....: 02/27/2006 Time Sampled.....: 14:05 Sample Matrix.....: Water			Laboratory Sample ID: 244715-10 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0		U	0.35	1.0	1.00000	ug/L	175552		03/08/06 1447	jdj
	1,2-Dichlorobenzene	1.0		U	0.29	1.0	1.00000	ug/L	175552		03/08/06 1447	jdj
	1,2-Dibromo-3-chloropropane	1.0		U	0.41	1.0	1.00000	ug/L	175552		03/08/06 1447	jdj
	1,2,4-Trichlorobenzene	1.0		U	0.36	1.0	1.00000	ug/L	175552		03/08/06 1447	jdj
	Hexachlorobutadiene	1.0		U	0.36	1.0	1.00000	ug/L	175552		03/08/06 1447	jdj
	Naphthalene	1.0		U	0.37	1.0	1.00000	ug/L	175552		03/08/06 1447	jdj
	1,2,3-Trichlorobenzene	1.0		U	0.43	1.0	1.00000	ug/L	175552		03/08/06 1447	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-1A
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 09:00
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-11
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 1512	jd

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-1A
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 09:00
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-11
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Tetrachloroethane	1.2	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 1512	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1512	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1512	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS						Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: RFW-1A Date Sampled.....: 02/27/2006 Time Sampled.....: 09:00 Sample Matrix.....: Water			Laboratory Sample ID: 244715-11 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1512	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1512	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175552		03/08/06 1512	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1512	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1512	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175552		03/08/06 1512	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175552		03/08/06 1512	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-1B
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 08:30
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-12
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 1537	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-1B
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 08:30
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-12
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715 Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc. PROJECT: BLACK AND DECKER ATTN: Tom Cornuet

Customer Sample ID: RFW-1B
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 08:30
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-12
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175552		03/08/06 1537	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS						Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: RFW-2A Date Sampled.....: 02/27/2006 Time Sampled.....: 08:00 Sample Matrix.....: Water			Laboratory Sample ID: 244715-13 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	Trichloroethene	1.3	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1601	jdn
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 1601	jdn

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-2A
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 08:00
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-13
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	Tetrachloroethane	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

TEST METHOD		PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
		n-Butylbenzene	1.0		U	0.35	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
		1,2-Dichlorobenzene	1.0		U	0.29	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
		1,2-Dibromo-3-chloropropane	1.0		U	0.41	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
		1,2,4-Trichlorobenzene	1.0		U	0.36	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
		Hexachlorobutadiene	1.0		U	0.36	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
		Naphthalene	1.0		U	0.37	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj
		1,2,3-Trichlorobenzene	1.0		U	0.43	1.0	1.00000	ug/L	175552		03/08/06 1601	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS												
Job Number: 244715								Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: RFW-2B Date Sampled.....: 02/27/2006 Time Sampled.....: 08:20 Sample Matrix.....: Water						Laboratory Sample ID: 244715-14 Date Received.....: 03/02/2006 Time Received.....: 10:10						
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Trichloroethene	2.0	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 1626	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-2B
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 08:20
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-14
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS												
Job Number: 244715								Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: RFW-2B Date Sampled.....: 02/27/2006 Time Sampled.....: 08:20 Sample Matrix.....: Water						Laboratory Sample ID: 244715-14 Date Received.....: 03/02/2006 Time Received.....: 10:10						
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0		U	0.35	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,2-Dichlorobenzene	1.0		U	0.29	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,2-Dibromo-3-chloropropane	1.0		U	0.41	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,2,4-Trichlorobenzene	1.0		U	0.36	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Hexachlorobutadiene	1.0		U	0.36	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	Naphthalene	1.0		U	0.37	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj
	1,2,3-Trichlorobenzene	1.0		U	0.43	1.0	1.00000	ug/L	175552		03/08/06 1626	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS						Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet					
Customer Sample ID: RFW-3B Date Sampled.....: 02/28/2006 Time Sampled.....: 08:15 Sample Matrix.....: Water			Laboratory Sample ID: 244715-15 Date Received.....: 03/02/2006 Time Received.....: 10:10									
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	cis-1,2-Dichloroethene	9.3	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	Trichloroethene	1.2	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 1651	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-3B
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 08:15
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-15
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	Tetrachloroethane	4.7	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 1651	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 1651	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1651	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1651	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number: 244715		LABORATORY TEST RESULTS						Date: 03/15/2006					
CUSTOMER: Weston Solutions, Inc.			PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet						
Customer Sample ID: RFW-3B Date Sampled.....: 02/28/2006 Time Sampled.....: 08:15 Sample Matrix.....: Water			Laboratory Sample ID: 244715-15 Date Received.....: 03/02/2006 Time Received.....: 10:10										
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH	
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj	
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj	
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj	
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj	
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj	
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj	
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175552		03/08/06 1651	jdj	

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-4A
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 07:30
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-16
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	cis-1,2-Dichloroethene	1.2	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	Trichloroethene	41	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1716	jdn
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 1716	jdn

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-4A
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 07:30
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-16
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	Tetrachloroethene	40			0.18	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS												
Job Number: 244715								Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: RFW-4A Date Sampled.....: 02/28/2006 Time Sampled.....: 07:30 Sample Matrix.....: Water						Laboratory Sample ID: 244715-16 Date Received.....: 03/02/2006 Time Received.....: 10:10						
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175552		03/08/06 1716	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS												
Job Number: 244715								Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: RFW-4B						Laboratory Sample ID: 244715-17						
Date Sampled.....: 02/28/2006						Date Received.....: 03/02/2006						
Time Sampled.....: 08:00						Time Received.....: 10:10						
Sample Matrix.....: Water												
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	cis-1,2-Dichloroethene	4.5	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Trichloroethene	13	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 1741	jd

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-4B
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 08:00
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-17
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Tetrachloroethene	37			0.18	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 1741	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1741	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1741	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS												
Job Number: 244715								Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: RFW-4B Date Sampled.....: 02/28/2006 Time Sampled.....: 08:00 Sample Matrix.....: Water						Laboratory Sample ID: 244715-17 Date Received.....: 03/02/2006 Time Received.....: 10:10						
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1741	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1741	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175552		03/08/06 1741	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1741	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1741	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175552		03/08/06 1741	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175552		03/08/06 1741	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-4B DUP
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 08:00
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-18
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	cis-1,2-Dichloroethene	4.4	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Trichloroethene	13	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 1805	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-4B DUP
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 08:00
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-18
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Tetrachloroethane	36			0.18	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 1805	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1805	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1805	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

L A B O R A T O R Y T E S T R E S U L T S

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-4B DUP
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 08:00
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-18
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0		U	0.35	1.0	1.00000	ug/L	175552		03/08/06 1805	jdj
	1,2-Dichlorobenzene	1.0		U	0.29	1.0	1.00000	ug/L	175552		03/08/06 1805	jdj
	1,2-Dibromo-3-chloropropane	1.0		U	0.41	1.0	1.00000	ug/L	175552		03/08/06 1805	jdj
	1,2,4-Trichlorobenzene	1.0		U	0.36	1.0	1.00000	ug/L	175552		03/08/06 1805	jdj
	Hexachlorobutadiene	1.0		U	0.36	1.0	1.00000	ug/L	175552		03/08/06 1805	jdj
	Naphthalene	1.0		U	0.37	1.0	1.00000	ug/L	175552		03/08/06 1805	jdj
	1,2,3-Trichlorobenzene	1.0		U	0.43	1.0	1.00000	ug/L	175552		03/08/06 1805	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-6
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 07:45
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-19
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	cis-1,2-Dichloroethene	1.4	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Trichloroethene	8.8	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 1830	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-6
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 07:45
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-19
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Tetrachloroethene	6.9	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1830	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715 Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc. PROJECT: BLACK AND DECKER ATTN: Tom Cornuet

Customer Sample ID: RFW-6
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 07:45
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-19
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1830	jd
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1830	jd
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175552		03/08/06 1830	jd
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1830	jd
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1830	jd
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175552		03/08/06 1830	jd
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175552		03/08/06 1830	jd

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-7
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 09:50
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-20
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Trichloroethene	4.3	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 1855	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-7
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 09:50
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-20
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	Tetrachloroethane	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 1855	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 1855	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	1,1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1855	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1855	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS												
Job Number: 244715								Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: RFW-7 Date Sampled.....: 02/27/2006 Time Sampled.....: 09:50 Sample Matrix.....: Water						Laboratory Sample ID: 244715-20 Date Received.....: 03/02/2006 Time Received.....: 10:10						
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175552		03/08/06 1855	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-9
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 12:00
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-21
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	1,1-Dichloroethene	1.5	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	1,1-Dichloroethane	1.3	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	cis-1,2-Dichloroethene	14	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	1,1,1-Trichloroethane	2.1	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Trichloroethene	22	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 1919	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-9
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 12:00
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-21
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	Tetrachloroethane	6.9	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 1919	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 1919	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1919	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1919	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS												
Job Number: 244715								Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: RFW-9 Date Sampled.....: 02/28/2006 Time Sampled.....: 12:00 Sample Matrix.....: Water						Laboratory Sample ID: 244715-21 Date Received.....: 03/02/2006 Time Received.....: 10:10						
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175552		03/08/06 1919	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-11B
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 12:30
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-22
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Trichloroethene	27	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 1944	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS												
Job Number: 244715								Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: RFW-11B Date Sampled.....: 02/28/2006 Time Sampled.....: 12:30 Sample Matrix.....: Water						Laboratory Sample ID: 244715-22 Date Received.....: 03/02/2006 Time Received.....: 10:10						
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 1944	jdj

* In Description = Dry Wgt.

L A B O R A T O R Y T E S T R E S U L T S

Job Number: 244715

Date:03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-11B
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 12:30
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-22
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 1944	jd
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 1944	jd
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175552		03/08/06 1944	jd
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1944	jd
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 1944	jd
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175552		03/08/06 1944	jd
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175552		03/08/06 1944	jd

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-12B
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 08:50
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-23
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	cis-1,2-Dichloroethene	6.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	Trichloroethene	630	U		1.3	10	10.0000	ug/L	175552	D1	03/08/06 2034	jdn
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 2009	jdn
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 2009	jdn

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-12B
 Date Sampled.....: 02/28/2006
 Time Sampled.....: 08:50
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-23
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	Tetrachloroethane	48			0.18	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	1,1,1,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS												
Job Number: 244715								Date: 03/15/2006				
CUSTOMER: Weston Solutions, Inc.				PROJECT: BLACK AND DECKER				ATTN: Tom Cornuet				
Customer Sample ID: RFW-12B Date Sampled.....: 02/28/2006 Time Sampled.....: 08:50 Sample Matrix.....: Water				Laboratory Sample ID: 244715-23 Date Received.....: 03/02/2006 Time Received.....: 10:10								
TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175552		03/08/06 2009	jdj

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-13
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 14:25
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-24
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	Trichloroethene	16	U		0.13	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 2058	jdn
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175552		03/08/06 2058	jdn

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-13
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 14:25
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-24
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	Tetrachloroethene	41			0.18	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175552		03/08/06 2058	jd
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175552		03/08/06 2058	jd
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 2058	jd
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175552		03/08/06 2058	jd

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

L A B O R A T O R Y T E S T R E S U L T S

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-13
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 14:25
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-24
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175552		03/08/06 2058	jdj
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175552		03/08/06 2058	jdj
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175552		03/08/06 2058	jdj
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 2058	jdj
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175552		03/08/06 2058	jdj
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175552		03/08/06 2058	jdj
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175552		03/08/06 2058	jdj

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-17
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 10:45
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-25
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175423		03/09/06 0447	mak

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-17
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 10:45
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-25
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175423		03/09/06 0447	mak
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175423		03/09/06 0447	mak

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

L A B O R A T O R Y T E S T R E S U L T S

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: RFW-17
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 10:45
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-25
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175423		03/09/06 0447	mak
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175423		03/09/06 0447	mak

* In Description = Dry Wgt.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: TRIP BLANK
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 08:00
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-26
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175423		03/09/06 0512	mak

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: TRIP BLANK
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 08:00
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-26
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175423		03/09/06 0512	mak
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175423		03/09/06 0512	mak

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

L A B O R A T O R Y T E S T R E S U L T S

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: TRIP BLANK
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 08:00
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-26
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175423		03/09/06 0512	mak
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175423		03/09/06 0512	mak

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: LEISTER-1
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 17:15
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-27
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175423		03/09/06 0536	mak

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: LEISTER-1
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 17:15
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-27
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175423		03/09/06 0536	mak
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175423		03/09/06 0536	mak

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: LEISTER-1
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 17:15
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-27
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175423		03/09/06 0536	mak
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175423		03/09/06 0536	mak

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: LEISTER-DAIRY
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 17:20
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-28
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
8260B	Volatile Organics											
	Dichlorodifluoromethane	1.0	U		0.12	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Chloromethane	1.0	U		0.20	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Vinyl chloride	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Bromomethane	1.0	U		0.59	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Chloroethane	1.0	U		0.32	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Trichlorofluoromethane	1.0	U		0.14	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,1-Dichloroethene	1.0	U		0.25	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Carbon disulfide	5.0	U		0.15	5.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Acetone	5.0	U		1.4	5.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Methylene chloride	1.0	U		0.24	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	trans-1,2-Dichloroethene	1.0	U		0.29	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,1-Dichloroethane	1.0	U		0.15	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	2,2-Dichloropropane	1.0	U		0.17	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	cis-1,2-Dichloroethene	1.0	U		0.20	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	2-Butanone (MEK)	5.0	U		1.0	5.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Bromochloromethane	1.0	U		0.27	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Chloroform	1.0	U		0.14	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,1,1-Trichloroethane	1.0	U		0.17	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,1-Dichloropropene	1.0	U		0.38	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Carbon tetrachloride	1.0	U		0.34	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Benzene	1.0	U		0.23	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,2-Dichloroethane	1.0	U		0.25	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Trichloroethene	1.0	U		0.13	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,2-Dichloropropane	1.0	U		0.19	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Dibromomethane	1.0	U		0.21	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Bromodichloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	cis-1,3-Dichloropropene	1.0	U		0.15	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	4-Methyl-2-pentanone (MIBK)	5.0	U		0.92	5.0	1.00000	ug/L	175423		03/09/06 0601	mak

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: LEISTER-DAIRY
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 17:20
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-28
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	Toluene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	trans-1,3-Dichloropropene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,1,2-Trichloroethane	1.0	U		0.24	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Tetrachloroethene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,3-Dichloropropane	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	2-Hexanone	5.0	U		0.99	5.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Dibromochloromethane	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,2-Dibromoethane (EDB)	1.0	U		0.33	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Chlorobenzene	1.0	U		0.15	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,1,1,2-Tetrachloroethane	1.0	U		0.33	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Ethylbenzene	1.0	U		0.21	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	m&p-Xylenes	2.0	U		0.36	2.0	1.00000	ug/L	175423		03/09/06 0601	mak
	o-Xylene	1.0	U		0.19	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Styrene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Bromoform	1.0	U		0.32	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Isopropylbenzene	1.0	U		0.20	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Bromobenzene	1.0	U		0.22	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,1,2,2-Tetrachloroethane	1.0	U		0.34	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,2,3-Trichloropropane	1.0	U		0.35	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	n-Propylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	2-Chlorotoluene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,3,5-Trimethylbenzene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	4-Chlorotoluene	1.0	U		0.18	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	tert-Butylbenzene	1.0	U		0.16	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,2,4-Trimethylbenzene	1.0	U		0.26	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	sec-Butylbenzene	1.0	U		0.19	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,3-Dichlorobenzene	1.0	U		0.21	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	p-Isopropyltoluene	1.0	U		0.29	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,4-Dichlorobenzene	1.0	U		0.25	1.0	1.00000	ug/L	175423		03/09/06 0601	mak

* In Description = Dry Wgt.

STL Chicago is part of Severn Trent Laboratories, Inc.

LABORATORY TEST RESULTS

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Customer Sample ID: LEISTER-DAIRY
 Date Sampled.....: 02/27/2006
 Time Sampled.....: 17:20
 Sample Matrix.....: Water

Laboratory Sample ID: 244715-28
 Date Received.....: 03/02/2006
 Time Received.....: 10:10

TEST METHOD	PARAMETER/TEST DESCRIPTION	SAMPLE RESULT	Q	FLAGS	MDL	RL	DILUTION	UNITS	BATCH	DT	DATE/TIME	TECH
	n-Butylbenzene	1.0	U		0.35	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,2-Dichlorobenzene	1.0	U		0.29	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,2-Dibromo-3-chloropropane	1.0	U		0.41	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,2,4-Trichlorobenzene	1.0	U		0.36	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Hexachlorobutadiene	1.0	U		0.36	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	Naphthalene	1.0	U		0.37	1.0	1.00000	ug/L	175423		03/09/06 0601	mak
	1,2,3-Trichlorobenzene	1.0	U		0.43	1.0	1.00000	ug/L	175423		03/09/06 0601	mak

* In Description = Dry Wgt.

LABORATORY CHRONICLE

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Lab ID	Client ID	Date Recvd	Sample Date	Method	Description	Run#	Batch#	Prep BT	#(S)	Date/Time Analyzed	Dilution
244715-1	EW-2	03/02/2006	02/28/2006	5030B	5030 10 mL Purge Prep	1	175147			03/07/2006 1609	
				5030B	5030 10 mL Purge Prep	2	175147			03/07/2006 1544	
				EDD	Electronic Data Deliverable	1					
				8260B	Volatile Organics	1	175148	175147		03/07/2006 1544	1.00000
				8260B	Volatile Organics	1	175148	175147		03/07/2006 1609	10.0000
244715-2	EW-3	03/02/2006	02/28/2006	5030B	5030 10 mL Purge Prep	1	175147			03/07/2006 1658	
				5030B	5030 10 mL Purge Prep	2	175147			03/07/2006 1634	
				8260B	Volatile Organics	1	175148	175147		03/07/2006 1634	1.00000
				8260B	Volatile Organics	1	175148	175147		03/07/2006 1658	10.0000
244715-3	EW-4	03/02/2006	02/28/2006	5030B	5030 10 mL Purge Prep	1	175147			03/07/2006 1748	
				5030B	5030 10 mL Purge Prep	2	175147			03/07/2006 1723	
				8260B	Volatile Organics	1	175148	175147		03/07/2006 1723	5.00000
				8260B	Volatile Organics	1	175148	175147		03/07/2006 1748	50.0000
244715-4	EW-5	03/02/2006	02/28/2006	5030B	5030 10 mL Purge Prep	1	175147			03/07/2006 1837	
				5030B	5030 10 mL Purge Prep	2	175147			03/07/2006 1812	
				8260B	Volatile Organics	1	175148	175147		03/07/2006 1812	1.00000
				8260B	Volatile Organics	1	175148	175147		03/07/2006 1837	10.0000
244715-5	EW-6	03/02/2006	02/27/2006	5030B	5030 10 mL Purge Prep	1	175147			03/07/2006 1903	
				8260B	Volatile Organics	1	175148	175147		03/07/2006 1903	1.00000
244715-6	EW-7	03/02/2006	02/27/2006	5030B	5030 10 mL Purge Prep	1	175147			03/07/2006 1928	
				8260B	Volatile Organics	1	175148	175147		03/07/2006 1928	1.00000
244715-7	EW-8	03/02/2006	02/27/2006	5030B	5030 10 mL Purge Prep	1	175147			03/07/2006 2017	
				5030B	5030 10 mL Purge Prep	2	175147			03/07/2006 1952	
				8260B	Volatile Organics	1	175148	175147		03/07/2006 1952	1.00000
244715-8	EW-9	03/02/2006	02/27/2006	5030B	5030 10 mL Purge Prep	1	175551			03/08/2006 1333	
				5030B	5030 10 mL Purge Prep	2	175551			03/08/2006 1308	
				8260B	Volatile Organics	1	175552	175551		03/08/2006 1308	1.00000
				8260B	Volatile Organics	1	175552	175551		03/08/2006 1333	10.0000
244715-9	EW-9 DUP	03/02/2006	02/27/2006	5030B	5030 10 mL Purge Prep	1	175551			03/08/2006 1423	
				5030B	5030 10 mL Purge Prep	2	175551			03/08/2006 1358	
				8260B	Volatile Organics	1	175552	175551		03/08/2006 1358	1.00000

LABORATORY CHRONICLE

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Lab ID:	Client ID:	Date Recvd:	Sample Date:	Method:	Description:	Run#:	Batch#:	Prep BT #:	Prep BT (S):	Date/Time Analyzed:	Dilution:
244715-9	EW-9 DUP	03/02/2006	02/27/2006	8260B	Volatile Organics	1	175552	175551		03/08/2006 1423	10.0000
244715-10	EW-10	03/02/2006	02/27/2006	5030B 8260B	5030 10 mL Purge Prep Volatile Organics	1	175551	175551		03/08/2006 1447 03/08/2006 1447	1.00000
244715-11	RFW-1A	03/02/2006	02/27/2006	5030B 8260B	5030 10 mL Purge Prep Volatile Organics	1	175551	175551		03/08/2006 1512 03/08/2006 1512	1.00000
244715-12	RFW-1B	03/02/2006	02/28/2006	5030B 8260B	5030 10 mL Purge Prep Volatile Organics	1	175551	175551		03/08/2006 1537 03/08/2006 1537	1.00000
244715-13	RFW-2A	03/02/2006	02/27/2006	5030B 8260B	5030 10 mL Purge Prep Volatile Organics	1	175551	175551		03/08/2006 1601 03/08/2006 1601	1.00000
244715-14	RFW-2B	03/02/2006	02/27/2006	5030B 8260B	5030 10 mL Purge Prep Volatile Organics	1	175551	175551		03/08/2006 1626 03/08/2006 1626	1.00000
244715-15	RFW-3B	03/02/2006	02/28/2006	5030B 8260B	5030 10 mL Purge Prep Volatile Organics	1	175551	175551		03/08/2006 1651 03/08/2006 1651	1.00000
244715-16	RFW-4A	03/02/2006	02/28/2006	5030B 8260B	5030 10 mL Purge Prep Volatile Organics	1	175551	175551		03/08/2006 1716 03/08/2006 1716	1.00000
244715-17	RFW-4B	03/02/2006	02/28/2006	5030B 8260B	5030 10 mL Purge Prep Volatile Organics	1	175551	175551		03/08/2006 1741 03/08/2006 1741	1.00000
244715-18	RFW-4B DUP	03/02/2006	02/28/2006	5030B 8260B	5030 10 mL Purge Prep Volatile Organics	1	175551	175551		03/08/2006 1805 03/08/2006 1805	1.00000
244715-19	RFW-6	03/02/2006	02/28/2006	5030B 8260B	5030 10 mL Purge Prep Volatile Organics	1	175551	175551		03/08/2006 1830 03/08/2006 1830	1.00000
244715-20	RFW-7	03/02/2006	02/27/2006	5030B	5030 10 mL Purge Prep	1	175551			03/08/2006 1855	

LABORATORY CHRONICLE

Job Number: 244715

Date: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Lab ID:	Client ID:	Date Recvd:	Sample Date:			DILUTION
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED
8260B	Volatile Organics	1	175552	175551		03/08/2006 1855 1.00000
Lab ID: 244715-21	Client ID: RFW-9	Date Recvd: 03/02/2006	Sample Date: 02/28/2006			DILUTION
5030B	5030 10 mL Purge Prep	1	175551			03/08/2006 1919 1.00000
8260B	Volatile Organics	1	175552	175551		03/08/2006 1919 1.00000
Lab ID: 244715-22	Client ID: RFW-11B	Date Recvd: 03/02/2006	Sample Date: 02/28/2006			DILUTION
5030B	5030 10 mL Purge Prep	1	175551			03/08/2006 1944 1.00000
8260B	Volatile Organics	1	175552	175551		03/08/2006 1944 1.00000
Lab ID: 244715-23	Client ID: RFW-12B	Date Recvd: 03/02/2006	Sample Date: 02/28/2006			DILUTION
5030B	5030 10 mL Purge Prep	1	175551			03/08/2006 2034 1.00000
5030B	5030 10 mL Purge Prep	2	175551			03/08/2006 2009 1.00000
8260B	Volatile Organics	1	175552	175551		03/08/2006 2009 10.0000
8260B	Volatile Organics	1	175552	175551		03/08/2006 2034 10.0000
Lab ID: 244715-24	Client ID: RFW-13	Date Recvd: 03/02/2006	Sample Date: 02/27/2006			DILUTION
5030B	5030 10 mL Purge Prep	1	175551			03/08/2006 2058 1.00000
8260B	Volatile Organics	1	175552	175551		03/08/2006 2058 1.00000
Lab ID: 244715-25	Client ID: RFW-17	Date Recvd: 03/02/2006	Sample Date: 02/27/2006			DILUTION
5030B	5030 10 mL Purge Prep	1	175404			03/09/2006 0447 1.00000
8260B	Volatile Organics	1	175423	175404		03/09/2006 0447 1.00000
Lab ID: 244715-26	Client ID: TRIP BLANK	Date Recvd: 03/02/2006	Sample Date: 02/27/2006			DILUTION
5030B	5030 10 mL Purge Prep	1	175404			03/09/2006 0512 1.00000
8260B	Volatile Organics	1	175423	175404		03/09/2006 0512 1.00000
Lab ID: 244715-27	Client ID: LEISTER-1	Date Recvd: 03/02/2006	Sample Date: 02/27/2006			DILUTION
5030B	5030 10 mL Purge Prep	1	175404			03/09/2006 0536 1.00000
8260B	Volatile Organics	1	175423	175404		03/09/2006 0536 1.00000
Lab ID: 244715-28	Client ID: LEISTER-DAIRY	Date Recvd: 03/02/2006	Sample Date: 02/27/2006			DILUTION
5030B	5030 10 mL Purge Prep	1	175404			03/09/2006 0601 1.00000
8260B	Volatile Organics	1	175423	175404		03/09/2006 0601 1.00000

STL Chicago is part of Severn Trent Laboratories, Inc.

SURROGATE RECOVERIES REPORT

Job Number.: 244715

Report Date.: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

Method.....: Volatile Organics
Method Code...: 8260B

Test Matrix...: Water
Batch(s).....: 175148

Prep Batch...: 175147

Lab ID	DT	Sample ID	Date	12DCED	BRFLBE	DBRFLM	TOLD8
LCS			03/07/2006	87	111	103	110
MB			03/07/2006	87	105	97	108
244715- 1		EW-2	03/07/2006	90	104	102	108
244715- 1	D1	EW-2	03/07/2006	86	104	100	106
244715- 2		EW-3	03/07/2006	90	105	104	107
244715- 2	D1	EW-3	03/07/2006	85	106	99	107
244715- 3		EW-4	03/07/2006	85	105	97	109
244715- 3	D1	EW-4	03/07/2006	88	101	101	107
244715- 4		EW-5	03/07/2006	95	105	104	108
244715- 4	D1	EW-5	03/07/2006	87	103	100	109
244715- 5		EW-6	03/07/2006	93	103	103	108
244715- 6		EW-7	03/07/2006	93	103	103	107
244715- 7		EW-8	03/07/2006	94	104	105	108

Test	Test Description	Limits
12DCED	1,2-Dichloroethane-d4 (surr)	62 - 127
BRFLBE	4-Bromofluorobenzene (surr)	67 - 132
DBRFLM	Dibromofluoromethane (surr)	77 - 119
TOLD8	Toluene-d8 (surr)	81 - 126

Method.....: Volatile Organics
Method Code...: 8260B

Test Matrix...: Water
Batch(s).....: 175423

Prep Batch...: 175404

Lab ID	DT	Sample ID	Date	12DCED	BRFLBE	DBRFLM	TOLD8
LCS			03/08/2006	100	114	116	110
MB			03/08/2006	103	99	111	107
244715- 25		RFW-17	03/09/2006	98	107	109	111
244715- 26		TRIP BLANK	03/09/2006	93	108	111	109
244715- 27		LEISTER-1	03/09/2006	95	107	111	110
244715- 28		LEISTER-DAIRY	03/09/2006	97	107	111	110

Test	Test Description	Limits
12DCED	1,2-Dichloroethane-d4 (surr)	62 - 127
BRFLBE	4-Bromofluorobenzene (surr)	67 - 132
DBRFLM	Dibromofluoromethane (surr)	77 - 119
TOLD8	Toluene-d8 (surr)	81 - 126

Method.....: Volatile Organics
Method Code...: 8260B

Test Matrix...: Water
Batch(s).....: 175552

Prep Batch...: 175551

Lab ID	DT	Sample ID	Date	12DCED	BRFLBE	DBRFLM	TOLD8
LCS			03/08/2006	96	111	115	110
MB			03/08/2006	99	104	105	107
244715- 8		EW-9	03/08/2006	100	103	106	107
244715- 8	D1	EW-9	03/08/2006	95	104	106	108
244715- 9		EW-9 DUP	03/08/2006	100	100	110	108
244715- 9	D1	EW-9 DUP	03/08/2006	98	100	108	107
244715- 10		EW-10	03/08/2006	102	103	111	108
244715- 11		RFW-1A	03/08/2006	102	105	111	108

STL Chicago is part of Severn Trent Laboratories, Inc.

Job Number.: 244715	SURROGATE RECOVERIES REPORT	Report Date.: 03/15/2006
CUSTOMER: Weston Solutions, Inc.	PROJECT: BLACK AND DECKER	ATTN: Tom Cornuet

Method.....: Volatile Organics	Test Matrix...: Water	Prep Batch...: 175551
Method Code...: 8260B	Batch(s).....: 175552	

Lab ID	DT	Sample ID	Date	12DCED	BRFLBE	DBRFLM	TOLD8
244715- 12		RFW-1B	03/08/2006	113	101	115	109
244715- 13		RFW-2A	03/08/2006	103	102	110	107
244715- 14		RFW-2B	03/08/2006	103	101	112	109
244715- 15		RFW-3B	03/08/2006	103	102	113	107
244715- 16		RFW-4A	03/08/2006	106	101	116	109
244715- 17		RFW-4B	03/08/2006	105	101	114	108
244715- 18		RFW-4B DUP	03/08/2006	107	101	115	108
244715- 19		RFW-6	03/08/2006	106	99	116	110
244715- 20		RFW-7	03/08/2006	109	100	118	109
244715- 21		RFW-9	03/08/2006	106	100	115	109
244715- 22		RFW-11B	03/08/2006	104	102	115	107
244715- 23		RFW-12B	03/08/2006	104	99	115	109
244715- 23	D1	RFW-12B	03/08/2006	101	101	113	109
244715- 24		RFW-13	03/08/2006	106	100	116	110

Test	Test Description	Limits
12DCED	1,2-Dichloroethane-d4 (surr)	62 - 127
BRFLBE	4-Bromofluorobenzene (surr)	67 - 132
DBRFLM	Dibromofluoromethane (surr)	77 - 119
TOLD8	Toluene-d8 (surr)	81 - 126

QUALITY CONTROL RESULTS

Job Number.: 244715

Report Date.: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

Test Method.....: 8260B

Equipment Code....: GCL16

Analyst....: jdn

Method Description.: Volatile Organics

Batch.....: 175148

LCS	Laboratory Control Sample	V06C07DSA	175147-002		03/07/2006	0958
-----	---------------------------	-----------	------------	--	------------	------

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	*	Limits	F
Dichlorodifluoromethane	ug/L	23.295		25.000	1.000	U 93	%	24-171	
Chloromethane	ug/L	25.079		25.000	1.000	U 100	%	31-182	
Vinyl chloride	ug/L	26.260		25.000	1.000	U 105	%	52-134	
Bromomethane	ug/L	33.853		25.000	1.000	U 135	%	31-188	
Chloroethane	ug/L	24.050		25.000	1.000	U 96	%	58-148	
Trichlorofluoromethane	ug/L	20.821		25.000	1.000	U 83	%	54-142	
1,1-Dichloroethane	ug/L	25.958		25.000	1.000	U 104	%	51-136	
Carbon disulfide	ug/L	21.484		25.000	5.000	U 86	%	21-111	
Acetone	ug/L	25.721		25.000	5.000	U 103	%	14-177	
Methylene chloride	ug/L	24.673		25.000	1.000	U 99	%	64-127	
trans-1,2-Dichloroethene	ug/L	25.338		25.000	1.000	U 101	%	62-138	
1,1-Dichloroethane	ug/L	26.157		25.000	1.000	U 105	%	70-124	
2,2-Dichloropropane	ug/L	29.152		25.000	1.000	U 117	%	68-127	
cis-1,2-Dichloroethene	ug/L	25.837		25.000	1.000	U 103	%	76-125	
2-Butanone (MEK)	ug/L	21.707		25.000	5.000	U 87	%	29-139	
Bromochloromethane	ug/L	23.881		25.000	1.000	U 96	%	57-116	
Chloroform	ug/L	23.730		25.000	1.000	U 95	%	75-122	
1,1,1-Trichloroethane	ug/L	27.304		25.000	1.000	U 109	%	70-127	
1,1-Dichloropropene	ug/L	26.484		25.000	1.000	U 106	%	70-125	
Carbon tetrachloride	ug/L	26.920		25.000	1.000	U 108	%	64-132	
Benzene	ug/L	26.354		25.000	1.000	U 105	%	75-122	
1,2-Dichloroethane	ug/L	20.670		25.000	1.000	U 83	%	67-120	
Trichloroethene	ug/L	25.548		25.000	1.000	U 102	%	75-124	
1,2-Dichloropropane	ug/L	25.204		25.000	1.000	U 101	%	76-116	
Dibromomethane	ug/L	21.402		25.000	1.000	U 86	%	68-116	
Bromodichloromethane	ug/L	22.370		25.000	1.000	U 89	%	75-125	
cis-1,3-Dichloropropene	ug/L	21.738		26.000	1.000	U 84	%	72-115	
4-Methyl-2-pentanone (MIBK)	ug/L	19.543		25.000	5.000	U 78	%	39-137	
Toluene	ug/L	26.327		25.000	1.000	U 105	%	77-120	
trans-1,3-Dichloropropene	ug/L	19.351		24.000	1.000	U 81	%	68-119	
1,1,2-Trichloroethane	ug/L	22.197		25.000	1.000	U 89	%	63-127	
Tetrachloroethene	ug/L	25.295		25.000	1.000	U 101	%	70-125	
1,3-Dichloropropane	ug/L	24.406		25.000	1.000	U 98	%	72-118	
2-Hexanone	ug/L	21.077		25.000	5.000	U 84	%	36-144	
Dibromochloromethane	ug/L	22.188		25.000	1.000	U 89	%	73-116	
1,2-Dibromoethane (EDB)	ug/L	20.175		25.000	1.000	U 81	%	62-123	
Chlorobenzene	ug/L	25.854		25.000	1.000	U 103	%	76-116	
1,1,1,2-Tetrachloroethane	ug/L	23.256		25.000	1.000	U 93	%	77-120	
Ethylbenzene	ug/L	28.104		25.000	1.000	U 112	%	75-125	
m&p-Xylenes	ug/L	55.503		50.000	2.000	U 111	%	75-123	
o-Xylene	ug/L	27.404		25.000	1.000	U 110	%	76-121	
Styrene	ug/L	28.133		25.000	1.000	U 113	%	77-128	
Bromoform	ug/L	20.420		25.000	1.000	U 82	%	65-115	
Isopropylbenzene	ug/L	25.535		25.000	1.000	U 102	%	64-119	
Bromobenzene	ug/L	24.368		25.000	1.000	U 97	%	76-118	
1,1,2,2-Tetrachloroethane	ug/L	24.358		25.000	1.000	U 97	%	61-122	
1,2,3-Trichloropropane	ug/L	22.196		25.000	1.000	U 89	%	62-124	
n-Propylbenzene	ug/L	29.566		25.000	1.000	U 118	%	69-132	
2-Chlorotoluene	ug/L	26.920		25.000	1.000	U 108	%	70-127	
1,3,5-Trimethylbenzene	ug/L	27.613		25.000	1.000	U 110	%	70-132	

Job Number.: 244715

QUALITY CONTROL RESULTS

Report Date.: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
LCS	Laboratory Control Sample	V06C07DSA	175147-002		03/07/2006	0958

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits	F
4-Chlorotoluene	ug/L	26.984		25.000	1.000	U 108	% 70-126	
tert-Butylbenzene	ug/L	27.572		25.000	1.000	U 110	% 70-133	
1,2,4-Trimethylbenzene	ug/L	27.301		25.000	1.000	U 109	% 71-131	
sec-Butylbenzene	ug/L	29.506		25.000	1.000	U 118	% 70-134	
1,3-Dichlorobenzene	ug/L	25.244		25.000	1.000	U 101	% 71-120	
p-Isopropyltoluene	ug/L	27.373		25.000	1.000	U 109	% 66-130	
1,4-Dichlorobenzene	ug/L	24.634		25.000	1.000	U 99	% 70-118	
n-Butylbenzene	ug/L	30.071		25.000	1.000	U 120	% 64-142	
1,2-Dichlorobenzene	ug/L	24.642		25.000	1.000	U 99	% 72-118	
1,2-Dibromo-3-chloropropane	ug/L	21.133		25.000	1.000	U 85	% 57-119	
1,2,4-Trichlorobenzene	ug/L	23.102		25.000	1.000	U 92	% 60-132	
Hexachlorobutadiene	ug/L	24.705		25.000	1.000	U 99	% 63-145	
Naphthalene	ug/L	22.080		25.000	1.000	U 88	% 57-128	
1,2,3-Trichlorobenzene	ug/L	22.582		25.000	1.000	U 90	% 66-124	

QUALITY CONTROL RESULTS

Job Number.: 244715

Report Date.: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

Test Method.....: 8260B

Equipment Code....: GCL16

Analyst....: jdn

Method Description.: Volatile Organics

Batch.....: 175148

MB	Method Blank		175147-001		03/07/2006	0933
----	--------------	--	------------	--	------------	------

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits	F
Dichlorodifluoromethane	ug/L	1.000	U					
Chloromethane	ug/L	1.000	U					
Vinyl chloride	ug/L	1.000	U					
Bromomethane	ug/L	1.000	U					
Chloroethane	ug/L	1.000	U					
Trichlorofluoromethane	ug/L	1.000	U					
1,1-Dichloroethene	ug/L	1.000	U					
Carbon disulfide	ug/L	5.000	U					
Acetone	ug/L	5.000	U					
Methylene chloride	ug/L	1.000	U					
trans-1,2-Dichloroethene	ug/L	1.000	U					
1,1-Dichloroethane	ug/L	1.000	U					
2,2-Dichloropropane	ug/L	1.000	U					
cis-1,2-Dichloroethene	ug/L	1.000	U					
2-Butanone (MEK)	ug/L	5.000	U					
Bromochloromethane	ug/L	1.000	U					
Chloroform	ug/L	1.000	U					
1,1,1-Trichloroethane	ug/L	1.000	U					
1,1-Dichloropropene	ug/L	1.000	U					
Carbon tetrachloride	ug/L	1.000	U					
Benzene	ug/L	1.000	U					
1,2-Dichloroethane	ug/L	1.000	U					
Trichloroethene	ug/L	1.000	U					
1,2-Dichloropropane	ug/L	1.000	U					
Dibromomethane	ug/L	1.000	U					
Bromodichloromethane	ug/L	1.000	U					
cis-1,3-Dichloropropene	ug/L	1.000	U					
4-Methyl-2-pentanone (MIBK)	ug/L	5.000	U					
Toluene	ug/L	1.000	U					
trans-1,3-Dichloropropene	ug/L	1.000	U					
1,1,2-Trichloroethane	ug/L	1.000	U					
Tetrachloroethene	ug/L	1.000	U					
1,3-Dichloropropane	ug/L	1.000	U					
2-Hexanone	ug/L	5.000	U					
Dibromochloromethane	ug/L	1.000	U					
1,2-Dibromoethane (EDB)	ug/L	1.000	U					
Chlorobenzene	ug/L	1.000	U					
1,1,1,2-Tetrachloroethane	ug/L	1.000	U					
Ethylbenzene	ug/L	1.000	U					
m&p-Xylenes	ug/L	2.000	U					
o-Xylene	ug/L	1.000	U					
Styrene	ug/L	1.000	U					
Bromoform	ug/L	1.000	U					
Isopropylbenzene	ug/L	1.000	U					
Bromobenzene	ug/L	1.000	U					
1,1,2,2-Tetrachloroethane	ug/L	1.000	U					
1,2,3-Trichloropropane	ug/L	1.000	U					
n-Propylbenzene	ug/L	1.000	U					
2-Chlorotoluene	ug/L	1.000	U					
1,3,5-Trimethylbenzene	ug/L	1.000	U					

Job Number.: 244715

QUALITY CONTROL RESULTS

Report Date.: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
MB	Method Blank		175147-001		03/07/2006	0933

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits	F
4-Chlorotoluene	ug/L	1.000	U					
tert-Butylbenzene	ug/L	1.000	U					
1,2,4-Trimethylbenzene	ug/L	1.000	U					
sec-Butylbenzene	ug/L	1.000	U					
1,3-Dichlorobenzene	ug/L	1.000	U					
p-Isopropyltoluene	ug/L	1.000	U					
1,4-Dichlorobenzene	ug/L	1.000	U					
n-Butylbenzene	ug/L	1.000	U					
1,2-Dichlorobenzene	ug/L	1.000	U					
1,2-Dibromo-3-chloropropane	ug/L	1.000	U					
1,2,4-Trichlorobenzene	ug/L	1.000	U					
Hexachlorobutadiene	ug/L	1.000	U					
Naphthalene	ug/L	1.000	U					
1,2,3-Trichlorobenzene	ug/L	1.000	U					

QUALITY CONTROL RESULTS

Job Number.: 244715

Report Date.: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

Test Method.....: 8260B

Equipment Code.....: GCL16

Analyst....: mak

Method Description.: Volatile Organics

Batch.....: 175423

LCS	Laboratory Control Sample	V06C08DSA	175404-002		03/08/2006	2351
-----	---------------------------	-----------	------------	--	------------	------

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	*	Limits	F
Dichlorodifluoromethane	ug/L	26.560		25.000	1.000	U 106	%	24-171	
Chloromethane	ug/L	28.167		25.000	1.000	U 113	%	31-182	
Vinyl chloride	ug/L	29.053		25.000	1.000	U 116	%	52-134	
Bromomethane	ug/L	25.846		25.000	1.000	U 103	%	31-188	
Chloroethane	ug/L	24.009		25.000	1.000	U 96	%	58-148	
Trichlorofluoromethane	ug/L	26.607		25.000	1.000	U 106	%	54-142	
1,1-Dichloroethene	ug/L	25.086		25.000	1.000	U 100	%	51-136	
Carbon disulfide	ug/L	20.191		25.000	5.000	U 81	%	21-111	
Acetone	ug/L	24.767		25.000	5.000	U 99	%	14-177	
Methylene chloride	ug/L	25.776		25.000	1.000	U 103	%	64-127	
trans-1,2-Dichloroethene	ug/L	25.600		25.000	1.000	U 102	%	62-138	
1,1-Dichloroethane	ug/L	27.532		25.000	1.000	U 110	%	70-124	
2,2-Dichloropropane	ug/L	26.382		25.000	1.000	U 106	%	68-127	
cis-1,2-Dichloroethene	ug/L	26.390		25.000	1.000	U 106	%	76-125	
2-Butanone (MEK)	ug/L	22.121		25.000	5.000	U 88	%	29-139	
Bromochloromethane	ug/L	25.430		25.000	1.000	U 102	%	57-116	
Chloroform	ug/L	26.152		25.000	1.000	U 105	%	75-122	
1,1,1-Trichloroethane	ug/L	27.375		25.000	1.000	U 109	%	70-127	
1,1-Dichloropropene	ug/L	26.071		25.000	1.000	U 104	%	70-125	
Carbon tetrachloride	ug/L	25.925		25.000	1.000	U 104	%	64-132	
Benzene	ug/L	25.703		25.000	1.000	U 103	%	75-122	
1,2-Dichloroethane	ug/L	22.994		25.000	1.000	U 92	%	67-120	
Trichloroethene	ug/L	24.509		25.000	1.000	U 98	%	75-124	
1,2-Dichloropropane	ug/L	24.483		25.000	1.000	U 98	%	76-116	
Dibromomethane	ug/L	23.282		25.000	1.000	U 93	%	68-116	
Bromodichloromethane	ug/L	21.976		25.000	1.000	U 88	%	75-125	
cis-1,3-Dichloropropene	ug/L	19.330		26.000	1.000	U 74	%	72-115	
4-Methyl-2-pentanone (MIBK)	ug/L	20.346		25.000	5.000	U 81	%	39-137	
Toluene	ug/L	25.576		25.000	1.000	U 102	%	77-120	
trans-1,3-Dichloropropene	ug/L	17.950		24.000	1.000	U 75	%	68-119	
1,1,2-Trichloroethane	ug/L	23.645		25.000	1.000	U 95	%	63-127	
Tetrachloroethene	ug/L	24.951		25.000	1.000	U 100	%	70-125	
1,3-Dichloropropane	ug/L	25.530		25.000	1.000	U 102	%	72-118	
2-Hexanone	ug/L	19.807		25.000	5.000	U 79	%	36-144	
Dibromochloromethane	ug/L	20.977		25.000	1.000	U 84	%	73-116	
1,2-Dibromoethane (EDB)	ug/L	21.178		25.000	1.000	U 85	%	62-123	
Chlorobenzene	ug/L	25.557		25.000	1.000	U 102	%	76-116	
1,1,1,2-Tetrachloroethane	ug/L	21.865		25.000	1.000	U 87	%	77-120	
Ethylbenzene	ug/L	26.966		25.000	1.000	U 108	%	75-125	
m&p-Xylenes	ug/L	53.998		50.000	2.000	U 108	%	75-123	
o-Xylene	ug/L	26.581		25.000	1.000	U 106	%	76-121	
Styrene	ug/L	27.664		25.000	1.000	U 111	%	77-128	
Bromoform	ug/L	19.952		25.000	1.000	U 80	%	65-115	
Isopropylbenzene	ug/L	22.747		25.000	1.000	U 91	%	64-119	
Bromobenzene	ug/L	23.092		25.000	1.000	U 92	%	76-118	
1,1,2,2-Tetrachloroethane	ug/L	25.231		25.000	1.000	U 101	%	61-122	
1,2,3-Trichloropropane	ug/L	22.222		25.000	1.000	U 89	%	62-124	
n-Propylbenzene	ug/L	27.047		25.000	1.000	U 108	%	69-132	
2-Chlorotoluene	ug/L	25.689		25.000	1.000	U 103	%	70-127	
1,3,5-Trimethylbenzene	ug/L	25.643		25.000	1.000	U 103	%	70-132	

Job Number.: 244715

QUALITY CONTROL RESULTS

Report Date.: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

LCS	Laboratory Control Sample	VO6c08DSA	175404-002		03/08/2006	2351
-----	---------------------------	-----------	------------	--	------------	------

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	*	Limits	F
4-Chlorotoluene	ug/L	25.182		25.000	1.000	U 101	%	70-126	
tert-Butylbenzene	ug/L	24.976		25.000	1.000	U 100	%	70-133	
1,2,4-Trimethylbenzene	ug/L	25.752		25.000	1.000	U 103	%	71-131	
sec-Butylbenzene	ug/L	26.741		25.000	1.000	U 107	%	70-134	
1,3-Dichlorobenzene	ug/L	24.219		25.000	1.000	U 97	%	71-120	
p-Isopropyltoluene	ug/L	25.069		25.000	1.000	U 100	%	66-130	
1,4-Dichlorobenzene	ug/L	23.733		25.000	1.000	U 95	%	70-118	
n-Butylbenzene	ug/L	27.381		25.000	1.000	U 110	%	64-142	
1,2-Dichlorobenzene	ug/L	23.903		25.000	1.000	U 96	%	72-118	
1,2-Dibromo-3-chloropropane	ug/L	19.379		25.000	1.000	U 78	%	57-119	
1,2,4-Trichlorobenzene	ug/L	22.397		25.000	1.000	U 90	%	60-132	
Hexachlorobutadiene	ug/L	23.244		25.000	1.000	U 93	%	63-145	
Naphthalene	ug/L	22.435		25.000	1.000	U 90	%	57-128	
1,2,3-Trichlorobenzene	ug/L	22.745		25.000	1.000	U 91	%	66-124	

QUALITY CONTROL RESULTS

Job Number.: 244715

Report Date.: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

Test Method.....: 8260B

Equipment Code....: GCL16

Analyst....: mak

Method Description.: Volatile Organics

Batch.....: 175423

MB	Method Blank		175404-001		03/08/2006	2326
----	--------------	--	------------	--	------------	------

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits	F
Dichlorodifluoromethane	ug/L	1.000	U					
Chloromethane	ug/L	1.000	U					
Vinyl chloride	ug/L	1.000	U					
Bromomethane	ug/L	1.000	U					
Chloroethane	ug/L	1.000	U					
Trichlorofluoromethane	ug/L	1.000	U					
1,1-Dichloroethene	ug/L	1.000	U					
Carbon disulfide	ug/L	5.000	U					
Acetone	ug/L	5.000	U					
Methylene chloride	ug/L	1.000	U					
trans-1,2-Dichloroethene	ug/L	1.000	U					
1,1-Dichloroethane	ug/L	1.000	U					
2,2-Dichloropropane	ug/L	1.000	U					
cis-1,2-Dichloroethene	ug/L	1.000	U					
2-Butanone (MEK)	ug/L	5.000	U					
Bromochloromethane	ug/L	1.000	U					
Chloroform	ug/L	1.000	U					
1,1,1-Trichloroethane	ug/L	1.000	U					
1,1-Dichloropropene	ug/L	1.000	U					
Carbon tetrachloride	ug/L	1.000	U					
Benzene	ug/L	1.000	U					
1,2-Dichloroethane	ug/L	1.000	U					
Trichloroethene	ug/L	1.000	U					
1,2-Dichloropropane	ug/L	1.000	U					
Dibromomethane	ug/L	1.000	U					
Bromodichloromethane	ug/L	1.000	U					
cis-1,3-Dichloropropene	ug/L	1.000	U					
4-Methyl-2-pentanone (MIBK)	ug/L	5.000	U					
Toluene	ug/L	1.000	U					
trans-1,3-Dichloropropene	ug/L	1.000	U					
1,1,2-Trichloroethane	ug/L	1.000	U					
Tetrachloroethene	ug/L	1.000	U					
1,3-Dichloropropane	ug/L	1.000	U					
2-Hexanone	ug/L	5.000	U					
Dibromochloromethane	ug/L	1.000	U					
1,2-Dibromoethane (EDB)	ug/L	1.000	U					
Chlorobenzene	ug/L	1.000	U					
1,1,1,2-Tetrachloroethane	ug/L	1.000	U					
Ethylbenzene	ug/L	1.000	U					
m&p-Xylenes	ug/L	2.000	U					
o-Xylene	ug/L	1.000	U					
Styrene	ug/L	1.000	U					
Bromoform	ug/L	1.000	U					
Isopropylbenzene	ug/L	1.000	U					
Bromobenzene	ug/L	1.000	U					
1,1,2,2-Tetrachloroethane	ug/L	1.000	U					
1,2,3-Trichloropropane	ug/L	1.000	U					
n-Propylbenzene	ug/L	1.000	U					
2-Chlorotoluene	ug/L	1.000	U					
1,3,5-Trimethylbenzene	ug/L	1.000	U					

Job Number.: 244715

QUALITY CONTROL RESULTS

Report Date.: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
MB	Method Blank		175404-001		03/08/2006	2326

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits	F
4-Chlorotoluene	ug/L	1.000	U					
tert-Butylbenzene	ug/L	1.000	U					
1,2,4-Trimethylbenzene	ug/L	1.000	U					
sec-Butylbenzene	ug/L	1.000	U					
1,3-Dichlorobenzene	ug/L	1.000	U					
p-Isopropyltoluene	ug/L	1.000	U					
1,4-Dichlorobenzene	ug/L	1.000	U					
n-Butylbenzene	ug/L	1.000	U					
1,2-Dichlorobenzene	ug/L	1.000	U					
1,2-Dibromo-3-chloropropane	ug/L	1.000	U					
1,2,4-Trichlorobenzene	ug/L	1.000	U					
Hexachlorobutadiene	ug/L	1.000	U					
Naphthalene	ug/L	1.000	U					
1,2,3-Trichlorobenzene	ug/L	1.000	U					

QUALITY CONTROL RESULTS

Job Number.: 244715

Report Date.: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

Test Method.....: 8260B

Equipment Code....: GCL16

Analyst....: jdn

Method Description.: Volatile Organics

Batch.....: 175552

LCS	Laboratory Control Sample	VO6C08DSA	175551-002	03/08/2006	1129
-----	---------------------------	-----------	------------	------------	------

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	*	Limits	F
Dichlorodifluoromethane	ug/L	25.235		25.000	1.000	U 101	%	24-171	
Chloromethane	ug/L	26.979		25.000	1.000	U 108	%	31-182	
Vinyl chloride	ug/L	28.321		25.000	1.000	U 113	%	52-134	
Bromomethane	ug/L	25.872		25.000	1.000	U 103	%	31-188	
Chloroethane	ug/L	22.440		25.000	1.000	U 90	%	58-148	
Trichlorofluoromethane	ug/L	23.376		25.000	1.000	U 94	%	54-142	
1,1-Dichloroethene	ug/L	26.796		25.000	1.000	U 107	%	51-136	
Carbon disulfide	ug/L	21.079		25.000	5.000	U 84	%	21-111	
Acetone	ug/L	33.254		25.000	5.000	U 133	%	14-177	
Methylene chloride	ug/L	26.644		25.000	1.000	U 107	%	64-127	
trans-1,2-Dichloroethene	ug/L	26.502		25.000	1.000	U 106	%	62-138	
1,1-Dichloroethane	ug/L	22.590		25.000	1.000	U 90	%	70-124	
2,2-Dichloropropane	ug/L	29.082		25.000	1.000	U 116	%	68-127	
cis-1,2-Dichloroethene	ug/L	27.392		25.000	1.000	U 110	%	76-125	
2-Butanone (MEK)	ug/L	24.699		25.000	5.000	U 99	%	29-139	
Bromochloromethane	ug/L	25.928		25.000	1.000	U 104	%	57-116	
Chloroform	ug/L	26.661		25.000	1.000	U 107	%	75-122	
1,1,1-Trichloroethane	ug/L	27.702		25.000	1.000	U 111	%	70-127	
1,1-Dichloropropene	ug/L	26.765		25.000	1.000	U 107	%	70-125	
Carbon tetrachloride	ug/L	25.711		25.000	1.000	U 103	%	64-132	
Benzene	ug/L	27.049		25.000	1.000	U 108	%	75-122	
1,2-Dichloroethane	ug/L	22.847		25.000	1.000	U 91	%	67-120	
Trichloroethene	ug/L	25.397		25.000	1.000	U 102	%	75-124	
1,2-Dichloropropane	ug/L	25.790		25.000	1.000	U 103	%	76-116	
Dibromomethane	ug/L	23.359		25.000	1.000	U 93	%	68-116	
Bromodichloromethane	ug/L	22.354		25.000	1.000	U 89	%	75-125	
cis-1,3-Dichloropropene	ug/L	21.457		26.000	1.000	U 83	%	72-115	
4-Methyl-2-pentanone (MIBK)	ug/L	20.041		25.000	5.000	U 80	%	39-137	
Toluene	ug/L	26.734		25.000	1.000	U 107	%	77-120	
trans-1,3-Dichloropropene	ug/L	19.013		24.000	1.000	U 79	%	68-119	
1,1,2-Trichloroethane	ug/L	23.799		25.000	1.000	U 95	%	63-127	
Tetrachloroethene	ug/L	25.737		25.000	1.000	U 103	%	70-125	
1,3-Dichloropropane	ug/L	25.229		25.000	1.000	U 101	%	72-118	
2-Hexanone	ug/L	21.406		25.000	5.000	U 86	%	36-144	
Dibromochloromethane	ug/L	21.352		25.000	1.000	U 85	%	73-116	
1,2-Dibromoethane (EDB)	ug/L	21.254		25.000	1.000	U 85	%	62-123	
Chlorobenzene	ug/L	26.239		25.000	1.000	U 105	%	76-116	
1,1,1,2-Tetrachloroethane	ug/L	22.625		25.000	1.000	U 90	%	77-120	
Ethylbenzene	ug/L	28.035		25.000	1.000	U 112	%	75-125	
m&p-Xylenes	ug/L	56.469		50.000	2.000	U 113	%	75-123	
o-Xylene	ug/L	27.450		25.000	1.000	U 110	%	76-121	
Styrene	ug/L	28.620		25.000	1.000	U 114	%	77-128	
Bromoform	ug/L	19.466		25.000	1.000	U 78	%	65-115	
Isopropylbenzene	ug/L	23.977		25.000	1.000	U 96	%	64-119	
Bromobenzene	ug/L	23.963		25.000	1.000	U 96	%	76-118	
1,1,2,2-Tetrachloroethane	ug/L	25.464		25.000	1.000	U 102	%	61-122	
1,2,3-Trichloropropane	ug/L	23.105		25.000	1.000	U 92	%	62-124	
n-Propylbenzene	ug/L	28.359		25.000	1.000	U 113	%	69-132	
2-Chlorotoluene	ug/L	27.079		25.000	1.000	U 108	%	70-127	
1,3,5-Trimethylbenzene	ug/L	26.982		25.000	1.000	U 108	%	70-132	

Job Number.: 244715

QUALITY CONTROL RESULTS

Report Date.: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

LCS	Laboratory Control Sample	V06C08DSA	175551-002		03/08/2006	1129
-----	---------------------------	-----------	------------	--	------------	------

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits	F
4-Chlorotoluene	ug/L	26.687		25.000	1.000	U 107	% 70-126	
tert-Butylbenzene	ug/L	26.646		25.000	1.000	U 107	% 70-133	
1,2,4-Trimethylbenzene	ug/L	27.066		25.000	1.000	U 108	% 71-131	
sec-Butylbenzene	ug/L	28.165		25.000	1.000	U 113	% 70-134	
1,3-Dichlorobenzene	ug/L	25.245		25.000	1.000	U 101	% 71-120	
p-Isopropyltoluene	ug/L	26.591		25.000	1.000	U 106	% 66-130	
1,4-Dichlorobenzene	ug/L	24.491		25.000	1.000	U 98	% 70-118	
n-Butylbenzene	ug/L	29.449		25.000	1.000	U 118	% 64-142	
1,2-Dichlorobenzene	ug/L	24.870		25.000	1.000	U 99	% 72-118	
1,2-Dibromo-3-chloropropane	ug/L	20.149		25.000	1.000	U 81	% 57-119	
1,2,4-Trichlorobenzene	ug/L	24.068		25.000	1.000	U 96	% 60-132	
Hexachlorobutadiene	ug/L	24.883		25.000	1.000	U 100	% 63-145	
Naphthalene	ug/L	23.119		25.000	1.000	U 92	% 57-128	
1,2,3-Trichlorobenzene	ug/L	23.880		25.000	1.000	U 96	% 66-124	

Job Number.: 244715

QUALITY CONTROL RESULTS

Report Date.: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
---------	-------------	------------	--------	-----------------	------	------

Test Method.....: 8260B

Equipment Code.....: GCL16

Analyst....: jdn

Method Description.: Volatile Organics

Batch.....: 175552

MB	Method Blank		175551-001		03/08/2006	1104
----	--------------	--	------------	--	------------	------

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits	F
Dichlorodifluoromethane	ug/L	1.000	U					
Chloromethane	ug/L	1.000	U					
Vinyl chloride	ug/L	1.000	U					
Bromomethane	ug/L	1.000	U					
Chloroethane	ug/L	1.000	U					
Trichlorofluoromethane	ug/L	1.000	U					
1,1-Dichloroethene	ug/L	1.000	U					
Carbon disulfide	ug/L	5.000	U					
Acetone	ug/L	5.000	U					
Methylene chloride	ug/L	1.000	U					
trans-1,2-Dichloroethene	ug/L	1.000	U					
1,1-Dichloroethane	ug/L	1.000	U					
2,2-Dichloropropane	ug/L	1.000	U					
cis-1,2-Dichloroethene	ug/L	1.000	U					
2-Butanone (MEK)	ug/L	5.000	U					
Bromochloromethane	ug/L	1.000	U					
Chloroform	ug/L	1.000	U					
1,1,1-Trichloroethane	ug/L	1.000	U					
1,1-Dichloropropene	ug/L	1.000	U					
Carbon tetrachloride	ug/L	1.000	U					
Benzene	ug/L	1.000	U					
1,2-Dichloroethane	ug/L	1.000	U					
Trichloroethene	ug/L	1.000	U					
1,2-Dichloropropane	ug/L	1.000	U					
Dibromomethane	ug/L	1.000	U					
Bromodichloromethane	ug/L	1.000	U					
cis-1,3-Dichloropropene	ug/L	1.000	U					
4-Methyl-2-pentanone (MIBK)	ug/L	5.000	U					
Toluene	ug/L	1.000	U					
trans-1,3-Dichloropropene	ug/L	1.000	U					
1,1,2-Trichloroethane	ug/L	1.000	U					
Tetrachloroethene	ug/L	1.000	U					
1,3-Dichloropropane	ug/L	1.000	U					
2-Hexanone	ug/L	5.000	U					
Dibromochloromethane	ug/L	1.000	U					
1,2-Dibromoethane (EDB)	ug/L	1.000	U					
Chlorobenzene	ug/L	1.000	U					
1,1,1,2-Tetrachloroethane	ug/L	1.000	U					
Ethylbenzene	ug/L	1.000	U					
m&p-Xylenes	ug/L	2.000	U					
o-Xylene	ug/L	1.000	U					
Styrene	ug/L	1.000	U					
Bromoform	ug/L	1.000	U					
Isopropylbenzene	ug/L	1.000	U					
Bromobenzene	ug/L	1.000	U					
1,1,2,2-Tetrachloroethane	ug/L	1.000	U					
1,2,3-Trichloropropane	ug/L	1.000	U					
n-Propylbenzene	ug/L	1.000	U					
2-Chlorotoluene	ug/L	1.000	U					
1,3,5-Trimethylbenzene	ug/L	1.000	U					

Job Number.: 244715

QUALITY CONTROL RESULTS

Report Date.: 03/15/2006

CUSTOMER: Weston Solutions, Inc.

PROJECT: BLACK AND DECKER

ATTN: Tom Cornuet

QC Type	Description	Reag. Code	Lab ID	Dilution Factor	Date	Time
MB	Method Blank		175551-001		03/08/2006	1104

Parameter/Test Description	Units	QC Result	QC Result	True Value	Orig. Value	QC Calc.	* Limits	F
4-Chlorotoluene	ug/L	1.000	U					
tert-Butylbenzene	ug/L	1.000	U					
1,2,4-Trimethylbenzene	ug/L	1.000	U					
sec-Butylbenzene	ug/L	1.000	U					
1,3-Dichlorobenzene	ug/L	1.000	U					
p-Isopropyltoluene	ug/L	1.000	U					
1,4-Dichlorobenzene	ug/L	1.000	U					
n-Butylbenzene	ug/L	1.000	U					
1,2-Dichlorobenzene	ug/L	1.000	U					
1,2-Dibromo-3-chloropropane	ug/L	1.000	U					
1,2,4-Trichlorobenzene	ug/L	1.000	U					
Hexachlorobutadiene	ug/L	1.000	U					
Naphthalene	ug/L	1.000	U					
1,2,3-Trichlorobenzene	ug/L	1.000	U					

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

Report Date: 03/15/2006

REPORT COMMENTS

- 1) All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.
- 2) Soil, sediment and sludge sample results are reported on a "dry weight" basis except when analyzed for landfill disposal or incineration parameters. All other solid matrix samples are reported on an "as received" basis unless noted differently.
- 3) Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.
- 4) The test results for the noted analytical method(s) meet the requirements of NELAC. Lab Cert. ID# 100201
- 5) According to 40CFR Part 136.3, pH, Chlorine Residual and Dissolved Oxygen analyses are to be performed immediately after aqueous sample collection. When these parameters are not indicated as field (e.g. pH Field) they were not analyzed immediately, but as soon as possible on laboratory receipt.

Glossary of flags, qualifiers and abbreviations (any number of which may appear in the report)

Inorganic Qualifiers (Q-Column)

- U Analyte was not detected at or above the stated limit.
- < Not detected at or above the reporting limit.
- J Result is less than the RL, but greater than or equal to the method detection limit.
- B Result is less than the CRDL/RL, but greater than or equal to the IDL/MDL.
- S Result was determined by the Method of Standard Additions.
- F AFCEE: Result is less than the RL, but greater than or equal to the method detection limit.

Inorganic Flags (Flag Column)

- ICV,CCV,ICB,CCB,ISA,ISB,CRI,CRA,MRL: Instrument related QC exceed the upper or lower control limits.
- * LCS, LCD, MD: Batch QC exceeds the upper or lower control limits.
- + MSA correlation coefficient is less than 0.995.
- 4 MS, MSD: The analyte present in the original sample is 4 times greater than the matrix spike concentration; therefore, control limits are not applicable.
- E SD: Serial dilution exceeds the control limits.
- H MB, EB1, EB2, EB3: Batch QC is greater than reporting limit or had a negative instrument reading lower than the absolute value of the reporting limit.
- N MS, MSD: Spike recovery exceeds the upper or lower control limits.
- W AS(GFAA) Post-digestion spike was outside 85-115% control limits.

Organic Qualifiers (Q - Column)

- U Analyte was not detected at or above the stated limit.
- ND Compound not detected.
- J Result is an estimated value below the reporting limit or a tentatively identified compound (TIC).
- Q Result was qualitatively confirmed, but not quantified.
- C Pesticide identification was confirmed by GC/MS.
- Y The chromatographic response resembles a typical fuel pattern.
- Z The chromatographic response does not resemble a typical fuel pattern.
- E Result exceeded calibration range, secondary dilution required.
- F AFCEE:Result is an estimated value below the reporting limit or a tentatively identified compound (TIC)

Organic Flags (Flags Column)

- B MB: Batch QC is greater than reporting limit.
- * LCS, LCD, ELC, ELD, CV, MS, MSD, Surrogate: Batch QC exceeds the upper or lower control limits.
- EB1, EB2, EB3, MLE: Batch QC is greater than reporting Limit
- A Concentration exceeds the instrument calibration range
- a Concentration is below the method Reporting Limit (RL)
- B Compound was found in the blank and sample.
- D Surrogate or matrix spike recoveries were not obtained because the extract was diluted for analysis; also compounds analyzed at a dilution will be flagged with a D.
- H Alternate peak selection upon analytical review
- I Indicates the presence of an interference, recovery is not calculated.
- M Manually integrated compound.
- P The lower of the two values is reported when the % difference between the results of two GC columns is

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

Report Date: 03/15/2006

greater than 25%.

Abbreviations

AS	Post Digestion Spike (GFAA Samples - See Note 1 below)
Batch	Designation given to identify a specific extraction, digestion, preparation set, or analysis set
CAP	Capillary Column CCB Continuing Calibration Blank
CCV	Continuing Calibration Verification
CF	Confirmation analysis of original
C1	Confirmation analysis of A1 or D1
C2	Confirmation analysis of A2 or D2
C3	Confirmation analysis of A3 or D3
CRA	Low Level Standard Check - GFAA; Mercury
CRI	Low Level Standard Check - ICP
CV	Calibration Verification Standard
Dil Fac	Dilution Factor - Secondary dilution analysis
D1	Dilution 1
D2	Dilution 2
D3	Dilution 3
DLFac	Detection Limit Factor
DSH	Distilled Standard - High Level
DSL	Distilled Standard - Low Level
DSM	Distilled Standard - Medium Level
EB1	Extraction Blank 1
EB2	Extraction Blank 2
EB3	DI Blank
ELC	Method Extracted LCS
ELD	Method Extracted LCD
ICAL	Initial calibration
ICB	Initial Calibration Blank
ICV	Initial Calibration Verification
IDL	Instrument Detection Limit
ISA	Interference Check Sample A - ICAP
ISB	Interference Check Sample B - ICAP
Job No.	The first six digits of the sample ID which refers to a specific client, project and sample group Lab ID An 8 number unique laboratory identification
LCD	Laboratory Control Standard Duplicate
LCS	Laboratory Control Standard with reagent grade water or a matrix free from the analyte of interest
MB	Method Blank or (PB) Preparation Blank
MD	Method Duplicate
MDL	Method Detection Limit
MLE	Medium Level Extraction Blank
MRL	Method Reporting Limit Standard
MSA	Method of Standard Additions
MS	Matrix Spike
MSD	Matrix Spike Duplicate
ND	Not Detected
PREPF	Preparation factor used by the Laboratory's Information Management System (LIMS)
PDS	Post Digestion Spike (ICAP)
RA	Re-analysis of original
A1	Re-analysis of D1
A2	Re-analysis of D2
A3	Re-analysis of D3
RD	Re-extraction of dilution
RE	Re-extraction of original
RC	Re-extraction Confirmation
RL	Reporting Limit
RPD	Relative Percent Difference of duplicate (unrounded) analyses
RRF	Relative Response Factor
RT	Retention Time

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

Report Date: 03/15/2006

RTW Retention Time Window Sample ID A 9 digit number unique for each sample, the first six digits are referred as the job number
SCB Seeded Control Blank
SD Serial Dilution (Calculated when sample concentration exceeds 50 times the MDL)
UCB Unseeded Control Blank
SSV Second Source Verification Standard
SLCS Solid Laboratory Control Standard(LCS)
PHC pH Calibration Check LCSP pH Laboratory Control Sample
LCDP pH Laboratory Control Sample Duplicate
MDPH pH Sample Duplicate
MDFP Flashpoint Sample Duplicate
LCFP Flashpoint LCS
G1 Gelex Check Standard Range 0-1
G2 Gelex Check Standard Range 1-10
G3 Gelex Check Standard Range 10-100
G4 Gelex Check Standard Range 100-1000

Note 1: The Post Spike Designation on Batch QC for GFAA is designated with an "S" added to the current abbreviation used. EX. LCS S=LCS Post Spike (GFAA); MSS=MS Post Spike (GFAA)

Note 2: The MD calculates an absolute difference (A) when the sample concentration is less than 5 times the reporting limit. The control limit is represented as +/- the RL.

SEVERN TRENT STL

STL Chicago
2417 Bond Street
University Park, IL 60466
Phone: 708-534-5200
Fax: 708-534-5211

Report To:

Bill To:

Shaded Areas For Internal Use Only 1 of 3

Contact: Greg Flasiński
Company: Western
Address: 1401 Western Way
Wichster PA 19380
Phone: 610-701-7293
Fax: 610-701-7401
E-Mail:

Contact:
Company:
Address:
Phone:
Fax:
PO#: Quote:

Lab Lot#: 244715

Package Sealed <input checked="" type="radio"/> Yes <input type="radio"/> No	Samples Sealed <input checked="" type="radio"/> Yes <input type="radio"/> No
Received on Ice <input checked="" type="radio"/> Yes <input type="radio"/> No	Samples Intact <input checked="" type="radio"/> Yes <input type="radio"/> No
Temperature: C of Cooler <u>32</u>	
Within Hold Time <input checked="" type="radio"/> Yes <input type="radio"/> No	Preserv. Indicated <input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> NA
pH Check OK <input checked="" type="radio"/> Yes <input type="radio"/> No <input checked="" type="radio"/> NA	Res. Cl ₂ Check OK <input checked="" type="radio"/> Yes <input type="radio"/> No <input checked="" type="radio"/> NA
Sample Labels and COC Agree <input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> COC not present	

Sampler Name: Greg Flasiński
Project Name: Black + Decker
Project Location: Hampstead Md
Lab PM:

Signature: [Signature]
Project Number: 02501.004.004
Date Required:
Hard Copy:
Fax:

Refr.#	#/Cont	Volume	Preserv	Matrix	Comp/Grab
	<u>3/60</u>	<u>10ml</u>	<u>HCl</u>	<u>VOA</u>	<u>✓</u>

Laboratory ID	MS-MSD	Client Sample ID	Sampling Date	Time	Matrix	Comp/Grab
1		EW-2	2/28/06	945	W	✓
2		EW-3		1000		✓
3		EW-4		1210		✓
4		EW-5		1115		✓
5		EW-6	2/27/06	1335		✓
6		EW-7		1340		✓
7		EW-8		1345		✓
8		EW-9		1355		✓
9		EW-9 Dup		1355		✓
10		EW-10		1405		✓

Additional Analyses / Remarks

REINQUISHED BY: [Signature] COMPANY: Western DATE: 3/1/06 TIME: 1600

RECEIVED BY: [Signature] COMPANY: SR DATE: 3/2/06 TIME: 1010

- Matrix Key**
- WW = Wastewater
 - W = Water
 - S = Soil
 - SL = Sludge
 - MS = Miscellaneous
 - OL = Oil
 - A = Air
 - SE = Sediment
 - SO = Solid
 - DS = Drum Solid
 - DL = Drum Liquid
 - L = Leachate
 - WI = Wipe
 - O =

- Container Key**
- Plastic
 - VOA Vial
 - Sterile Plastic
 - Amber Glass
 - Widemouth Glass
 - Other

- Preservative Key**
- HCl, Cool to 4°
 - H2SO4, Cool to 4°
 - HNO3, Cool to 4°
 - NaOH, Cool to 4°
 - NaOH/Zn, Cool to 4°
 - Cool to 4°
 - None

COMMENTS

Date Received: 3, 2, 06
Courier: FR Hand Delivered
Bill of Lading: see attach

**SEVERN
TRENT** **STL**

STL Chicago
2417 Bond Street
University Park, IL 60466
Phone: 708-534-5200
Fax: 708-534-5211

Report To:

Contact: _____
Company: _____
Address: See Page 1
Phone: _____
Fax: _____
E-Mail: _____

Bill To:

Contact: _____
Company: _____
Address: _____
Phone: _____
Fax: _____
PO#: _____ Quote: _____

Shaded Areas For Internal Use Only 3 of 3

Lab Lot# 244715

Package Sealed Yes No	Samples Sealed Yes No
Received on Ice Yes No	Samples Intact Yes No
Temperature °C of Cooler	
Within Hold Time Yes No	Preserv. Indicated Yes No NA
pH Check OK Yes No NA	Res Cl ₂ Check OK Yes No NA
Sample Labels and COC Agree Yes No	COC not present

Sampler Name: Greg Flasihski Signature: [Signature]

Project Name: Black & Decker Project Number: 02501.004.004

Project Location: Hampstead MD Date Required: _____
Lab PM: _____ Hard Copy: _____
Fax: _____

Refrg #	#/Cont	Volume	Preserv
	<u>3</u>	<u>400ml</u>	<u>100</u>

Laboratory ID	MS-MSD	Client Sample ID	Sampling		Matrix	Comp/Grab	Additional Analyses / Remarks									
			Date	Time												
23		RFW-12B	2/28/06	850	W	✓										
24		RFW-13	2/27/06	1425		✓										
25		RFW-17	2/27/06	1045		✓										
26		Trip Blank	2/27/06	800		✓										
27		Leister-1	2/27/06	1715		✓										
28		Leister-Dairy	2/27/06	1730		✓										

RELINQUISHED BY: [Signature] COMPANY: Western DATE: 3/1/06 TIME: 1600

RECEIVED BY: [Signature] COMPANY: STL DATE: 3/2/06 TIME: 1010

- Matrix Key**
- WW = Wastewater
 - W = Water
 - S = Soil
 - SL = Sludge
 - MS = Miscellaneous
 - OL = Oil
 - A = Air
 - SE = Sediment
 - SO = Solid
 - DS = Drum Solid
 - DL = Drum Liquid
 - L = Leachate
 - WI = Wipe
 - O =

- Container Key**
- Plastic
 - VOA Vial
 - Sterile Plastic
 - Amber Glass
 - Widemouth Glass
 - Other

- Preservative Key**
- HCl, Cool to 4°
 - H2SO4, Cool to 4°
 - HNO3, Cool to 4°
 - NaOH, Cool to 4°
 - NaOH/Zn, Cool to 4°
 - Cool to 4°
 - None

COMMENTS:

Date Received 3/2/06

Courier: Fx Hand Delivered

Bill of Lading



STL

ANALYTICAL REPORT

Job Number: 680-14764-1

Job Description: Black & Decker

For:
Weston Solutions, Inc.
1400 Weston Way
PO BOX 2653
Westchester, PA 19380

Attention: Mr. Tom Cornuet

Bernard Kirkland
Project Manager I
bkirkland@stl-inc.com
03/29/2006

Project Manager: Bernard Kirkland

Severn Trent Laboratories, Inc.

STL Savannah 5102 LaRoche Avenue, Savannah, GA 31404
Tel (912) 354-7858 Fax (912) 351-3673 www.stl-inc.com



METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 680-14764-1

Description	Lab Location	Method	Preparation Method
Matrix: Water			
Purgeable Organic Compounds in Water by GC/MS	STL-SAV	EPA-DW 524.2	

LAB REFERENCES:

STL-SAV = STL-Savannah

METHOD REFERENCES:

EPA-DW - "Methods For The Determination Of Organic Compounds In Drinking Water", EPA/600/4-88/039, December 1988 And Its Supplements.

SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 680-14764-1

<u>Lab Sample ID</u>	<u>Client Sample ID</u>	<u>Client Matrix</u>	<u>Date/Time Sampled</u>	<u>Date/Time Received</u>
680-14764-1	RFW-20	Water	03/17/2006 1430	03/18/2006 0915
680-14764-2	RFW-21	Water	03/17/2006 1000	03/18/2006 0915
680-14764-3	HAMP-22	Water	03/17/2006 1135	03/18/2006 0915
680-14764-4	HAMP-23	Water	03/17/2006 1140	03/18/2006 0915

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-14764-1

Client Sample ID: RFW-20

Lab Sample ID: 680-14764-1

Date Sampled: 03/17/2006 1430

Client Matrix: Water

Date Received: 03/18/2006 0915

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-39672

Instrument ID: GC/MS Volatiles - U

Preparation: N/A

Lab File ID: u0851.d

Dilution: 1.0

Initial Weight/Volume: 5 mL

Date Analyzed: 03/22/2006 1932

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	RL
Acetone	<10		10
Benzene	<0.50		0.50
Bromobenzene	<0.50		0.50
Bromoform	<0.50		0.50
Bromomethane	<1.0		1.0
Carbon tetrachloride	<0.50		0.50
Chlorobenzene	<0.50		0.50
Chlorobromomethane	<0.50		0.50
Chlorodibromomethane	<0.50		0.50
Chloroethane	<1.0		1.0
Chloroform	<0.50		0.50
Chloromethane	<0.50		0.50
2-Chlorotoluene	<0.50		0.50
4-Chlorotoluene	<0.50		0.50
cis-1,2-Dichloroethene	<0.50		0.50
cis-1,3-Dichloropropene	<0.50		0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.50
Dibromomethane	<0.50		0.50
1,2-Dichlorobenzene	<0.50		0.50
1,3-Dichlorobenzene	<0.50		0.50
1,4-Dichlorobenzene	<0.50		0.50
Dichlorobromomethane	<0.50		0.50
Dichlorodifluoromethane	<0.50		0.50
1,2-Dichloroethane	<0.50		0.50
1,1-Dichloroethane	<0.50		0.50
1,1-Dichloroethene	<0.50		0.50
1,3-Dichloropropane	<0.50		0.50
2,2-Dichloropropane	<0.50		0.50
1,2-Dichloropropane	<0.50		0.50
1,1-Dichloropropene	<0.50		0.50
1,3-Dichloropropene, Total	<0.50		0.50
Diisopropyl ether	<1.0		1.0
Ethylbenzene	<0.50		0.50
Ethylene Dibromide	<0.50		0.50
Freon 113	<1.0		1.0
Hexachlorobutadiene	<0.50		0.50
2-Hexanone	<10		10
Isopropylbenzene	<0.50		0.50
4-Isopropyltoluene	<0.50		0.50
Methylene Chloride	<0.50		0.50
Methyl Ethyl Ketone	<10		10
methyl isobutyl ketone	<10		10
m-Xylene & p-Xylene	<0.50		0.50

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-14764-1

Client Sample ID: RFW-20

Lab Sample ID: 680-14764-1

Date Sampled: 03/17/2006 1430

Client Matrix: Water

Date Received: 03/18/2006 0915

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-39672

Instrument ID: GC/MS Volatiles - U

Preparation: N/A

Lab File ID: u0851.d

Dilution: 1.0

Initial Weight/Volume: 5 mL

Date Analyzed: 03/22/2006 1932

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	RL
Naphthalene	<1.0		1.0
n-Butylbenzene	<0.50		0.50
N-Propylbenzene	<0.50		0.50
o-Xylene	<0.50		0.50
sec-Butylbenzene	<0.50		0.50
Styrene	<0.50		0.50
Tert-amyl methyl ether	<1.0		1.0
tert-Butyl alcohol	<2.0		2.0
tert-Butylbenzene	<0.50		0.50
Tert-butyl ethyl ether	<1.0		1.0
1,1,2,2-Tetrachloroethane	<0.50		0.50
1,1,1,2-Tetrachloroethane	<0.50		0.50
Tetrachloroethene	<0.50		0.50
Toluene	<0.50		0.50
trans-1,2-Dichloroethene	<0.50		0.50
trans-1,3-Dichloropropene	<0.50		0.50
1,2,4-Trichlorobenzene	<0.50		0.50
1,2,3-Trichlorobenzene	<0.50		0.50
1,1,2-Trichloroethane	<0.50		0.50
1,1,1-Trichloroethane	<0.50		0.50
Trichloroethene	1.1		0.50
Trichlorofluoromethane	<0.50		0.50
1,2,3-Trichloropropane	<0.50		0.50
Trihalomethanes, Total	<0.5		0.5
1,2,4-Trimethylbenzene	<0.50		0.50
1,3,5-Trimethylbenzene	<0.50		0.50
Vinyl chloride	<0.50		0.50
Xylenes, Total	<0.50		0.50
Surrogate	%Rec		Acceptance Limits
4-Bromofluorobenzene	95		70 - 130
1,2-Dichlorobenzene-d4	97		70 - 130

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-14764-1

Client Sample ID: RFW-21

Lab Sample ID: 680-14764-2

Date Sampled: 03/17/2006 1000

Client Matrix: Water

Date Received: 03/18/2006 0915

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-39672

Instrument ID: GC/MS Volatiles - U

Preparation: N/A

Lab File ID: u0852.d

Dilution: 1.0

Initial Weight/Volume: 5 mL

Date Analyzed: 03/22/2006 1955

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	RL
Acetone	<10		10
Benzene	<0.50		0.50
Bromobenzene	<0.50		0.50
Bromoform	<0.50		0.50
Bromomethane	<1.0		1.0
Carbon tetrachloride	<0.50		0.50
Chlorobenzene	<0.50		0.50
Chlorobromomethane	<0.50		0.50
Chlorodibromomethane	<0.50		0.50
Chloroethane	<1.0		1.0
Chloroform	<0.50		0.50
Chloromethane	<0.50		0.50
2-Chlorotoluene	<0.50		0.50
4-Chlorotoluene	<0.50		0.50
cis-1,2-Dichloroethene	<0.50		0.50
cis-1,3-Dichloropropene	<0.50		0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.50
Dibromomethane	<0.50		0.50
1,2-Dichlorobenzene	<0.50		0.50
1,3-Dichlorobenzene	<0.50		0.50
1,4-Dichlorobenzene	<0.50		0.50
Dichlorobromomethane	<0.50		0.50
Dichlorodifluoromethane	<0.50		0.50
1,2-Dichloroethane	<0.50		0.50
1,1-Dichloroethane	<0.50		0.50
1,1-Dichloroethene	<0.50		0.50
1,3-Dichloropropane	<0.50		0.50
2,2-Dichloropropane	<0.50		0.50
1,2-Dichloropropane	<0.50		0.50
1,1-Dichloropropene	<0.50		0.50
1,3-Dichloropropene, Total	<0.50		0.50
Diisopropyl ether	<1.0		1.0
Ethylbenzene	<0.50		0.50
Ethylene Dibromide	<0.50		0.50
Freon 113	<1.0		1.0
Hexachlorobutadiene	<0.50		0.50
2-Hexanone	<10		10
Isopropylbenzene	<0.50		0.50
4-Isopropyltoluene	<0.50		0.50
Methylene Chloride	<0.50		0.50
Methyl Ethyl Ketone	<10		10
methyl isobutyl ketone	<10		10
m-Xylene & p-Xylene	<0.50		0.50

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-14764-1

Client Sample ID: RFW-21

Lab Sample ID: 680-14764-2

Date Sampled: 03/17/2006 1000

Client Matrix: Water

Date Received: 03/18/2006 0915

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-39672

Instrument ID: GC/MS Volatiles - U

Preparation: N/A

Lab File ID: u0852.d

Dilution: 1.0

Initial Weight/Volume: 5 mL

Date Analyzed: 03/22/2006 1955

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	RL
Naphthalene	<1.0		1.0
n-Butylbenzene	<0.50		0.50
N-Propylbenzene	<0.50		0.50
o-Xylene	<0.50		0.50
sec-Butylbenzene	<0.50		0.50
Styrene	<0.50		0.50
Tert-amyl methyl ether	<1.0		1.0
tert-Butyl alcohol	<2.0		2.0
tert-Butylbenzene	<0.50		0.50
Tert-butyl ethyl ether	<1.0		1.0
1,1,2,2-Tetrachloroethane	<0.50		0.50
1,1,1,2-Tetrachloroethane	<0.50		0.50
Tetrachloroethene	<0.50		0.50
Toluene	<0.50		0.50
trans-1,2-Dichloroethene	<0.50		0.50
trans-1,3-Dichloropropene	<0.50		0.50
1,2,4-Trichlorobenzene	<0.50		0.50
1,2,3-Trichlorobenzene	<0.50		0.50
1,1,2-Trichloroethane	<0.50		0.50
1,1,1-Trichloroethane	<0.50		0.50
Trichloroethene	<0.50		0.50
Trichlorofluoromethane	<0.50		0.50
1,2,3-Trichloropropane	<0.50		0.50
Trihalomethanes, Total	<0.5		0.5
1,2,4-Trimethylbenzene	<0.50		0.50
1,3,5-Trimethylbenzene	<0.50		0.50
Vinyl chloride	<0.50		0.50
Xylenes, Total	<0.50		0.50
Surrogate	%Rec		Acceptance Limits
4-Bromofluorobenzene	93		70 - 130
1,2-Dichlorobenzene-d4	93		70 - 130

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-14764-1

Client Sample ID: HAMP-22

Lab Sample ID: 680-14764-3

Date Sampled: 03/17/2006 1135

Client Matrix: Water

Date Received: 03/18/2006 0915

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-39672

Instrument ID: GC/MS Volatiles - U

Preparation: N/A

Lab File ID: u0853.d

Dilution: 1.0

Initial Weight/Volume: 5 mL

Date Analyzed: 03/22/2006 2016

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	RL
Acetone	<10		10
Benzene	<0.50		0.50
Bromobenzene	<0.50		0.50
Bromoform	<0.50		0.50
Bromomethane	<1.0		1.0
Carbon tetrachloride	<0.50		0.50
Chlorobenzene	<0.50		0.50
Chlorobromomethane	<0.50		0.50
Chlorodibromomethane	<0.50		0.50
Chloroethane	<1.0		1.0
Chloroform	<0.50		0.50
Chloromethane	<0.50		0.50
2-Chlorotoluene	<0.50		0.50
4-Chlorotoluene	<0.50		0.50
cis-1,2-Dichloroethene	<0.50		0.50
cis-1,3-Dichloropropene	<0.50		0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.50
Dibromomethane	<0.50		0.50
1,2-Dichlorobenzene	<0.50		0.50
1,3-Dichlorobenzene	<0.50		0.50
1,4-Dichlorobenzene	<0.50		0.50
Dichlorobromomethane	<0.50		0.50
Dichlorodifluoromethane	<0.50		0.50
1,2-Dichloroethane	<0.50		0.50
1,1-Dichloroethane	<0.50		0.50
1,1-Dichloroethene	<0.50		0.50
1,3-Dichloropropane	<0.50		0.50
2,2-Dichloropropane	<0.50		0.50
1,2-Dichloropropane	<0.50		0.50
1,1-Dichloropropene	<0.50		0.50
1,3-Dichloropropene, Total	<0.50		0.50
Diisopropyl ether	<1.0		1.0
Ethylbenzene	<0.50		0.50
Ethylene Dibromide	<0.50		0.50
Freon 113	<1.0		1.0
Hexachlorobutadiene	<0.50		0.50
2-Hexanone	<10		10
Isopropylbenzene	<0.50		0.50
4-Isopropyltoluene	<0.50		0.50
Methylene Chloride	<0.50		0.50
Methyl Ethyl Ketone	<10		10
methyl isobutyl ketone	<10		10
m-Xylene & p-Xylene	<0.50		0.50

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-14764-1

Client Sample ID: HAMP-22

Lab Sample ID: 680-14764-3

Date Sampled: 03/17/2006 1135

Client Matrix: Water

Date Received: 03/18/2006 0915

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch: 680-39672	Instrument ID: GC/MS Volatiles - U
Preparation:	N/A		Lab File ID: u0853.d
Dilution:	1.0		Initial Weight/Volume: 5 mL
Date Analyzed:	03/22/2006 2016		Final Weight/Volume: 5 mL
Date Prepared:	N/A		

Analyte	Result (ug/L)	Qualifier	RL
Naphthalene	<1.0		1.0
n-Butylbenzene	<0.50		0.50
N-Propylbenzene	<0.50		0.50
o-Xylene	<0.50		0.50
sec-Butylbenzene	<0.50		0.50
Styrene	<0.50		0.50
Tert-amyl methyl ether	<1.0		1.0
tert-Butyl alcohol	<2.0		2.0
tert-Butylbenzene	<0.50		0.50
Tert-butyl ethyl ether	<1.0		1.0
1,1,2,2-Tetrachloroethane	<0.50		0.50
1,1,1,2-Tetrachloroethane	<0.50		0.50
Tetrachloroethene	<0.50		0.50
Toluene	<0.50		0.50
trans-1,2-Dichloroethene	<0.50		0.50
trans-1,3-Dichloropropene	<0.50		0.50
1,2,4-Trichlorobenzene	<0.50		0.50
1,2,3-Trichlorobenzene	<0.50		0.50
1,1,2-Trichloroethane	<0.50		0.50
1,1,1-Trichloroethane	<0.50		0.50
Trichloroethene	<0.50		0.50
Trichlorofluoromethane	<0.50		0.50
1,2,3-Trichloropropane	<0.50		0.50
Trihalomethanes, Total	<0.5		0.5
1,2,4-Trimethylbenzene	<0.50		0.50
1,3,5-Trimethylbenzene	<0.50		0.50
Vinyl chloride	<0.50		0.50
Xylenes, Total	<0.50		0.50
Surrogate	%Rec		Acceptance Limits
4-Bromofluorobenzene	96		70 - 130
1,2-Dichlorobenzene-d4	93		70 - 130

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-14764-1

Client Sample ID: HAMP-23

Lab Sample ID: 680-14764-4

Date Sampled: 03/17/2006 1140

Client Matrix: Water

Date Received: 03/18/2006 0915

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2
 Preparation: N/A
 Dilution: 1.0
 Date Analyzed: 03/22/2006 2042
 Date Prepared: N/A

Analysis Batch: 680-39672

Instrument ID: GC/MS Volatiles - U
 Lab File ID: u0854.d
 Initial Weight/Volume: 5 mL
 Final Weight/Volume: 5 mL

Analyte	Result (ug/L)	Qualifier	RL
Acetone	<10		10
Benzene	<0.50		0.50
Bromobenzene	<0.50		0.50
Bromoform	<0.50		0.50
Bromomethane	<1.0		1.0
Carbon tetrachloride	<0.50		0.50
Chlorobenzene	<0.50		0.50
Chlorobromomethane	<0.50		0.50
Chlorodibromomethane	<0.50		0.50
Chloroethane	<1.0		1.0
Chloroform	<0.50		0.50
Chloromethane	<0.50		0.50
2-Chlorotoluene	<0.50		0.50
4-Chlorotoluene	<0.50		0.50
cis-1,2-Dichloroethene	<0.50		0.50
cis-1,3-Dichloropropene	<0.50		0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.50
Dibromomethane	<0.50		0.50
1,2-Dichlorobenzene	<0.50		0.50
1,3-Dichlorobenzene	<0.50		0.50
1,4-Dichlorobenzene	<0.50		0.50
Dichlorobromomethane	<0.50		0.50
Dichlorodifluoromethane	<0.50		0.50
1,2-Dichloroethane	<0.50		0.50
1,1-Dichloroethane	<0.50		0.50
1,1-Dichloroethene	<0.50		0.50
1,3-Dichloropropane	<0.50		0.50
2,2-Dichloropropane	<0.50		0.50
1,2-Dichloropropane	<0.50		0.50
1,1-Dichloropropene	<0.50		0.50
1,3-Dichloropropene, Total	<0.50		0.50
Diisopropyl ether	<1.0		1.0
Ethylbenzene	<0.50		0.50
Ethylene Dibromide	<0.50		0.50
Freon 113	<1.0		1.0
Hexachlorobutadiene	<0.50		0.50
2-Hexanone	<10		10
Isopropylbenzene	<0.50		0.50
4-Isopropyltoluene	<0.50		0.50
Methylene Chloride	<0.50		0.50
Methyl Ethyl Ketone	<10		10
methyl isobutyl ketone	<10		10
m-Xylene & p-Xylene	<0.50		0.50

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-14764-1

Client Sample ID: HAMP-23

Lab Sample ID: 680-14764-4

Date Sampled: 03/17/2006 1140

Client Matrix: Water

Date Received: 03/18/2006 0915

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch: 680-39672	Instrument ID: GC/MS Volatiles - U
Preparation:	N/A		Lab File ID: u0854.d
Dilution:	1.0		Initial Weight/Volume: 5 mL
Date Analyzed:	03/22/2006 2042		Final Weight/Volume: 5 mL
Date Prepared:	N/A		

Analyte	Result (ug/L)	Qualifier	RL
Naphthalene	<1.0		1.0
n-Butylbenzene	<0.50		0.50
N-Propylbenzene	<0.50		0.50
o-Xylene	<0.50		0.50
sec-Butylbenzene	<0.50		0.50
Styrene	<0.50		0.50
Tert-amyl methyl ether	<1.0		1.0
tert-Butyl alcohol	<2.0		2.0
tert-Butylbenzene	<0.50		0.50
Tert-butyl ethyl ether	<1.0		1.0
1,1,2,2-Tetrachloroethane	<0.50		0.50
1,1,1,2-Tetrachloroethane	<0.50		0.50
Tetrachloroethene	<0.50		0.50
Toluene	<0.50		0.50
trans-1,2-Dichloroethene	<0.50		0.50
trans-1,3-Dichloropropene	<0.50		0.50
1,2,4-Trichlorobenzene	<0.50		0.50
1,2,3-Trichlorobenzene	<0.50		0.50
1,1,2-Trichloroethane	<0.50		0.50
1,1,1-Trichloroethane	<0.50		0.50
Trichloroethene	<0.50		0.50
Trichlorofluoromethane	<0.50		0.50
1,2,3-Trichloropropane	<0.50		0.50
Trihalomethanes, Total	<0.5		0.5
1,2,4-Trimethylbenzene	<0.50		0.50
1,3,5-Trimethylbenzene	<0.50		0.50
Vinyl chloride	<0.50		0.50
Xylenes, Total	<0.50		0.50
Surrogate	%Rec		Acceptance Limits
4-Bromofluorobenzene	93		70 - 130
1,2-Dichlorobenzene-d4	95		70 - 130

DATA REPORTING QUALIFIERS

<u>Lab Section</u>	<u>Qualifier</u>	<u>Description</u>
--------------------	------------------	--------------------

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-14764-1

Method Blank - Batch: 680-39672

Method: 524.2
Preparation: N/A

Lab Sample ID: MB 680-39672/3
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/22/2006 1748
Date Prepared: N/A

Analysis Batch: 680-39672
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - U
Lab File ID: uq456.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	Result	Qual	RL
Acetone	<10		10
Benzene	<0.50		0.50
Bromobenzene	<0.50		0.50
Bromoform	<0.50		0.50
Bromomethane	<1.0		1.0
Carbon tetrachloride	<0.50		0.50
Chlorobenzene	<0.50		0.50
Chlorobromomethane	<0.50		0.50
Chlorodibromomethane	<0.50		0.50
Chloroethane	<1.0		1.0
Chloroform	<0.50		0.50
Chloromethane	<0.50		0.50
2-Chlorotoluene	<0.50		0.50
4-Chlorotoluene	<0.50		0.50
cis-1,2-Dichloroethene	<0.50		0.50
cis-1,3-Dichloropropene	<0.50		0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.50
Dibromomethane	<0.50		0.50
1,2-Dichlorobenzene	<0.50		0.50
1,3-Dichlorobenzene	<0.50		0.50
1,4-Dichlorobenzene	<0.50		0.50
Dichlorobromomethane	<0.50		0.50
Dichlorodifluoromethane	<0.50		0.50
1,2-Dichloroethane	<0.50		0.50
1,1-Dichloroethane	<0.50		0.50
1,1-Dichloroethene	<0.50		0.50
1,3-Dichloropropane	<0.50		0.50
2,2-Dichloropropane	<0.50		0.50
1,2-Dichloropropane	<0.50		0.50
1,1-Dichloropropene	<0.50		0.50
1,3-Dichloropropene, Total	<0.50		0.50
Diisopropyl ether	<1.0		1.0
Ethylbenzene	<0.50		0.50
Ethylene Dibromide	<0.50		0.50
Freon 113	<1.0		1.0
Hexachlorobutadiene	<0.50		0.50
2-Hexanone	<10		10
Isopropylbenzene	<0.50		0.50
4-Isopropyltoluene	<0.50		0.50
Methylene Chloride	<0.50		0.50
Methyl Ethyl Ketone	<10		10

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-14764-1

Method Blank - Batch: 680-39672

Method: 524.2
Preparation: N/A

Lab Sample ID: MB 680-39672/3
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/22/2006 1748
Date Prepared: N/A

Analysis Batch: 680-39672
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - U
Lab File ID: uq456.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	Result	Qual	RL
methyl isobutyl ketone	<10		10
m-Xylene & p-Xylene	<0.50		0.50
Naphthalene	<1.0		1.0
n-Butylbenzene	<0.50		0.50
N-Propylbenzene	<0.50		0.50
o-Xylene	<0.50		0.50
sec-Butylbenzene	<0.50		0.50
Styrene	<0.50		0.50
Tert-amyl methyl ether	<1.0		1.0
tert-Butyl alcohol	<2.0		2.0
tert-Butylbenzene	<0.50		0.50
Tert-butyl ethyl ether	<1.0		1.0
1,1,2,2-Tetrachloroethane	<0.50		0.50
1,1,1,2-Tetrachloroethane	<0.50		0.50
Tetrachloroethene	<0.50		0.50
Toluene	<0.50		0.50
trans-1,2-Dichloroethene	<0.50		0.50
trans-1,3-Dichloropropene	<0.50		0.50
1,2,4-Trichlorobenzene	<0.50		0.50
1,2,3-Trichlorobenzene	<0.50		0.50
1,1,2-Trichloroethane	<0.50		0.50
1,1,1-Trichloroethane	<0.50		0.50
Trichloroethene	<0.50		0.50
Trichlorofluoromethane	<0.50		0.50
1,2,3-Trichloropropane	<0.50		0.50
Trihalomethanes, Total	<0.5		0.5
1,2,4-Trimethylbenzene	<0.50		0.50
1,3,5-Trimethylbenzene	<0.50		0.50
Vinyl chloride	<0.50		0.50
Xylenes, Total	<0.50		0.50

Surrogate	% Rec	Acceptance Limits
4-Bromofluorobenzene	93	70 - 130
1,2-Dichlorobenzene-d4	91	70 - 130

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-14764-1

**Laboratory Control/
Laboratory Control Duplicate Recovery Report - Batch: 680-39672**

**Method: 524.2
Preparation: N/A**

LCS Lab Sample ID: LCS 680-39672/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/22/2006 1808
Date Prepared: N/A

Analysis Batch: 680-39672
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - U
Lab File ID: uq457.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

LCSD Lab Sample ID: LCSD 680-39672/5
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/22/2006 1830
Date Prepared: N/A

Analysis Batch: 680-39672
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - U
Lab File ID: uq458.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	LCS Qual	LCSD Qual
	LCS	LCSD					
Benzene	102	99	70 - 130	3	30		
Bromobenzene	100	100	70 - 130	0	30		
Bromoform	99	99	70 - 130	0	30		
Bromomethane	84	73	70 - 130	15	30		
Carbon tetrachloride	91	88	70 - 130	3	30		
Chlorobenzene	98	97	70 - 130	2	30		
Chlorobromomethane	100	100	70 - 130	0	30		
Chlorodibromomethane	95	96	70 - 130	0	30		
Chloroethane	85	94	70 - 130	11	30		
Chloroform	94	92	70 - 130	2	30		
Chloromethane	91	89	70 - 130	2	30		
2-Chlorotoluene	98	97	70 - 130	1	30		
4-Chlorotoluene	100	99	70 - 130	1	30		
cis-1,2-Dichloroethene	94	94	70 - 130	0	30		
cis-1,3-Dichloropropene	98	99	70 - 130	1	30		
1,2-Dibromo-3-Chloropropane	95	101	70 - 130	6	30		
Dibromomethane	94	94	70 - 130	0	30		
1,2-Dichlorobenzene	101	102	70 - 130	1	30		
1,3-Dichlorobenzene	99	100	70 - 130	1	30		
1,4-Dichlorobenzene	100	99	70 - 130	1	30		
Dichlorobromomethane	92	93	70 - 130	0	30		
Dichlorodifluoromethane	91	88	70 - 130	4	30		
1,1-Dichloroethane	97	95	70 - 130	2	30		
1,2-Dichloroethane	86	86	70 - 130	1	30		
1,1-Dichloroethene	93	80	70 - 130	14	30		
1,2-Dichloropropane	102	100	70 - 130	1	30		
1,3-Dichloropropane	100	100	70 - 130	1	30		
2,2-Dichloropropane	95	92	70 - 130	3	30		
1,1-Dichloropropene	97	93	70 - 130	3	30		
1,3-Dichloropropene, Total	99	101	70 - 130	1	30		
Diisopropyl ether	109	100	70 - 130	8	30		
Ethylbenzene	99	97	70 - 130	1	30		

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-14764-1

**Laboratory Control/
Laboratory Control Duplicate Recovery Report - Batch: 680-39672**

**Method: 524.2
Preparation: N/A**

LCS Lab Sample ID: LCS 680-39672/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/22/2006 1808
Date Prepared: N/A

Analysis Batch: 680-39672
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - U
Lab File ID: uq457.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

LCSD Lab Sample ID: LCSD 680-39672/5
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/22/2006 1830
Date Prepared: N/A

Analysis Batch: 680-39672
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - U
Lab File ID: uq458.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	LCS Qual	LCSD Qual
	LCS	LCSD					
Ethylene Dibromide	100	101	70 - 130	1	30		
Hexachlorobutadiene	93	94	70 - 130	1	30		
Isopropylbenzene	98	97	70 - 130	1	30		
4-Isopropyltoluene	101	100	70 - 130	1	30		
Methylene Chloride	99	98	70 - 130	1	30		
m-Xylene & p-Xylene	101	99	70 - 130	2	30		
Naphthalene	106	113	70 - 130	7	30		
n-Butylbenzene	103	103	70 - 130	0	30		
N-Propylbenzene	99	98	70 - 130	1	30		
o-Xylene	99	99	70 - 130	1	30		
sec-Butylbenzene	101	98	70 - 130	3	30		
Styrene	107	105	70 - 130	2	30		
Tert-amyl methyl ether	116	110	70 - 130	5	30		
tert-Butyl alcohol	99	97	70 - 130	1	30		
tert-Butylbenzene	99	98	70 - 130	1	30		
Tert-butyl ethyl ether	116	107	70 - 130	8	30		
1,1,1,2-Tetrachloroethane	96	95	70 - 130	2	30		
1,1,2,2-Tetrachloroethane	109	110	70 - 130	1	30		
Tetrachloroethene	97	93	70 - 130	4	30		
Toluene	98	96	70 - 130	2	30		
trans-1,2-Dichloroethene	95	92	70 - 130	3	30		
trans-1,3-Dichloropropene	101	102	70 - 130	2	30		
1,2,3-Trichlorobenzene	96	98	70 - 130	2	30		
1,2,4-Trichlorobenzene	94	98	70 - 130	4	30		
1,1,1-Trichloroethane	88	87	70 - 130	2	30		
1,1,2-Trichloroethane	101	102	70 - 130	1	30		
Trichlorofluoromethane	90	91	70 - 130	2	30		
1,2,3-Trichloropropane	98	102	70 - 130	4	30		
Trihalomethanes, Total	95	95	70 - 130	0	30		
1,2,4-Trimethylbenzene	102	102	70 - 130	1	30		
1,3,5-Trimethylbenzene	100	99	70 - 130	1	30		
Vinyl chloride	93	90	70 - 130	3	30		

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-14764-1

**Laboratory Control/
Laboratory Control Duplicate Recovery Report - Batch: 680-39672**

**Method: 524.2
Preparation: N/A**

LCS Lab Sample ID: LCS 680-39672/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/22/2006 1808
Date Prepared: N/A

Analysis Batch: 680-39672
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - U
Lab File ID: uq457.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

LCSD Lab Sample ID: LCSD 680-39672/5
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 03/22/2006 1830
Date Prepared: N/A

Analysis Batch: 680-39672
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - U
Lab File ID: uq458.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	LCS Qual	LCSD Qual
	LCS	LCSD					
Xylenes, Total	101	99	70 - 130	2	30		

Calculations are performed before rounding to avoid round-off errors in calculated results.

