

Quarterly Groundwater Monitoring Report

Prepared for

Black & Decker (U.S.) Inc.

Hampstead, Maryland

October 2008

Prepared by

WESTON SOLUTIONS, INC.

West Chester, Pennsylvania 19380-1499

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1-1
2. SITE CHARACTERISTICS.....	2-1
2.1 HYDRAULIC PROPERTIES	2-1
2.2 EFFLUENT CHARACTERISTICS	2-1
2.3 GROUNDWATER QUALITY DATA	2-1
3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM.....	3-1
4. RECOMMENDATIONS.....	4-1

LIST OF APPENDICES

APPENDIX A - GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS

APPENDIX B - DISCHARGE MONITORING REPORTS

APPENDIX C - GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS

APPENDIX D - GROUNDWATER ANALYTICAL DATA PACKAGE

LIST OF TABLES

Table	Page
Table 2-1 Treatment System Pumping Records – 3rd Quarter 2008	2-2
Table 2-2 Groundwater Elevation Data – 3rd Quarter 2008.....	2-3
Table 2-3 Effluent Characteristics Summary – 3rd Quarter 2008.....	2-4
Table 2-4 Summary of Groundwater Analytical Results - August 2008.....	2-5
Table 3-1 Treatment System Maintenance Activities – 3rd Quarter 2008.....	3-2

1. INTRODUCTION

This Groundwater Monitoring Report has been prepared to meet the requirements of Condition IV.G of the Administrative Consent Order between the State of Maryland Department of the Environment (MDE) and Black & Decker (U.S.) Inc. (April 1995) (Consent Order). Specifically, Condition IV.G calls for preparation of a Groundwater Monitoring Report containing the following information for each reporting period:

- The quantities of groundwater pumped, treated, and discharged.
- The calculation of quantities of contaminants removed from groundwater.
- A summary of all sampling analyses.
- An explanation of all operational or other problems encountered, and the manner in which each problem was resolved.
- Copies of all reports submitted to the Department of Natural Resources in conjunction with the Groundwater Appropriations Permit.
- Recommendations for changes to the Interim Groundwater Treatment System.

This document is one of several which are being prepared in response to the Consent Order; each of these documents are to be submitted to the MDE in accordance with the schedule outlined in the Consent Order. This document will become part of the Administrative Record for the site, which is maintained at the Hampstead Public Library.

2. SITE CHARACTERISTICS

2.1 HYDRAULIC PROPERTIES

In accordance with the Consent Order and the Water Appropriation Permit issued to the Black and Decker (U.S.) Inc. Hampstead, Maryland, facility, the following pumping and water level information is included for the period of July through September 2008.

Pumping records showing the total gallons pumped per month of treatment system operation are presented in Table 2-1. The complete groundwater treatment system pumping records are included in Appendix A.

Monthly water levels for wells included in the water level monitoring plan are presented in Table 2-2. For the reporting period of July through September 2008, the extraction wells were pumping at an average combined rate of approximately 147 gallons per minute (gpm).

2.2 EFFLUENT CHARACTERISTICS

Effluent characteristics of the NPDES discharge points are recorded monthly on Discharge Monitoring Reports (DMRs) and are submitted to MDE, Water Management Administration, on a quarterly basis. A summary of the sample results from the DMRs is presented in Table 2-3. DMRs for the period of July through September 2008 are included in Appendix B.

2.3 GROUNDWATER QUALITY DATA

For the reporting period of July through September 2008, approximately 22.3 pounds of total volatile organic compounds (VOCs) were removed from the groundwater by the extraction and treatment system. In general, the total VOCs removed from the groundwater were comprised primarily of trichloroethene (TCE) (85.5 %) and tetrachloroethene (PCE) (14.5 %). Analytical results of the groundwater collected from the air stripper for the period of January through March 2008 are included in Appendix C.

A summary of the analytical results from the third quarter (August 2008) groundwater sampling round of the extraction and monitor wells is included in Table 2-4. The complete

Table 2-1
Treatment System Pumping Records - 3rd Quarter 2008
Black & Decker
Hampstead, Maryland

Date	Water Pumped (gallons)
July 2008	6,306,339
August 2008	6,110,707
September 2008	5,079,145

Table 2-2
Groundwater Elevation Data - 3rd Quarter 2008
Black & Decker
Hampstead, Maryland

WELL NO	TOC ELEV	TOTAL DEPTH	7/26/2008		8/27/2008		9/29/2008	
			DTW	ELEV	DTW	ELEV	DTW	ELEV
EW-1	847.21	55	DRY	NC	DRY	NC	DRY	NC
EW-2	849.21	110	78.90	770.31	62.10	787.11	72.12	777.09
EW-3	846.64	118	95.78	750.86	97.40	749.24	83.14	763.50
EW-4	858.01	97.5	PC	NC	PC	NC	PC	NC
EW-5	864.17	98	80.71	783.46	64.69	799.48	65.33	798.84
EW-6	831.98	115	94.60	737.38	103.20	728.78	79.08	752.90
EW-7	818.38	78	66.43	751.95	71.71	746.67	71.50	746.88
EW-8	811.13	98	86.11	725.02	91.70	719.43	91.17	719.96
EW-9	811.35	141	102.00	709.35	103.70	707.65	102.30	709.05
EW-10	807.74	INA	58.64	749.10	59.90	747.84	57.82	749.92
RFW-1A	864.37	78	51.65	812.72	48.21	816.16	49.11	815.26
RFW-1B	864.23	200	51.59	812.64	48.24	815.99	49.14	815.09
RFW-2A	857.41	35	14.21	843.20	17.51	839.90	16.84	840.57
RFW-2B	857.73	75	14.82	842.91	18.11	839.62	17.30	840.43
RFW-3B	839.21	153	38.01	801.20	35.86	803.35	37.41	801.80
RFW-4A	830.37	62	37.41	792.96	35.51	794.86	37.79	792.58
RFW-4B	830.37	120	37.30	793.07	35.43	794.94	37.71	792.66
RFW-5A	817.50	30	DRY	NC	DRY	NC	DRY	NC
RFW-6	785.04	120	4.14	780.90	4.85	780.19	4.06	780.98
RFW-7	805.14	29	7.89	797.25	7.51	797.63	7.84	797.30
RFW-8	860.07	56	DRY	NC	DRY	NC	DRY	NC
RFW-9	862.02	49	28.37	833.65	28.16	833.86	28.26	833.76
RFW-10	852.06	58	DRY	NC	DRY	NC	DRY	NC
RFW-11A	849.32	72	Damaged	NC	Damaged	NC	Damaged	NC
RFW-11B	849.62	116	66.75	782.87	65.48	784.14	66.63	782.99
RFW-12B	844.87	264	55.12	789.75	48.90	795.97	51.11	793.76
RFW-13	849.11	150	65.10	784.01	65.46	783.65	65.22	783.89
RFW-14B	812.39	281	54.53	757.86	49.58	762.81	44.83	767.56
RFW-16	856.14	41	DRY	NC	DRY	NC	DRY	NC
RFW-17	834.66	60.5	29.78	804.88	27.41	807.25	27.84	806.82
RFW-20	842.49	142	38.83	803.66	35.63	806.86	35.69	806.80
RFW-21	832.65	102	24.18	808.47	23.18	809.47	24.63	808.02
PH-7	805.94	89	39.31	766.63	37.69	768.25	38.26	767.68
PH-9	814.94	98	47.43	767.51	55.23	759.71	50.09	764.85
PH-11	820.68	78	49.40	771.28	50.78	769.90	51.30	769.38
PH-12	828.35	87	50.66	777.69	51.52	776.83	52.02	776.33
B-3	803.02	83	10.78	792.24	9.17	793.85	9.47	793.55
Amoco	842.29	INA	NA	NC	NA	NC	NA	NC
Hamp. Town #22	804.96	INA	17.14	787.82	17.11	787.85	34.74	770.22
Pembroke #1	INA	INA	14.47	NC	16.00	NC	14.70	NC
Pembroke #2	INA	INA	Damaged	NC	Damaged	NC	Damaged	NC
N. Houcks. Rd.	INA	INA	11.08	NC	12.11	NC	11.08	NC
E. Century St.	INA	INA	22.31	NC	19.46	NC	19.21	NC
Lwr. Beckleys. Rd.	INA	INA	54.83	NC	54.64	NC	53.74	NC

NA - Not Available/Not Accessible
NC - Not Calculable
INA - Information not available
PC - Pump Cycles

Table 2-3
Effluent Characteristics Summary - 3rd Quarter 2008
Black & Decker
Hampstead, Maryland

Discharge Number	Parameter	Units	Permit Limits	DMR DATE			
				July 2008	August 2008	September 2008	
001	FLOW	average	MGD	NA	0.097	0.058	0.133
		maximum	MGD	NA	0.151	0.089	0.400
	1,1,1-Trichloroethane		ug/l	5	< 1	< 1	< 1
	Tetrachloroethylene		ug/l	5	< 1	< 1	< 1
	Trichloroethylene		ug/l	5	< 1	< 1	< 1
	Total Residual Chlorine		mg/l	< 0.1	< 0.1	< 0.1	< 0.1
	Oil & Grease	maximum	mg/l	15	< 5	< 5	< 5
		quarterly average	mg/l	10	< 5	< 5	< 5
	pH	minimum	STD	6.0	6.50	6.20	6.30
		maximum	STD	8.5	7.00	6.80	8.10
BOD		mg/l	15	5.0	4.0	0.0	
TSS	maximum	mg/l	30	14.0	12.0	6.0	
	quarterly average	mg/l	20	14.0	12.0	11.0	
101 (Monitoring Point)	FLOW	average	MGD	NA	0.200	0.234	0.262
		maximum	MGD	NA	0.293	0.367	0.352
	Fecal Coliform		MPN/100ml	200	2.0	1.0	1.0
201 (Monitoring Point)	FLOW	average	MGD	NA	NR	NR	0.190
		maximum	MGD	NA	NR	NR	0.254
	1,1,1-Trichloroethane		ug/l	NA	NR	NR	< 1
	Tetrachloroethylene		ug/l	NA	NR	NR	< 1
	Trichloroethylene		ug/l	NA	NR	NR	< 1

DMR - Discharge Monitoring Report

NA - Not Applicable

NR - Not Reported

Table 2-4
Summary of Groundwater Analytical Results - August 2008
Black & Decker
Hampstead, Maryland

PARAMETER	Units	EW-1	EW-2	EW-3	EW-4	EW-5	EW-6	EW-7	EW-8	EW-9	EW-9 (DUP)	EW-10
Chloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U
Acetone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	5 U	5 U	1.1	5 U	5 U	5 U	5 U
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1	1.1	1 U	1 U	1 U
1,2-Dichloroethene (total)	ug/L	NS	3.1	2.4	1 U	1 U	1 U	9.8	27	1 U	1 U	1 U
Chloroform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1.8	1 U	1 U	1 U	1 U	1 U	1 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trichloroethene	ug/L	NS	350	150	1600	250	12	7.1	13	1.6	1.5	1 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Benzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Bromoform	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U
Tetrachloroethene	ug/L	NS	74	3.6	36	15	21	14	81	160	170	1 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Toluene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Styrene	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U

Notes: U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.

J = Indicates an estimated value.

NS = Not Sampled

Table 2-4
Summary of Groundwater Analytical Results - August 2008
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-1A	RFW-1B	RFW-2A	RFW-2B	RFW-3B	RFW-4A	RFW-4A (DUP)	RFW-4B	RFW-5A	RFW-6	RFW-7	RFW-8	RFW-9	RFW-10
Chloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromomethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Vinyl Chloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Methylene Chloride	ug/L	2 U	2 U	2 U	2 U	2 U	2 U	2 U	2 U	NS	2 U	2 U	NS	2 U	NS
Acetone	ug/L	5 U	6.5	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Carbon Disulfide	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1-Dichloroethene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.4	NS
1,1-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.1	NS
1,2-Dichloroethene (total)	ug/L	1 U	1 U	1 U	1 U	4.5	1 U	1 U	3.7	NS	1 U	1 U	NS	14	NS
Chloroform	ug/L	1 U	1 U	1 U	1 U	1 U	1.3	1.2	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
2-Butanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
1,1,1-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1.6	NS
Carbon Tetrachloride	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromodichloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,2-Dichloropropane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
cis-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trichloroethene	ug/L	1 U	1 U	1.5	1.7	1 U	29	28	16	NS	4.8	10	NS	17	NS
Dibromochloromethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
1,1,2-Trichloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Benzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Trans-1,3-Dichloropropene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Bromoform	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
4-Methyl-2-pentanone	ug/L	5 U	5 U	5 U	1 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
2-Hexanone	ug/L	5 U	5 U	5 U	5 U	5 U	5 U	5 U	5 U	NS	5 U	5 U	NS	5 U	NS
Tetrachloroethene	ug/L	1 U	1 U	1 U	1 U	1.7	21	20	35	NS	3.9	1 U	NS	6.7	NS
1,1,2,2-Tetrachloroethane	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Toluene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Chlorobenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Ethylbenzene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Styrene	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS
Xylene (total)	ug/L	1 U	1 U	1 U	1 U	1 U	1 U	1 U	1 U	NS	1 U	1 U	NS	1 U	NS

Notes: DUP = Duplicate sample
NS = Not sampled

U = Compound was analyzed for but not detected. Value shown is the method detection limit for quantification.
J = Indicates an estimated value.

Table 2-4

Summary of Groundwater Analytical Results - August 2008
Black & Decker
Hampstead, Maryland

PARAMETER	Units	RFW-11A	RFW-11B	RFW-12B	RFW-13	RFW-16	RFW-17	Leister Dairy	Leister Res. #1	Leister Res. #2	Trip Blank	RFW-20	RFW-21	Town #22	Town #23	Trip Blank
		USEPA drinking water method 524.2														
Chloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromomethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Vinyl Chloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	1 U	1 U	1 U	1 U	1 U
Methylene Chloride	ug/L	NS	2 U	2 U	2 U	NS	2 U	ABD	ABD	ABD	3.4	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Acetone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Carbon Disulfide	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	NA	NA	NA	NA	NA
1,1-Dichloroethene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethene (total)	ug/L	NS	1 U	2.1	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chloroform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
2-Butanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
1,1,1-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Carbon Tetrachloride	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromodichloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,2-Dichloropropane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
cis-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trichloroethene	ug/L	NS	13	430	5.5	NS	1 U	ABD	ABD	ABD	1 U	0.6	0.5 U	0.5 U	0.5 U	0.5 U
Dibromochloromethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2-Trichloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Benzene	ug/L	NS	1 U	1 U	1 U	NS	1.3	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Trans-1,3-Dichloropropene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Bromoform	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
4-Methyl-2-pentanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
2-Hexanone	ug/L	NS	5 U	5 U	5 U	NS	5 U	ABD	ABD	ABD	5 U	10 U	10 U	10 U	10 U	10 U
Tetrachloroethene	ug/L	NS	1 U	36	24	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
1,1,2,2-Tetrachloroethane	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Toluene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Chlorobenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Ethylbenzene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Styrene	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U
Xylene (total)	ug/L	NS	1 U	1 U	1 U	NS	1 U	ABD	ABD	ABD	1 U	0.5 U	0.5 U	0.5 U	0.5 U	0.5 U

Notes: Samples from wells RFW-20 & 21, Town-22&23 are analyzed with the USEPA drinking water method 524.2 at the request of the MDE Source Protection and Appropriation Division. Samples from all of the other wells are analyzed with USEPA Method 8260.

NS = Not sampled

U = Compound was analyzed but not detected.

ABD = Well has been abandoned

analytical data package is included in Appendix D.

As found in earlier sampling events at the Black & Decker facility, TCE and PCE were the VOCs detected at the highest concentrations in the groundwater samples. The highest concentration of TCE was detected in the groundwater samples collected from wells RFW-12B and EW-4 and the highest concentration of PCE was detected in the groundwater sample collected from wells RFW-4B and EW-9. The remainder of VOCs present were detected at levels below the Federal Maximum Contaminant Levels (MCL).

3. OPERATION AND MAINTENANCE OF THE TREATMENT SYSTEM

A summary of the maintenance activities which were undertaken with the extraction and treatment system during the reporting period (July through September 2008) is provided in Table 3-1. This table is comprehensive in summarizing significant maintenance events or activities, while not including those activities considered unworthy of note (such as replacement of light bulbs, lubrication of moving parts as appropriate or other routine activities).

Table 3-1
Treatment System Maintenance Activities - 3rd Quarter 2008
Black & Decker
Hampstead, Maryland

Date	Event/Corrective Action
Jul-08	Alarm at air stripper. High column blower failure, reset the system. System back online.
Aug-08	Alarm at air stripper due to high wet well, reset the system. System back online.
Aug-08	Micro-Tech performed routine calibration of the air stripper.
Aug-08	Power is out to the air stripper building. System is left off for two days prior to Primo Electric arriving onsite to run a temporary 70 AMP electric line from the boiler room to the stripper building.
Sep-08	Alarm at stripper. Circuit breaker in the boiler room tripped. The system is drawing too many Amps from the temporary feed. Wells 5 and 8 are turned off for three days so the system was not pulling as many Amps.
Sep-08	Alarm at stripper. Due to a loose neutral wire on the terminal block in well 2. The wire is reconnected and all wells are back online.
Sep-08	Alarm at stripper. Circuit breaker in the boiler room tripped again. The system is drawing too many Amps from the temporary feed. Wells 7 and 8 were turned off so the system is not pulling as many Amps. Weston directed B&D to turn wells 7 and 8 on and turn off wells 6 and 10.
Sep-08	IES Electric ran a temporary 200 AMP electric feed from the old weld shop to the air stripper. The system was running with 2 wells down for approximately 20 days. All wells are now back online.
Sep-08	Alarm at the stripper, well 6 tripped out. Replaced the timing relay in well 6. All wells are back online.

4. RECOMMENDATIONS

For the reporting period of July through September 2008, the treatment system continued to create a hydraulic boundary preventing off-site migration of groundwater. The extraction system will continue to operate as currently configured to pump and treat contaminated groundwater. Depth-to-water measurements will continue to be collected on a monthly basis in all site monitor wells to construct a groundwater elevation contour map for the site. The groundwater elevation contour map will be used to verify that the required area of groundwater capture is being maintained. If necessary, pumping rates will be adjusted to maintain groundwater capture due to seasonal fluctuations in groundwater elevations. The treatment system will also continue to operate as currently configured, as data collected have proven that the treatment system is fully effective in removing VOCs from the extracted groundwater.

APPENDIX A
GROUNDWATER TREATMENT SYSTEM PUMPING RECORDS
(JULY – SEPTEMBER 2008)

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operator Earle Villarreal, ESS Certification # 1017

Black & Decker WTP

PWSID # 106-0004 County: Carroll

Month: July

Operated by Maryland Environmental Service

Address: BTR CAPITAL GROUP, Hampstead, MD 21073
625 Hanover Pike, Hampstead, Carroll County, Maryland

Year: 2008

GENERAL (DOMESTIC WATER)				CHEMICAL							MONITORING			DISTRIBUTION		RAW WATER		Comments		
Date	Day	Weather	Flow meter reading	MGD Total FQIR	pH P.O.E	Free Cl ₂	Na ₂ CO ₃ Level	Na ₂ CO ₃ (gpd)	NaOCl Level	NaOCl (gpd)	VOC'S (ppb)	Bacti Pos/Neg	pH su	TRC mg/l	DISTRIBUTION LOCATION	Operator Initials	pH su		TOTAL RAW WATER WELL (mgd)	
1	tue	clr	0	0.0024	7.4	0.97	42.00	1.00	56.00	0.00						ss		0.166944		
2	wed	clr	0	0.0026	7.1	1.16	41.00	1.00	56.00	0.00						djones		0.211680		
3	thur	clr	0	0.0049	7.5	1.20	40.00	1.00	56.00	0.00			6.90	0.70	Eng Lab	djones	5.10	0.227484		
4	fri	cldy	0	0.0003	7.2	1.15	39.00	1.00	56.00	0.00						ss		0.212144		
5	sat	cldy	0	0.0000	7.1	1.16	38.00	1.00	56.00	0.00						gk		0.198410		
6	sun	cldy	0	0.0007	7.1	1.16	37.00	0.00	56.00	0.00						gk		0.185334		
7	mon	clr	0	0.0042	7.6	1.12	37.00	1.00	56.00	0.00			7.40	1.00	Admin 1st FI	djones		0.206078		
8	tue	clr	0	0.0050	7.4	1.26	36.00	2.00	56.00	0.00						djones		0.223603		
9	wed	clr	0	0.0023	7.3	1.33	34.00	1.00	56.00	0.00			6.70	0.80	Eng Lab	djones	5.10	0.178639		
10	thur	clr	0	0.0050	7.3	1.20	33.00	1.00	56.00	0.00						djones		0.206440		
11	fri	clr	0	0.0035	7.4	1.34	32.00	1.00	56.00	0.00			6.90	0.90	Admin 2nd FI	djones		0.217456		
12	sat	clr	0	0.0000	7.9	1.22	31.00	0.00	56.00	0.00						ss		0.214776		
13	sun	clr	0	0.0027	7.6	1.36	31.00	1.00	56.00	0.00						gk		0.203576		
14	mon	clr	0	0.0027	7.0	1.08	30.00	1.00	56.00	0.00			7.43	0.82	Admin 1st FI	ss		0.182986		
15	tue	clr	0	0.0045	7.4	1.10	29.00	1.00	56.00	0.00						djones		0.213086		
16	wed	clr	0	0.0051	7.4	1.28	28.00	2.00	56.00	0.00			7.05	0.92	Eng Lab	djones	5.10	0.189759		
17	thur	clr	0	0.0026	7.2	1.16	26.00	1.00	56.00	0.00						ss		0.212910		
18	fri	clr	0	0.0021	7.5	1.20	25.00	1.00	56.00	0.00			7.31	1.08	Admin 2nd FI	djones		0.206697		
19	sat	clr	0	0.0023	7.6	1.01	44.00	1.00	56.00	0.00						djones		0.200405		
20	sun	clr	0	0.0080	7.8	1.02	43.00	1.00	56.00	0.00						djones		0.218179		
21	mon	clr	0	0.0029	7.8	1.39	42.00	2.00	56.00	0.00			6.85	0.91	Admin 1st FI	ss		0.206172		
22	tue	clr	0	0.0036	7.4	1.27	40.00	1.00	56.00	5.00						ss		0.187136		
23	wed	cldy	0	0.0050	7.2	1.14	39.00	1.00	51.00	0.00			7.27	1.06	Eng Lab	djones	5.00	0.219718		
24	thur	CLR	0	0.0041	7.0	1.45	38.00	2.00	51.00	0.00						djones		0.205131		
25	fri	CLR	0	0.0000	7.5	1.34	36.00	0.00	51.00	0.00			7.94	0.97	Admin 2nd FI	SS		0.195127		
26	sat	CLR	0	0.0023	7.2	1.10	36.00	1.00	51.00	0.00						SS		0.204407		
27	sun	CLDY	0	0.0027	7.4	1.36	35.00	1.00	51.00	0.00						SS		0.203410		
28	mon	CLR	0	0.0048	8.1	1.41	72.00	1.00	51.00	0.00			7.64	0.80	Eng Lab	GAD		0.208263		
29	tue	CLR	0	0.0026	6.8	0.79	71.00	6.00	51.00	0.00						GAD		0.200477		
30	wed	CLR	0	0.0024	7.8	0.63	65.00	0.00	51.00	0.00			6.84	0.62	Admin 1st FI	SS		0.174221		
31	thur	CLDY	0	0.0052	6.4	0.91	65.00	5.00	51.00	0.00						GAD		0.225691		
Total				0.0965	228.1	36.27	1235.0	40.00	1691.0	5.00	0.0	0.0	86.2	10.6					6.306339	
Average				0.0031	7.36	1.17	39.84	1.29	54.55	0.16	0.0	0.0	7.19	0.88					0.203430	
Minimum				0.0000	6.36	0.63	25.00	0.00	51.00	0.00	0.0	0.0	6.70	0.62					0.166944	MOR
Maximum				0.0080	8.08	1.45	72.00	6.00	56.00	5.00	0.0	0.0	7.94	1.08					0.227484	04/09/07

MARYLAND DEPARTMENT of the ENVIRONMENT, WATER MANAGEMENT ADMINISTRATION, 1800 WASHINGTON BLVD, BALTIMORE, MD 21230

Operator Earle Villarreal ESS Certification # 1017

Black & Decker WTP

PWSID # 106-0004

County: Carroll

Month: August

Operated by
Maryland Environmental Service

Address: BTR CAPITAL GROUP, Hampstead, MD 21073
625 Hanover Pike, Hampstead, Carroll County, Maryland

Year: 2008

GENERAL (DOMESTIC WATER)				CHEMICAL							MONITORING		DISTRIBUTION			RAW WATER		Comments	
Date	Day	Weather	Flow meter reading o	MGD Total FOIR	pH P.O.E	Free Cl ₂	Na ₂ CO ₃ Level	Na ₂ CO ₃ (gpd)	NaOCl Level	NaOCl (gpd)	VOC'S (ppb)	Bacil Pos/Neg	pH su	TRC mg/l	DISTRIBUTION LOCATION	Operator Initials	pH su		TOTAL RAW WATER WELL (mgd)
1	fri	clr	0	0.0024	7.5	0.83	60.00	1.00	51.00	0.00			6.82	0.66	Admin 2nd FI	ss	5.31	0.185971	
2	sat	cldy	0	0.0000	7.5	0.68	59.00	1.00	51.00	0.00						mwhitt		0.204457	
3	sun	clr	0	0.0024	7.3	0.61	58.00	0.00	51.00	0.00						mwhitt		0.186305	
4	mon	clr	0	0.0050	7.2	0.97	58.00	1.00	51.00	0.00						djones		0.198660	
5	tue	cldy	0	0.0049	7.1	1.13	57.00	1.00	51.00	0.00			7.0	0.75	Admin 1st FI	djones		0.217994	
6	wed	clr	0	0.0027	7.1	1.14	56.00	1.00	51.00	0.00			7.2	0.89	Eng Lab	djones		0.185555	
7	thur	clr	0	0.0025	7.1	1.20	55.00	1.00	51.00	0.00			7.1	0.88	Admin 2nd FI	djones	5.06	0.198021	
8	fri	clr	0	0.0051	7.0	1.12	54.00	1.00	51.00	0.00						djones		0.210117	
9	sat	clr	0	0.0000	6.9	1.04	53.00	0.00	51.00	0.00						djones		0.184851	
10	sun	clr	0	0.0025	9.9	1.05	53.00	1.00	51.00	0.00						djones		0.219873	
11	mon	clr	0	0.0057	7.7	1.09	52.00	1.00	51.00	0.00			6.6	0.71	Admin 1st FI	ss		0.200847	
12	tue	clr	0	0.0048	7.1	1.21	51.00	1.00	51.00	0.00						ss		0.197989	
13	wed	clr	0	0.0030	7.6	1.33	50.00	1.00	51.00	0.00			7.1	1.06	Eng Lab	djones		0.179673	
14	thur	cldy	0	0.0044	7.0	1.30	49.00	1.00	51.00	0.00						djones	5.07	0.202063	
15	fri	cldy	0	0.0025	7.0	1.40	48.00	1.00	51.00	0.00			7.1	1.08	Admin 2nd FI	djones		0.224553	
16	sat	clr	0	0.0024	7.2	1.33	47.00	1.00	51.00	0.00						ss		0.193636	
17	sun	clr	0	0.0025	7.0	1.27	46.00	1.00	51.00	0.00						ss		0.197290	
18	mon	clr	0	0.0023	7.0	1.40	45.00	1.00	51.00	0.00			7.4	0.90	Admin 1st FI	djones		0.199241	
19	tue	clr	0	0.0073	7.4	1.30	44.00	2.00	51.00	0.00						djones		0.212617	
20	wed	clr	0	0.0027	7.2	1.40	42.00	1.00	51.00	0.00			7.2	1.14	Eng Lab	djones	5.05	0.188485	
21	thur	clr	0	0.0051	6.8	1.31	41.00	1.00	51.00	0.00						djones		0.202671	
22	fri	clr	0	0.0023	6.8	1.44	40.00	1.00	51.00	0.00			6.7	1.05	Admin 2nd FI	djones		0.210594	
23	sat	clr	0	0.0000	7.0	1.22	39.00	1.00	51.00	0.00						mwhitt		0.198563	
24	sun	clr	0	0.0027	7.1	1.17	38.00	1.00	51.00	0.00						mwhitt		0.190923	
25	mon	rain	0	0.0046	7.1	1.35	37.00	1.00	51.00	0.00			7.2	1.17	Admin 1st FI	djones		0.204212	
26	tue	clr	0	0.0047	6.9	1.32	36.00	2.00	51.00	0.00						djones	4.94	0.203373	
27	wed	clr	0	0.0025	7.1	1.43	34.00	1.00	51.00	0.00			6.9	1.07	Eng Lab	djones		0.194029	
28	thur	rain	0	0.0044	6.9	1.46	33.00	1.00	51.00	0.00						djones		0.209248	
29	fri	clr	0	0.0009	7.0	1.33	32.00	1.00	51.00	0.00			6.8	1.07	Admin 2nd FI	djones		0.214242	
30	sat	clr	0	0.0023	7.3	1.20	31.00	1.00	51.00	0.00						djones		0.205154	
31	sun	clr	0	0.0000	7.3	1.47	30.00	0.00	51.00	0.00						djones		0.089500	Pow outage
Total				0.0946	224.1	37.50	1428.0	30.00	1581.0	0.00	0.0	0.0	91	1.12				6.110707	
Average				0.0031	7.23	1.21	46.06	0.97	51.00	0.00	0.0	0.0	6.99	0.96				0.197120	
Minimum				0.0000	6.80	0.61	30.00	0.00	51.00	0.00	0.0	0.0	6.59	0.66				0.089500	MOR
Maximum				0.0073	9.92	1.47	60.00	2.00	51.00	0.00	0.0	0.0	7.40	1.17				0.224553	04/09/07

Black & Decker WTP

PWSID # 106-0004

County: Carroll

Month: September

Operated by

Address: BTR CAPITAL GROUP, Hampstead, MD 21073

Maryland Environmental Service

625 Hanover Pike, Hampstead, Carroll County, Maryland

Year: 2008

GENERAL (DOMESTIC WATER)				CHEMICAL							MONITORING			DISTRIBUTION		RAW WATER		Comments	
Date	Day	Weather	Flow meter reading 0	MGD Total FQIR	pH P.O.E	Free Cl ₂	Na ₂ CO ₃ Level	Na ₂ CO ₃ (gpd)	NaOCl Level	NaOCl (gpd)	VOC'S (ppb)	Bactl Pos/Neg	pH su	TRC mg/l	DISTRIBUTION LOCATION	Operator Initials	pH su		TOTAL RAW WATER WELL (mgd)
1	mon	clr	0	0.0008	7.48	1.46	51.00	1.00	51.00	0.00						mw		0.089005	
2	tue	clr	0	0.0027	7.32	1.22	50.00	1.00	51.00	0.00						ss		0.074596	
3	wed	clr	0	0.0035	7.31	1.00	49.00	1.00	51.00	0.00			6.94	0.73	Eng Lab	djones		0.204251	
4	thur	clr	0	0.0046	6.90	1.16	48.00	1.00	51.00	0.00						djones	5.01	0.165844	
5	fri	clr	0	0.0039	6.96	1.06	47.00	2.00	51.00	0.00			6.92	0.96	Admin 2nd FI	djones		0.190741	
6	sat	rain	0	0.0000	7.04	1.02	45.00	1.00	51.00	0.00						ss		0.182622	
7	sun	clr	0	0.0027	7.20	1.15	44.00	1.00	51.00	0.00						ss		0.177195	
8	mon	clr	0	0.0054	7.32	1.38	43.00	1.00	51.00	0.00			7.19	1.16	Admin 1st FI	djones		0.163423	
9	tue	rain	0	0.0054	7.00	1.60	42.00	1.00	51.00	0.00						djones		0.152797	
10	wed	clr	0	0.0024	7.42	1.57	41.00	1.00	51.00	0.00			7.07	1.24	Eng Lab	djones	4.76	0.139150	
11	thur	cldy	0	0.0051	7.27	1.48	40.00	1.00	51.00	0.00						djones		0.135494	
12	fri	cldy	0	0.0024	7.10	1.59	39.00	1.00	51.00	0.00			6.92	1.41	Admin 2nd FI	djones		0.209334	
13	sat	clr	0	0.0000	7.28	1.35	38.00	1.00	51.00	0.00						mw		0.172369	
14	sun	clr	0	0.0023	7.18	1.28	37.00	0.00	51.00	0.00						mw		0.168472	
15	mon	clr	0	0.0049	7.57	1.43	37.00	1.00	51.00	0.00			7.40	1.24	Admin 1st FI	djones		0.181709	
16	tue	cldy	0	0.0052	6.95	1.40	36.00	1.00	51.00	0.00						djones	5.10	0.153471	
17	wed	clr	0	0.0049	7.04	1.45	35.00	1.00	51.00	0.00			7.00	1.00	Eng Lab	djones		0.147811	
18	thur	clr	0	0.0024	6.93	1.13	54.00	0.00	51.00	0.00						gd		0.087557	
19	fri	clr	0	0.0048	7.24	1.33	54.00	3.00	51.00	0.00			7.21	1.08	Admin 2nd FI	gd		0.165396	
20	sat	clr	0	0.0000	7.45	1.29	51.00	0.00	51.00	0.00						gd		0.145593	
21	sun	clr	0	0.0025	7.28	1.22	51.00	2.00	51.00	0.00						gd		0.159583	
22	mon	clr	0	0.0052	7.26	1.22	49.00	1.00	51.00	0.00						ss		0.152443	
23	tue	clr	0	0.0050	7.83	1.35	48.00	1.00	51.00	0.00			7.01	1.02	Admin 2nd FI	ss		0.140097	
24	wed	clr	0	0.0026	7.21	1.56	47.00	1.00	51.00	0.00			6.90	1.29	Eng Lab	djones	4.95	0.125280	
25	thur	clr	0	0.0053	6.90	1.51	46.00	1.00	51.00	0.00						djones		0.236241	
26	fri	clr	0	0.0025	7.20	1.47	45.00	1.00	51.00	0.00			7.05	1.24	Admin 1st FI	djones		0.253818	
27	sat	clr	0	0.0024	7.11	1.17	44.00	1.00	51.00	0.00						ss		0.220696	
28	sun	clr	0	0.0027	7.25	1.33	43.00	1.00	51.00	0.00						ss		0.224511	
29	mon	clr	0	0.0024	7.15	1.49	42.00	1.00	51.00	0.00			6.89	1.12	Admin 1st FI	djones		0.232201	
30	tue	clr	0	0.0053	7.05	1.33	41.00	1.00	51.00	0.00						djones		0.227445	
31																			
Total				0.0993	216.2	40.00	1337.0	31.00	1530.0	0.00	0.0	0.0	84.5	13.5				5.079145	
Average				0.0033	7.21	1.33	44.57	1.03	51.00	0.00	0.0	0.0	7.04	1.12				0.169305	
Minimum				0.0000	6.90	1.00	35.00	0.00	51.00	0.00	0.0	0.0	6.89	0.73				0.074596	MOR
Maximum				0.0054	7.83	1.60	54.00	3.00	51.00	0.00	0.0	0.0	7.40	1.41				0.253818	04/09/07

**APPENDIX B
DISCHARGE MONITORING REPORTS
(JULY - SEPTEMBER 2008)**

Facility Name/Location (include address if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
08	07	01	TO	08	07	31

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (46-53)			QUANTITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE (3 Card Only) (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (4 Card Only) (38-45)	AVERAGE (54-61)	MAXIMUM				UNITS
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	5	(19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15			ONE/MONTH	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	****	6.5	*****	7.0	(12)	0	TWO/WEEK	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	6.5			TWO/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	14	14	(19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	20	30			ONE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	96774	151000	(07)	*****	*****	*****		0	MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****			MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.01	0.019			ONE/MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5			ONE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5			ONE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
410 729-8350
 AREA CODE NUMBER

DATE
08 08 25
 YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS(Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

MD0001881

PERMIT NUMBER

001

DISCHARGE NUMBER

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

MONITORING PERIOD


FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	08	07	01		08	07	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (54-61)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM				
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****		*****	*****	0		0	ONE/MONTH	GRAB
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5	ug/l		ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****		*****	0	0	(19)	0	ONE/MONTH	GRAB
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
410	729-8350	08	08	25
AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

State Discharge Permit
02-DP-0022

MD0001881

PERMIT NUMBER

101

DISCHARGE NUMBER

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	08	07	01		08	07	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***


NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	REPORT	200194	293000	(07) GPD	*****	*****	*****	****	0	ONE/MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	REPORT	*****	*****	****	*****	*****	2	MPN	0	ONE/WEEK	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: 410 729-8350
DATE: 08 08 25

AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

MD0001881

PERMIT NUMBER

001

DISCHARGE NUMBER

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
08	08	01		08	08	31
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only (46-53) (54-61))			QUANTITY OR CONCENTRATION (4 Card Only (38-45) (46-53) (54-61))				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	*****	4	(19)	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15			ONE/ MONTH	GRAB
pH		*****	*****	****	6.2	*****	6.8	(12)	0	TWO/ WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	8.5			TWO/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	12	12	(.19)	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	20	30			ONE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50060 1 0 0 EFFLUENT GROSS VALUE		58258	89000	(07)	*****	*****	*****		0	MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****		****	MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	<0.1	<0.1	(19)	0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.01	0.019			ONE/ MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	*****	0		0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	0			ONE/ MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE		*****	*****	****	*****	*****	0		0	ONE/ MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	0			ONE/ MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: **410 729-8350**
 DATE: **08 09 22**
 AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**
 ADDRESS **626 Hanover Pike**

Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

MD0001881
 PERMIT NUMBER

001
 DISCHARGE NUMBER

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98


MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
08	08	01		08	08	31	
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)	

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (34-61)			QUANTITY OR CONCENTRATION (46-53)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS			
TRICHLOROETHENE	SAMPLE MEASUREMENT	*****	*****		*****	*****	0		0	ONE/MONTH	GRAB
79141 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			****			5	ug/l		ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE	SAMPLE MEASUREMENT	*****	*****		*****	0	0	(19)	0	ONE/MONTH	GRAB
70030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			****		10	5	MG/L		ONE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Jim Harkins, Director MES
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: **410 729-8350**
 DATE: **08 09 22**
 AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**
 ADDRESS **626 Hanover Pike**
Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

MD0001881
 PERMIT NUMBER

101
 DISCHARGE NUMBER

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
08	08	01		08	08	31
(20-21)		(22-23)		(24-25)		(26-27)
				(28-29)		(30-31)

*** NO DISCHARGE ***
 NOTE: Read Instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (54-61)			QUANTITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (46-53)	UNITS (46-53)	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (46-53)			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	REPORT	233645	367000	(07) GPD	*****	*****	*****	0	ONE/MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	REPORT	*****	*****	****	*****	*****	1 200	0	ONE/WEEK	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE			
Jim Harkins, Director MES			410 729-8350	08 09 22			
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)
 NAME **AG/GFI Hampstead, Inc**
 ADDRESS **626 Hanover Pike**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

Form Approved. 12345
 OMB No. 2040-0004.
 Approval expires 05-31-98


MD0001881 **001**
 PERMIT NUMBER DISCHARGE NUMBER

Hampstead, MD 21074
 FACILITY **Black and Decker WWTP**
 LOCATION **626 Hanover Pike**

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
08	09	01	TO	08	09	30	
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)	

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING (3 Card Only) (46-53) (54-61)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45) (46-53) (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT *****	*****	*****	****	*****	*****	0	(19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT *****	*****	*****	****	*****	*****	15			ONE/MONTH	GRAB
pH	SAMPLE MEASUREMENT *****	*****	*****	****	6.3	*****	8.1	(12)	0	TWO/WEEK	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT *****	*****	*****	****	6.0	*****	8.5			TWO/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT *****	*****	*****	****	*****	6	6	(19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT *****	*****	*****	****	*****	20	30			ONE/MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT 133100	400000	(07)	*****	*****	*****	*****		0	MEASURED	RECORD
	PERMIT REQUIREMENT REPORT	REPORT	GPD	*****	*****	*****	*****	****		MEASURED	RECORD
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT *****	*****	*****	****	*****	<0.1	<0.1	(19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT *****	*****	*****	****	*****	0.011	0.019			ONE/MONTH	GRAB
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT *****	*****	*****	****	*****	*****	0		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT *****	*****	*****	****	*****	*****	5			ONE/MONTH	GRAB
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT *****	*****	*****	****	*****	*****	0		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT *****	*****	*****	****	*****	*****	5			ONE/MONTH	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Jim Harkins, Director MES	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE	DATE		
TYPED OR PRINTED			410	729-8350	08	10
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)	AREA CODE	NUMBER	YEAR	MO	DAY	

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)

State Discharge Permit

02-DP-0022

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

MD0001881

PERMIT NUMBER

001

DISCHARGE NUMBER

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	08	09	01		08	09	30
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

*** NO DISCHARGE ***
NOTE: Read Instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0	ug/l	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	5			ONE/MONTH	GRAB
OIL AND GREASE TOTAL RECOVERABLE 70030 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	(19)	0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	10	15	MG/L		ONE/MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE		
TYPED OR PRINTED			410 729-8350	08	10	22

COMMENT AND EXPLANATION OF ANY VIOLATIONS(Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
 (2-16) (17-19)

State Discharge Permit
02-DP-0022

MD0001881
 PERMIT NUMBER

101
 DISCHARGE NUMBER

Form Approved. **12345**
 OMB No. 2040-0004.
 Approval expires 05-31-98

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
08	09	01		08	09	30	
(20-21)		(22-23)		(24-25)		(26-27) (28-29) (30-31)	

*** NO DISCHARGE ***
 NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING- (3 Card Only) (46-53)			QUANTITY OR CONCENTRATION (4 Card Only) (38-45)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	262167	352000	(07)	*****	*****	*****		0	ONE/MONTH	GRAB
	PERMIT REQUIREMENT	REPORT *****	REPORT *****	GPD	*****	*****	*****	****		ONE/MONTH	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		*****	*****	1	(30)	0	ONE/WEEK	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	200	MPN		ONE/WEEK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE			
Jim Harkins, Director MES			410 729-8350	08	10	22	
TYPED OR PRINTED			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **AG/GFI Hampstead, Inc**

ADDRESS **626 Hanover Pike**

Hampstead, MD 21074

FACILITY **Black and Decker WWTP**

LOCATION **626 Hanover Pike**

ATTN:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

State Discharge Permit

02-DP-0022

Form Approved. 12345

OMB No. 2040-0004.

Approval expires 05-31-98

MD0001881

PERMIT NUMBER

201

DISCHARGE NUMBER

MONITORING PERIOD

FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
08	07	01	08	09	30
(20-21) (22-23) (24-25)			(26-27) (28-29) (30-31)		

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING (3 Card Only (46-53)) (54-61)			QUANTITY OR CONCENTRATION (4 Card Only (38-45)) (46-53) (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	190171	253818	(07)	*****	*****	*****	0	MEASURED	RECORD
	PERMIT REQUIREMENT	REPORT	REPORT	GPD	*****	*****	*****			
TETRACHLOROETHYLENE 34475 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	0	ONE/ QUARTER	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT			
1,1,1-TRICHLOROETHANE 34506 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	0	ONE/ QUARTER	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT			
TRICHLOROETHENE 79141 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0	0	0	ONE/ QUARTER	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT	REPORT			
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Jim Harkins, Director MES	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	410	729-8350	08
		AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS(Reference all attachments here)

Quarterly Report! Outfall 201 quarterly sample's collected on 7/9/08 & 9/03/08.

APPENDIX C
GROUNDWATER TREATMENT SYSTEM ANALYTICAL RESULTS
(JULY - SEPTEMBER 2008)



630 Churchmans Road
 Newark, Delaware 19702
 302-266-9121 • 454-8720 (FAX)
 WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS
 REVISED 7/23/2008

Maryland Environmental Services (A)
 259 Najoles Road
 Millersville, MD 21108

Order Number: A08070610
 Project Name: Black & Decker WWTP
 Receive Date: 7/9/2008
 Client Code: MES_A
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A08070610-01 **Sample Date: 7/9/2008 10:37**

Site: Black & Decker 001
 Client Sample ID:
 Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,1,2,2-Tetrachloroethane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,1,2-Trichloroethane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,1-Dichloroethane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,1-Dichloroethene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,1-Dichloropropene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,2,3-Trichlorobenzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,2,3-Trichloropropane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,2,4-Trichlorobenzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,2,4-Trimethylbenzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,2-Dibromo-3-Chloropropane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,2-Dibromoethane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,2-Dichlorobenzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,2-Dichloroethane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,2-Dichloropropane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,3,5-Trimethylbenzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,3-Dichlorobenzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,3-Dichloropropane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
1,4-Dichlorobenzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
2,2-Dichloropropane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
2-Butanone (MEK)	<10	ug/L	10	EPA 8260B	7/17/2008 6:37:00 AM	WWells
2-Chloroethylvinyl ether	<5	ug/L	5	EPA 8260B	7/17/2008 6:37:00 AM	WWells
2-Chlorotoluene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
2-Hexanone	<10	ug/L	10	EPA 8260B	7/17/2008 6:37:00 AM	WWells
3-Chloro-1-propene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
4-Chlorotoluene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
4-Isopropyltoluene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells

Approved: *Warner Van Arsdale*
 Quality Assurance Manager

Reported: 7/23/2008 8:41:52 AM

RDL = Reporting Detection Limit N/A = Not Applicable
 Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DES68



630 Churchmans Road
 Newark, Delaware 19702
 302-266-9121 • 454-8720 (FAX)
 WWW.ATLANTICCOASTLABS.COM

Maryland Environmental Services (A)

Order Number: A08070610

Sample # A08070610-01

Sample Date: 7/9/2008 10:37

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

Test	Result	Units	RDL	Method	Analysis Date	Analyst
4-Methyl-2-Pentanone (MIBK)	<10	ug/L	10	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Acetone	<10	ug/L	10	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Acrolein	<50	ug/L	50	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Acrylonitrile	<50	ug/L	50	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Benzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Bromobenzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Bromochloromethane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Bromodichloromethane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Bromoform	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Bromomethane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Carbon Disulfide	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Carbon Tetrachloride	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Chlorobenzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Chloroethane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Chloroform	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Chloromethane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
cis-1,2-Dichloroethene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
cis-1,3-Dichloropropene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Dibromochloromethane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Dibromomethane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Dichlorodifluoromethane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Dichlorofluoromethane	<10	ug/L	10	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Ethyl methacrylate	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Ethylbenzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Hexachlorobutadiene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Isopropylbenzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
m,p-Xylene	<2	ug/L	2	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Methyl Iodide (Iodomethane)	<10	ug/L	10	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Methyl methacrylate	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Methylene Chloride	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Methyl-tert-butyl ether	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Naphthalene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
n-Butylbenzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
n-Propylbenzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
o-Xylene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
sec-Butylbenzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells

Approved:

Warren Van Arsdale
 Quality Assurance Manager

Reported:

7/23/2008 8:41:52 AM

RDL = Reporting Detection Limit N/A = Not Applicable

Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568

Maryland Environmental Services (A)

Order Number: A08070610

Sample # A08070610-01

Sample Date: 7/9/2008 10:37

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Styrene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
tert-Amyl methyl ether (TAME)	<10	ug/L	10	EPA 8260B	7/17/2008 6:37:00 AM	WWells
tert-Butyl alcohol (TBA)	<10	ug/L	10	EPA 8260B	7/17/2008 6:37:00 AM	WWells
tert-Butylbenzene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Tetrachloroethene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Toluene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
trans-1,2-Dichloroethene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
trans-1,3-Dichloropropene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
trans-1,4-Dichloro-2-butene	<2	ug/L	2	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Trichloroethene	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Trichlorofluoromethane	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Vinyl Acetate	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Vinyl Chloride	<1	ug/L	1	EPA 8260B	7/17/2008 6:37:00 AM	WWells
Xylenes, Total	<2	ug/L	2	EPA 8260B	7/17/2008 6:37:00 AM	WWells

Sample # A08070610-01A

Sample Date: 7/9/2008 10:37

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID: A

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
BOD-5	5	mg/L	2	SM 5210 B	7/10/2008 12:00:00 PM	JMcGuire
Total Suspended Solids	14	mg/L	4	SM 2540D	7/11/2008 7:18:00 PM	JMcGuire

Sample # A08070610-01B

Sample Date: 7/9/2008 10:37

Site: Black & Decker 001

Matrix: Waste Water

Client Sample ID: B

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	<5	mg/L	5	EPA 1664	7/10/2008 12:33:00 PM	HHerman

Approved:



Quality Assurance Manager

Reported:

7/23/2008 8:41:53 AM



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A08070609
Project Name: Black & Decker WWTP
Receive Date: 7/9/2008
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A08070609-01

Sample Date: 7/9/2008

Site: Black & Decker 201

Matrix: Waste Water

Client Sample ID:

Sample Comments: None

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	7/17/2008 7:11:00 AM	WWells
Tetrachloroethene	<1	ug/L	1	EPA 8260B	7/17/2008 7:11:00 AM	WWells
Trichloroethene	<1	ug/L	1	EPA 8260B	7/17/2008 7:11:00 AM	WWells

Approved:


Quality Assurance Manager

Reported:

7/17/2008 12:46:30 PM

RDL = Reporting Detection Limit N/A = Not Applicable

Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



ATLANTIC COAST
Laboratories, Incorporated

630 Churchmans Road
Newark, Delaware 19702
302-266-9121 • 454-8720 (FAX)
WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A08080703
Project Name: Black & Decker WWTP
Receive Date: 8/13/2008
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A08080703-01

Sample Date: 8/13/2008 10:20

Site: Black & Decker 001
Client Sample ID:
Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
BOD-5	4	mg/L	2	SM 5210 B	8/14/2008 11:30:00 AM	JMcGuire
Total Suspended Solids	12	mg/L	4	SM 2540D	8/15/2008 4:24:00 PM	JMcGuire

Sample # A08080703-01A

Sample Date: 8/13/2008 10:20

Site: Black & Decker 001
Client Sample ID: A
Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
Oil and Grease (HEM)	<5	mg/L	5	EPA 1664	8/14/2008 12:47:00 PM	HHerman

Sample # A08080703-01B

Sample Date: 8/13/2008 10:20

Site: Black & Decker 001
Client Sample ID: B
Sample Comments: None

Matrix: Waste Water

Test	Result	Units	RDL	Method	Analysis Date	Analyst
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	8/16/2008 6:36:00 AM	WWells
Tetrachloroethene	<1	ug/L	1	EPA 8260B	8/16/2008 6:36:00 AM	WWells
Trichloroethene	<1	ug/L	1	EPA 8260B	8/16/2008 6:36:00 AM	WWells

Approved:
Quality Assurance Manager

Reported: 8/24/2008 1:08:58 PM

RDL = Reporting Detection Limit N/A = Not Applicable
Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



REPORT OF ANALYSIS

Maryland Environmental Services (A)
259 Najoles Road
Millersville, MD 21108

Order Number: A08090221
Project Name: Black & Decker WWTP
Receive Date: 9/3/2008
Client Code: MES_A
Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A08090221-01 **Sample Date: 9/3/2008 9:25**

Site: Black & Decker 001
Client Sample ID:
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
BOD-5	<2	mg/L	2	SM 5210 B	9/4/2008 12:30:00 PM	JMcGuire
Total Suspended Solids	6	mg/L	4	SM 2540D	9/8/2008 12:49:00 PM	JMcGuire

Sample # A08090221-01A **Sample Date: 9/3/2008 9:25**

Site: Black & Decker 001
Client Sample ID: A
Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
Oil and Grease (HEM)	<5	mg/L	5	EPA 1664	9/5/2008 10:44:00 AM	HHerman

Sample # A08090221-01B **Sample Date: 9/3/2008 9:25**

Site: Black & Decker 001
Client Sample ID: B
Sample Comments: None


Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	9/9/2008 3:03:00 AM	WWells
Tetrachloroethene	<1	ug/L	1	EPA 8260B	9/9/2008 3:03:00 AM	WWells
Trichloroethene	<1	ug/L	1	EPA 8260B	9/9/2008 3:03:00 AM	WWells

Approved: *Warren Van Arsdale*
Quality Assurance Manager

Reported: 9/16/2008 12:42:55 PM

RDL = Reporting Detection Limit N/A = Not Applicable
Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568



630 Churchmans Road
 Newark, Delaware 19702
 302-266-9121 • 454-8720 (FAX)
 WWW.ATLANTICCOASTLABS.COM

REPORT OF ANALYSIS

Maryland Environmental Services (A)
 259 Najoles Road
 Millersville, MD 21108

Order Number: A08090219
 Project Name: Black & Decker WWTP
 Receive Date: 9/3/2008
 Client Code: MES_A
 Project Location: Black & Decker WWTP

Attention: Mr. Jay Janney

Sample # A08090219-01 **Sample Date: 9/3/2008 9:40**

Site: Black & Decker 201
 Client Sample ID:
 Sample Comments: None

Matrix: Waste Water

<u>Test</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Analyst</u>
1,1,1-Trichloroethane	<1	ug/L	1	EPA 8260B	9/9/2008 2:31:00 AM	WWells
Tetrachloroethene	<1	ug/L	1	EPA 8260B	9/9/2008 2:31:00 AM	WWells
Trichloroethene	<1	ug/L	1	EPA 8260B	9/9/2008 2:31:00 AM	WWells

Approved: *Walter Van Arsdale*
 Quality Assurance Manager

Reported: 9/10/2008 2:05:51 PM

RDL = Reporting Detection Limit N/A = Not Applicable
 Laboratory Certification Numbers: Delaware - DE00011 Maryland - #138 Pennsylvania - 68-335 New Jersey - DE568

APPENDIX D
GROUNDWATER ANALYTICAL DATA PACKAGE
(AUGUST 2008)

ANALYTICAL REPORT

Job Number: 500-13672-1

Job Description: Black and Decker

For:

Weston Solutions, Inc.

1400 Weston Way

PO BOX 2653

West Chester, PA 19380

Attention: Mr. Tom Cornuet



Richard C Wright

Project Manager II

richard.wright@testamericainc.com

09/10/2008

These test results meet all the requirements of NELAC for accredited parameters.

The Lab Certification ID# is 100201.

All questions regarding this test report should be directed to the TestAmerica Project Manager whose signature appears on this report. All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.

Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.

TestAmerica Laboratories, Inc.

TestAmerica Chicago 2417 Bond Street, University Park, IL 60466

Tel (708) 534-5200 Fax (708) 534-5211 www.testamericainc.com



Job Narrative
500-J13672-1

Comments

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

GC/MS VOA

Method(s) 8260B: The following sample(s) was diluted due to the abundance of target analytes: EW-2 (500-13672-16), EW-4 (500-13672-18), RFW-12B (500-13672-13). Elevated reporting limits (RLs) are provided.

Method(s) 8260B: Surrogate recovery for the following sample(s) was outside control limits: EW-10 (500-13672-24), EW-2 (500-13672-16), EW-3 (500-13672-17), EW-4 (500-13672-18), EW-5 (500-13672-19), EW-6 (500-13672-20), EW-7 (500-13672-21), EW-9 (500-13672-23), EW-9 DUP (500-13672-25). Re-extraction and/or re-analysis was performed with concurring results. The original analysis has been reported.

No other analytical or quality issues were noted.

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-13672-2 Acetone	RFW-1B	6.5	5.0	ug/L	8260B
500-13672-3 Trichloroethene	RFW-2A	1.5	1.0	ug/L	8260B
500-13672-4 Trichloroethene	RFW-2B	1.7	1.0	ug/L	8260B
500-13672-5 cis-1,2-Dichloroethene Tetrachloroethene	RFW-3B	4.5 1.7	1.0 1.0	ug/L ug/L	8260B 8260B
500-13672-6 Chloroform Trichloroethene Tetrachloroethene	RFW-4A	1.3 29 21	1.0 1.0 1.0	ug/L ug/L ug/L	8260B 8260B 8260B
500-13672-7 Chloroform Trichloroethene Tetrachloroethene	RFW-4A DUP	1.2 28 20	1.0 1.0 1.0	ug/L ug/L ug/L	8260B 8260B 8260B
500-13672-8 cis-1,2-Dichloroethene Trichloroethene Tetrachloroethene	RFW-4B	3.7 16 35	1.0 1.0 1.0	ug/L ug/L ug/L	8260B 8260B 8260B
500-13672-9 Trichloroethene Tetrachloroethene	RFW-6	4.8 3.9	1.0 1.0	ug/L ug/L	8260B 8260B
500-13672-10 Trichloroethene	RFW-7	10	1.0	ug/L	8260B

TestAmerica Chicago

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Lab Sample ID Analyte	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-13672-11	RFW-9				
1,1-Dichloroethene		1.4	1.0	ug/L	8260B
1,1-Dichloroethane		1.1	1.0	ug/L	8260B
cis-1,2-Dichloroethene		14	1.0	ug/L	8260B
1,1,1-Trichloroethane		1.6	1.0	ug/L	8260B
Trichloroethene		17	1.0	ug/L	8260B
Tetrachloroethene		6.7	1.0	ug/L	8260B
500-13672-12	RFW-11B				
Trichloroethene		13	1.0	ug/L	8260B
500-13672-13	RFW-12B				
cis-1,2-Dichloroethene		2.1	2.0	ug/L	8260B
Trichloroethene		430	20	ug/L	8260B
Tetrachloroethene		36	2.0	ug/L	8260B
500-13672-14	RFW-13				
Trichloroethene		5.5	1.0	ug/L	8260B
Tetrachloroethene		24	1.0	ug/L	8260B
500-13672-15	RFW-17				
Benzene		1.3	1.0	ug/L	8260B
500-13672-16	EW-2				
cis-1,2-Dichloroethene		3.1	2.0	ug/L	8260B
Trichloroethene		350	20	ug/L	8260B
Tetrachloroethene		74	2.0	ug/L	8260B
500-13672-17	EW-3				
cis-1,2-Dichloroethene		2.4	1.0	ug/L	8260B
Trichloroethene		150	10	ug/L	8260B
Tetrachloroethene		3.6	1.0	ug/L	8260B
500-13672-18	EW-4				
Trichloroethene		1600	100	ug/L	8260B
Tetrachloroethene		36	10	ug/L	8260B

TestAmerica Chicago

EXECUTIVE SUMMARY - Detections

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Lab Sample ID	Client Sample ID	Result / Qualifier	Reporting Limit	Units	Method
500-13672-19	EW-5				
1,1,1-Trichloroethane		1.8	1.0	ug/L	8260B
Trichloroethene		250	10	ug/L	8260B
Tetrachloroethene		15	1.0	ug/L	8260B
500-13672-20	EW-6				
Trichloroethene		12	1.0	ug/L	8260B
Tetrachloroethene		21	1.0	ug/L	8260B
500-13672-21	EW-7				
Trichlorofluoromethane		1.1	1.0	ug/L	8260B
1,1-Dichloroethane		1.0	1.0	ug/L	8260B
cis-1,2-Dichloroethene		9.8	1.0	ug/L	8260B
Trichloroethene		7.1	1.0	ug/L	8260B
Tetrachloroethene		14	1.0	ug/L	8260B
500-13672-22	EW-8				
1,1-Dichloroethane		1.1	1.0	ug/L	8260B
cis-1,2-Dichloroethene		27	1.0	ug/L	8260B
Trichloroethene		13	1.0	ug/L	8260B
Tetrachloroethene		81	1.0	ug/L	8260B
500-13672-23	EW-9				
Trichloroethene		1.6	1.0	ug/L	8260B
Tetrachloroethene		160	10	ug/L	8260B
500-13672-24	EW-10				
Tetrachloroethene		2.7	1.0	ug/L	8260B
500-13672-25	EW-9 DUP				
Trichloroethene		1.5	1.0	ug/L	8260B
Tetrachloroethene		170	10	ug/L	8260B
500-13672-26	TRIP BLANK				
Methylene Chloride		3.4	2.0	ug/L	8260B

TestAmerica Chicago

METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Description	Lab Location	Method	Preparation Method
Matrix: Water			
VOC	TAL CHI	SW846 8260B	
Purge-and-Trap	TAL CHI		SW846 5030B

Lab References:

TAL CHI = TestAmerica Chicago

Method References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
500-13672-1	RFW-1A	Water	08/27/2008 0945	08/29/2008 1030
500-13672-2	RFW-1B	Water	08/28/2008 0730	08/29/2008 1030
500-13672-3	RFW-2A	Water	08/27/2008 1035	08/29/2008 1030
500-13672-4	RFW-2B	Water	08/27/2008 1110	08/29/2008 1030
500-13672-5	RFW-3B	Water	08/27/2008 1605	08/29/2008 1030
500-13672-6	RFW-4A	Water	08/28/2008 0720	08/29/2008 1030
500-13672-7	RFW-4A DUP	Water	08/28/2008 0720	08/29/2008 1030
500-13672-8	RFW-4B	Water	08/28/2008 0820	08/29/2008 1030
500-13672-9	RFW-6	Water	08/28/2008 0710	08/29/2008 1030
500-13672-10	RFW-7	Water	08/27/2008 1125	08/29/2008 1030
500-13672-11	RFW-9	Water	08/27/2008 1635	08/29/2008 1030
500-13672-12	RFW-11B	Water	08/28/2008 1230	08/29/2008 1030
500-13672-13	RFW-12B	Water	08/28/2008 1215	08/29/2008 1030
500-13672-14	RFW-13	Water	08/28/2008 1050	08/29/2008 1030
500-13672-15	RFW-17	Water	08/27/2008 1158	08/29/2008 1030
500-13672-16	EW-2	Water	08/27/2008 1700	08/29/2008 1030
500-13672-17	EW-3	Water	08/28/2008 1100	08/29/2008 1030
500-13672-18	EW-4	Water	08/28/2008 1030	08/29/2008 1030
500-13672-19	EW-5	Water	08/27/2008 0935	08/29/2008 1030
500-13672-20	EW-6	Water	08/27/2008 1440	08/29/2008 1030
500-13672-21	EW-7	Water	08/27/2008 1445	08/29/2008 1030
500-13672-22	EW-8	Water	08/27/2008 1530	08/29/2008 1030
500-13672-23	EW-9	Water	08/27/2008 1520	08/29/2008 1030
500-13672-24	EW-10	Water	08/27/2008 1510	08/29/2008 1030
500-13672-25	EW-9 DUP	Water	08/27/2008 1520	08/29/2008 1030
500-13672-26	TRIP BLANK	Water	08/27/2008 0800	08/29/2008 1030

SAMPLE RESULTS

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-1A
 Lab Sample ID: 500-13672-1

Date Sampled: 08/27/2008 0945
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/03/2008 2258			
Prep Method: 5030B		Date Prepared: 09/03/2008 2258			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	<1.0	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-1A
 Lab Sample ID: 500-13672-1

Date Sampled: 08/27/2008 0945
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate			Acceptance Limits		
1,2-Dichloroethane-d4 (Surr)	110	%	70 - 125		
Toluene-d8 (Surr)	97	%	75 - 120		
4-Bromofluorobenzene (Surr)	88	%	75 - 120		
Dibromofluoromethane	117	%	75 - 120		

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-1B
 Lab Sample ID: 500-13672-2

Date Sampled: 08/28/2008 0730
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 1316			
Prep Method: 5030B		Date Prepared: 09/04/2008 1316			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0 *	ug/L	0.39	5.0	1.0
Acetone	6.5	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	<1.0	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-1B
 Lab Sample ID: 500-13672-2

Date Sampled: 08/28/2008 0730
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		70 - 125	
Toluene-d8 (Surr)	97	%		75 - 120	
4-Bromofluorobenzene (Surr)	89	%		75 - 120	
Dibromofluoromethane	117	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-2A
 Lab Sample ID: 500-13672-3

Date Sampled: 08/27/2008 1035
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/03/2008 2345			
Prep Method: 5030B		Date Prepared: 09/03/2008 2345			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	1.5	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-2A
 Lab Sample ID: 500-13672-3

Date Sampled: 08/27/2008 1035
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	105	%		70 - 125	
Toluene-d8 (Surr)	98	%		75 - 120	
4-Bromofluorobenzene (Surr)	88	%		75 - 120	
Dibromofluoromethane	114	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-2B
 Lab Sample ID: 500-13672-4

Date Sampled: 08/27/2008 1110
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 0008			
Prep Method: 5030B		Date Prepared: 09/04/2008 0008			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	1.7	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-2B
 Lab Sample ID: 500-13672-4

Date Sampled: 08/27/2008 1110
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		70 - 125	
Toluene-d8 (Surr)	99	%		75 - 120	
4-Bromofluorobenzene (Surr)	88	%		75 - 120	
Dibromofluoromethane	115	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-3B
 Lab Sample ID: 500-13672-5

Date Sampled: 08/27/2008 1605
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 1340			
Prep Method: 5030B		Date Prepared: 09/04/2008 1340			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	4.5	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	<1.0	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	1.7	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-3B
 Lab Sample ID: 500-13672-5

Date Sampled: 08/27/2008 1605
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	111	%		70 - 125	
Toluene-d8 (Surr)	98	%		75 - 120	
4-Bromofluorobenzene (Surr)	90	%		75 - 120	
Dibromofluoromethane	114	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-4A
 Lab Sample ID: 500-13672-6

Date Sampled: 08/28/2008 0720
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 0054			
Prep Method: 5030B		Date Prepared: 09/04/2008 0054			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	1.3	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	29	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	21	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-4A
 Lab Sample ID: 500-13672-6

Date Sampled: 08/28/2008 0720
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	111	%		70 - 125	
Toluene-d8 (Surr)	100	%		75 - 120	
4-Bromofluorobenzene (Surr)	89	%		75 - 120	
Dibromofluoromethane	119	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-4A DUP
 Lab Sample ID: 500-13672-7

Date Sampled: 08/28/2008 0720
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 0117			
Prep Method: 5030B		Date Prepared: 09/04/2008 0117			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	1.2	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	28	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	20	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-4A DUP
 Lab Sample ID: 500-13672-7

Date Sampled: 08/28/2008 0720
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate			Acceptance Limits		
1,2-Dichloroethane-d4 (Surr)	112	%	70 - 125		
Toluene-d8 (Surr)	96	%	75 - 120		
4-Bromofluorobenzene (Surr)	87	%	75 - 120		
Dibromofluoromethane	119	%	75 - 120		

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-4B
 Lab Sample ID: 500-13672-8

Date Sampled: 08/28/2008 0820
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 0140			
Prep Method: 5030B		Date Prepared: 09/04/2008 0140			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	3.7	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	16	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	35	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-4B
 Lab Sample ID: 500-13672-8

Date Sampled: 08/28/2008 0820
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	98	%		75 - 120	
4-Bromofluorobenzene (Surr)	91	%		75 - 120	
Dibromofluoromethane	120	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-6
 Lab Sample ID: 500-13672-9

Date Sampled: 08/28/2008 0710
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 0203			
Prep Method: 5030B		Date Prepared: 09/04/2008 0203			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	4.8	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	3.9	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-6
 Lab Sample ID: 500-13672-9

Date Sampled: 08/28/2008 0710
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	110	%		70 - 125	
Toluene-d8 (Surr)	95	%		75 - 120	
4-Bromofluorobenzene (Surr)	91	%		75 - 120	
Dibromofluoromethane	119	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-7
 Lab Sample ID: 500-13672-10

Date Sampled: 08/27/2008 1125
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Met.iod: 8260B		Date Analyzed: 09/04/2008 0226			
Prep Method: 5030B		Date Prepared: 09/04/2008 0226			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	10	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-7
 Lab Sample ID: 500-13672-10

Date Sampled: 08/27/2008 1125
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	112	%		70 - 125	
Toluene-d8 (Surr)	100	%		75 - 120	
4-Bromofluorobenzene (Surr)	88	%		75 - 120	
Dibromofluoromethane	118	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-9
 Lab Sample ID: 500-13672-11

Date Sampled: 08/27/2008 1635
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 0250			
Prep Method: 5030B		Date Prepared: 09/04/2008 0250			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	1.4	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	1.1	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	14	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	1.6	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	17	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	6.7	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-9
 Lab Sample ID: 500-13672-11

Date Sampled: 08/27/2008 1635
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	111	%		70 - 125	
Toluene-d8 (Surr)	99	%		75 - 120	
4-Bromofluorobenzene (Surr)	88	%		75 - 120	
Dibromofluoromethane	115	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-11B
 Lab Sample ID: 500-13672-12

Date Sampled: 08/28/2008 1230
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 0313			
Prep Method: 5030B		Date Prepared: 09/04/2008 0313			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	13	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-11B
 Lab Sample ID: 500-13672-12

Date Sampled: 08/28/2008 1230
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	107	%		70 - 125	
Toluene-d8 (Surr)	98	%		75 - 120	
4-Bromofluorobenzene (Surr)	91	%		75 - 120	
Dibromofluoromethane	114	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-12B
 Lab Sample ID: 500-13672-13

Date Sampled: 08/28/2008 1215
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 1403			
Prep Method: 5030B		Date Prepared: 09/04/2008 1403			
Benzene	<2.0	ug/L	0.32	2.0	2.0
Dichlorodifluoromethane	<2.0	ug/L	0.58	2.0	2.0
Chloromethane	<2.0	ug/L	0.66	2.0	2.0
Vinyl chloride	<2.0	ug/L	0.46	2.0	2.0
Bromomethane	<2.0	ug/L	0.88	2.0	2.0
Chloroethane	<2.0	ug/L	0.90	2.0	2.0
Trichlorofluoromethane	<2.0	ug/L	0.64	2.0	2.0
1,1-Dichloroethene	<2.0	ug/L	0.44	2.0	2.0
Carbon disulfide	<10	ug/L	0.78	10	2.0
Acetone	<10	ug/L	2.4	10	2.0
Methylene Chloride	<4.0	ug/L	2.0	4.0	2.0
trans-1,2-Dichloroethene	<2.0	ug/L	0.34	2.0	2.0
1,1-Dichloroethane	<2.0	ug/L	0.36	2.0	2.0
2,2-Dichloropropane	<2.0	ug/L	0.60	2.0	2.0
cis-1,2-Dichloroethene	2.1	ug/L	0.42	2.0	2.0
Methyl Ethyl Ketone	<10	ug/L	1.7	10	2.0
Bromochloromethane	<2.0	ug/L	0.66	2.0	2.0
Chloroform	<2.0	ug/L	0.26	2.0	2.0
1,1,1-Trichloroethane	<2.0	ug/L	0.46	2.0	2.0
1,1-Dichloropropene	<2.0	ug/L	0.34	2.0	2.0
Carbon tetrachloride	<2.0	ug/L	0.42	2.0	2.0
1,2-Dichloroethane	<2.0	ug/L	0.44	2.0	2.0
1,2-Dichloropropane	<2.0	ug/L	0.46	2.0	2.0
Dibromomethane	<2.0	ug/L	0.62	2.0	2.0
Bromodichloromethane	<2.0	ug/L	0.36	2.0	2.0
cis-1,3-Dichloropropene	<2.0	ug/L	0.32	2.0	2.0
methyl isobutyl ketone	<10	ug/L	1.2	10	2.0
Toluene	<2.0	ug/L	0.32	2.0	2.0
trans-1,3-Dichloropropene	<2.0	ug/L	0.26	2.0	2.0
1,1,2-Trichloroethane	<2.0	ug/L	0.64	2.0	2.0
Tetrachloroethene	36	ug/L	0.28	2.0	2.0
1,3-Dichloropropane	<2.0	ug/L	0.34	2.0	2.0
2-Hexanone	<10	ug/L	1.5	10	2.0
Dibromochloromethane	<2.0	ug/L	0.38	2.0	2.0
1,2-Dibromoethane	<2.0	ug/L	0.48	2.0	2.0
Chlorobenzene	<2.0	ug/L	0.34	2.0	2.0
1,1,1,2-Tetrachloroethane	<2.0	ug/L	0.36	2.0	2.0
Ethylbenzene	<2.0	ug/L	0.34	2.0	2.0
m&p-Xylene	<4.0	ug/L	0.46	4.0	2.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-12B
 Lab Sample ID: 500-13672-13

Date Sampled: 08/28/2008 1215
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<2.0	ug/L	0.24	2.0	2.0
Styrene	<2.0	ug/L	0.30	2.0	2.0
Bromoform	<2.0	ug/L	0.60	2.0	2.0
Isopropylbenzene	<2.0	ug/L	0.28	2.0	2.0
Bromobenzene	<2.0	ug/L	0.30	2.0	2.0
1,1,2,2-Tetrachloroethane	<2.0	ug/L	0.50	2.0	2.0
1,2,3-Trichloropropane	<2.0	ug/L	0.78	2.0	2.0
N-Propylbenzene	<2.0	ug/L	0.22	2.0	2.0
2-Chlorotoluene	<2.0	ug/L	0.32	2.0	2.0
1,3,5-Trimethylbenzene	<2.0	ug/L	0.28	2.0	2.0
4-Chlorotoluene	<2.0	ug/L	0.28	2.0	2.0
tert-Butylbenzene	<2.0	ug/L	0.26	2.0	2.0
1,2,4-Trimethylbenzene	<2.0	ug/L	0.24	2.0	2.0
sec-Butylbenzene	<2.0	ug/L	0.28	2.0	2.0
1,3-Dichlorobenzene	<2.0	ug/L	0.38	2.0	2.0
p-Isopropyltoluene	<2.0	ug/L	0.24	2.0	2.0
1,4-Dichlorobenzene	<2.0	ug/L	0.30	2.0	2.0
n-Butylbenzene	<2.0	ug/L	0.26	2.0	2.0
1,2-Dichlorobenzene	<2.0	ug/L	0.30	2.0	2.0
1,2-Dibromo-3-Chloropropane	<4.0	ug/L	1.7	4.0	2.0
1,2,4-Trichlorobenzene	<2.0	ug/L	0.40	2.0	2.0
Hexachlorobutadiene	<2.0	ug/L	0.54	2.0	2.0
Naphthalene	<2.0	ug/L	0.64	2.0	2.0
1,2,3-Trichlorobenzene	<2.0	ug/L	0.40	2.0	2.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	112	%		70 - 125	
Toluene-d8 (Surr)	95	%		75 - 120	
4-Bromofluorobenzene (Surr)	89	%		75 - 120	
Dibromofluoromethane	119	%		75 - 120	
Method: 8260B Run Type: DL			Date Analyzed: 09/04/2008 0400		
Prep Method: 5030B			Date Prepared: 09/04/2008 0400		
Trichloroethene	430	ug/L	4.0	20	20
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	109	%		70 - 125	
Toluene-d8 (Surr)	96	%		75 - 120	
4-Bromofluorobenzene (Surr)	88	%		75 - 120	
Dibromofluoromethane	120	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-13
 Lab Sample ID: 500-13672-14

Date Sampled: 08/28/2008 1050
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 0423			
Prep Method: 5030B		Date Prepared: 09/04/2008 0423			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	5.5	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	24	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-13
 Lab Sample ID: 500-13672-14

Date Sampled: 08/28/2008 1050
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	110	%		70 - 125	
Toluene-d8 (Surr)	97	%		75 - 120	
4-Bromofluorobenzene (Surr)	88	%		75 - 120	
Dibromofluoromethane	118	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-17
 Lab Sample ID: 500-13672-15

Date Sampled: 08/27/2008 1158
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 0446			
Prep Method: 5030B		Date Prepared: 09/04/2008 0446			
Benzene	1.3	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	<1.0	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: RFW-17
 Lab Sample ID: 500-13672-15

Date Sampled: 08/27/2008 1158
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	108	%		70 - 125	
Toluene-d8 (Surr)	97	%		75 - 120	
4-Bromofluorobenzene (Surr)	90	%		75 - 120	
Dibromofluoromethane	116	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-2
 Lab Sample ID: 500-13672-16

Date Sampled: 08/27/2008 1700
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 1426			
Prep Method: 5030B		Date Prepared: 09/04/2008 1426			
Benzene	<2.0	ug/L	0.32	2.0	2.0
Dichlorodifluoromethane	<2.0	ug/L	0.58	2.0	2.0
Chloromethane	<2.0	ug/L	0.66	2.0	2.0
Vinyl chloride	<2.0	ug/L	0.46	2.0	2.0
Bromomethane	<2.0	ug/L	0.88	2.0	2.0
Chloroethane	<2.0	ug/L	0.90	2.0	2.0
Trichlorofluoromethane	<2.0	ug/L	0.64	2.0	2.0
1,1-Dichloroethene	<2.0	ug/L	0.44	2.0	2.0
Carbon disulfide	<10	ug/L	0.78	10	2.0
Acetone	<10	ug/L	2.4	10	2.0
Methylene Chloride	<4.0	ug/L	2.0	4.0	2.0
trans-1,2-Dichloroethene	<2.0	ug/L	0.34	2.0	2.0
1,1-Dichloroethane	<2.0	ug/L	0.36	2.0	2.0
2,2-Dichloropropane	<2.0	ug/L	0.60	2.0	2.0
cis-1,2-Dichloroethene	3.1	ug/L	0.42	2.0	2.0
Methyl Ethyl Ketone	<10	ug/L	1.7	10	2.0
Bromochloromethane	<2.0	ug/L	0.66	2.0	2.0
Chloroform	<2.0	ug/L	0.26	2.0	2.0
1,1,1-Trichloroethane	<2.0	ug/L	0.46	2.0	2.0
1,1-Dichloropropene	<2.0	ug/L	0.34	2.0	2.0
Carbon tetrachloride	<2.0	ug/L	0.42	2.0	2.0
1,2-Dichloroethane	<2.0	ug/L	0.44	2.0	2.0
1,2-Dichloropropane	<2.0	ug/L	0.46	2.0	2.0
Dibromomethane	<2.0	ug/L	0.62	2.0	2.0
Bromodichloromethane	<2.0	ug/L	0.36	2.0	2.0
cis-1,3-Dichloropropene	<2.0	ug/L	0.32	2.0	2.0
methyl isobutyl ketone	<10	ug/L	1.2	10	2.0
Toluene	<2.0	ug/L	0.32	2.0	2.0
trans-1,3-Dichloropropene	<2.0	ug/L	0.26	2.0	2.0
1,1,2-Trichloroethane	<2.0	ug/L	0.64	2.0	2.0
Tetrachloroethene	74	ug/L	0.28	2.0	2.0
1,3-Dichloropropane	<2.0	ug/L	0.34	2.0	2.0
2-Hexanone	<10	ug/L	1.5	10	2.0
Dibromochloromethane	<2.0	ug/L	0.38	2.0	2.0
1,2-Dibromoethane	<2.0	ug/L	0.48	2.0	2.0
Chlorobenzene	<2.0	ug/L	0.34	2.0	2.0
1,1,1,2-Tetrachloroethane	<2.0	ug/L	0.36	2.0	2.0
Ethylbenzene	<2.0	ug/L	0.34	2.0	2.0
m&p-Xylene	<4.0	ug/L	0.46	4.0	2.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-2
 Lab Sample ID: 500-13672-16

Date Sampled: 08/27/2008 1700
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<2.0	ug/L	0.24	2.0	2.0
Styrene	<2.0	ug/L	0.30	2.0	2.0
Bromoform	<2.0	ug/L	0.60	2.0	2.0
Isopropylbenzene	<2.0	ug/L	0.28	2.0	2.0
Bromobenzene	<2.0	ug/L	0.30	2.0	2.0
1,1,2,2-Tetrachloroethane	<2.0	ug/L	0.50	2.0	2.0
1,2,3-Trichloropropane	<2.0	ug/L	0.78	2.0	2.0
N-Propylbenzene	<2.0	ug/L	0.22	2.0	2.0
2-Chlorotoluene	<2.0	ug/L	0.32	2.0	2.0
1,3,5-Trimethylbenzene	<2.0	ug/L	0.28	2.0	2.0
4-Chlorotoluene	<2.0	ug/L	0.28	2.0	2.0
tert-Butylbenzene	<2.0	ug/L	0.26	2.0	2.0
1,2,4-Trimethylbenzene	<2.0	ug/L	0.24	2.0	2.0
sec-Butylbenzene	<2.0	ug/L	0.28	2.0	2.0
1,3-Dichlorobenzene	<2.0	ug/L	0.38	2.0	2.0
p-Isopropyltoluene	<2.0	ug/L	0.24	2.0	2.0
1,4-Dichlorobenzene	<2.0	ug/L	0.30	2.0	2.0
n-Butylbenzene	<2.0	ug/L	0.26	2.0	2.0
1,2-Dichlorobenzene	<2.0	ug/L	0.30	2.0	2.0
1,2-Dibromo-3-Chloropropane	<4.0	ug/L	1.7	4.0	2.0
1,2,4-Trichlorobenzene	<2.0	ug/L	0.40	2.0	2.0
Hexachlorobutadiene	<2.0	ug/L	0.54	2.0	2.0
Naphthalene	<2.0	ug/L	0.64	2.0	2.0
1,2,3-Trichlorobenzene	<2.0	ug/L	0.40	2.0	2.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	98	%		75 - 120	
4-Bromofluorobenzene (Surr)	87	%		75 - 120	
Dibromofluoromethane	123	X %		75 - 120	
Method: 8260B Run Type: DL			Date Analyzed: 09/04/2008 1449		
Prep Method: 5030B			Date Prepared: 09/04/2008 1449		
Trichloroethene	350	ug/L	4.0	20	20
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	112	%		70 - 125	
Toluene-d8 (Surr)	98	%		75 - 120	
4-Bromofluorobenzene (Surr)	89	%		75 - 120	
Dibromofluoromethane	119	%		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-3
 Lab Sample ID: 500-13672-17

Date Sampled: 08/28/2008 1100
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 1512			
Prep Method: 5030B		Date Prepared: 09/04/2008 1512			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0 *	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	2.4	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	3.6	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-3
 Lab Sample ID: 500-13672-17

Date Sampled: 08/28/2008 1100
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0

Surrogate	Result	Unit	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	115	%	70 - 125
Toluene-d8 (Surr)	100	%	75 - 120
4-Bromofluorobenzene (Surr)	90	%	75 - 120
Dibromofluoromethane	121 X	%	75 - 120

Method: 8260B Run Type: DL
 Prep Method: 5030B

Date Analyzed: 09/04/2008 1535
 Date Prepared: 09/04/2008 1535

Trichloroethene	150	ug/L	2.0	10	10
-----------------	-----	------	-----	----	----

Surrogate	Result	Unit	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	111	%	70 - 125
Toluene-d8 (Surr)	97	%	75 - 120
4-Bromofluorobenzene (Surr)	87	%	75 - 120
Dibromofluoromethane	117	%	75 - 120

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-4
 Lab Sample ID: 500-13672-18

Date Sampled: 08/28/2008 1030
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 1559			
Prep Method: 5030B		Date Prepared: 09/04/2008 1559			
Benzene	<10	ug/L	1.6	10	10
Dichlorodifluoromethane	<10	ug/L	2.9	10	10
Chloromethane	<10	ug/L	3.3	10	10
Vinyl chloride	<10	ug/L	2.3	10	10
Bromomethane	<10	ug/L	4.4	10	10
Chloroethane	<10	ug/L	4.5	10	10
Trichlorofluoromethane	<10	ug/L	3.2	10	10
1,1-Dichloroethene	<10	ug/L	2.2	10	10
Carbon disulfide	<50 *	ug/L	3.9	50	10
Acetone	<50	ug/L	12	50	10
Methylene Chloride	<20	ug/L	9.9	20	10
trans-1,2-Dichloroethene	<10	ug/L	1.7	10	10
1,1-Dichloroethane	<10	ug/L	1.8	10	10
2,2-Dichloropropane	<10	ug/L	3.0	10	10
cis-1,2-Dichloroethene	<10	ug/L	2.1	10	10
Methyl Ethyl Ketone	<50	ug/L	8.3	50	10
Bromochloromethane	<10	ug/L	3.3	10	10
Chloroform	<10	ug/L	1.3	10	10
1,1,1-Trichloroethane	<10	ug/L	2.3	10	10
1,1-Dichloropropene	<10	ug/L	1.7	10	10
Carbon tetrachloride	<10	ug/L	2.1	10	10
1,2-Dichloroethane	<10	ug/L	2.2	10	10
1,2-Dichloropropane	<10	ug/L	2.3	10	10
Dibromomethane	<10	ug/L	3.1	10	10
Bromodichloromethane	<10	ug/L	1.8	10	10
cis-1,3-Dichloropropene	<10	ug/L	1.6	10	10
methyl isobutyl ketone	<50	ug/L	5.8	50	10
Toluene	<10	ug/L	1.6	10	10
trans-1,3-Dichloropropene	<10	ug/L	1.3	10	10
1,1,2-Trichloroethane	<10	ug/L	3.2	10	10
Tetrachloroethene	36	ug/L	1.4	10	10
1,3-Dichloropropane	<10	ug/L	1.7	10	10
2-Hexanone	<50	ug/L	7.7	50	10
Dibromochloromethane	<10	ug/L	1.9	10	10
1,2-Dibromoethane	<10	ug/L	2.4	10	10
Chlorobenzene	<10	ug/L	1.7	10	10
1,1,1,2-Tetrachloroethane	<10	ug/L	1.8	10	10
Ethylbenzene	<10	ug/L	1.7	10	10
m&p-Xylene	<20	ug/L	2.3	20	10

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-4
 Lab Sample ID: 500-13672-18

Date Sampled: 08/28/2008 1030
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<10	ug/L	1.2	10	10
Styrene	<10	ug/L	1.5	10	10
Bromoform	<10	ug/L	3.0	10	10
Isopropylbenzene	<10	ug/L	1.4	10	10
Bromobenzene	<10	ug/L	1.5	10	10
1,1,2,2-Tetrachloroethane	<10	ug/L	2.5	10	10
1,2,3-Trichloropropane	<10	ug/L	3.9	10	10
N-Propylbenzene	<10	ug/L	1.1	10	10
2-Chlorotoluene	<10	ug/L	1.6	10	10
1,3,5-Trimethylbenzene	<10	ug/L	1.4	10	10
4-Chlorotoluene	<10	ug/L	1.4	10	10
tert-Butylbenzene	<10	ug/L	1.3	10	10
1,2,4-Trimethylbenzene	<10	ug/L	1.2	10	10
sec-Butylbenzene	<10	ug/L	1.4	10	10
1,3-Dichlorobenzene	<10	ug/L	1.9	10	10
p-Isopropyltoluene	<10	ug/L	1.2	10	10
1,4-Dichlorobenzene	<10	ug/L	1.5	10	10
n-Butylbenzene	<10	ug/L	1.3	10	10
1,2-Dichlorobenzene	<10	ug/L	1.5	10	10
1,2-Dibromo-3-Chloropropane	<20	ug/L	8.5	20	10
1,2,4-Trichlorobenzene	<10	ug/L	2.0	10	10
Hexachlorobutadiene	<10	ug/L	2.7	10	10
Naphthalene	<10	ug/L	3.2	10	10
1,2,3-Trichlorobenzene	<10	ug/L	2.0	10	10

Surrogate	Result	Unit	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	111	%	70 - 125
Toluene-d8 (Surr)	100	%	75 - 120
4-Bromofluorobenzene (Surr)	89	%	75 - 120
Dibromofluoromethane	121	X %	75 - 120

Method: 8260B Run Type: DL

Prep Method: 5030B

Date Analyzed: 09/04/2008 1623

Date Prepared: 09/04/2008 1623

Trichloroethene	1600	ug/L	20	100	100
-----------------	------	------	----	-----	-----

Surrogate	Result	Unit	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	116	%	70 - 125
Toluene-d8 (Surr)	100	%	75 - 120
4-Bromofluorobenzene (Surr)	88	%	75 - 120
Dibromofluoromethane	117	%	75 - 120

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-5
 Lab Sample ID: 500-13672-19

Date Sampled: 08/27/2008 0935
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 1646			
Prep Method: 5030B		Date Prepared: 09/04/2008 1646			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0 *	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	1.8	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	15	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-5
 Lab Sample ID: 500-13672-19

Date Sampled: 08/27/2008 0935
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0

Surrogate	Result	Unit	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	115	%	70 - 125
Toluene-d8 (Surr)	101	%	75 - 120
4-Bromofluorobenzene (Surr)	88	%	75 - 120
Dibromofluoromethane	121	X %	75 - 120

Method: 8260B Run Type: DL
 Prep Method: 5030B

Date Analyzed: 09/04/2008 1709
 Date Prepared: 09/04/2008 1709

Trichloroethene	250	ug/L	2.0	10	10
-----------------	-----	------	-----	----	----

Surrogate	Result	Unit	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	112	%	70 - 125
Toluene-d8 (Surr)	96	%	75 - 120
4-Bromofluorobenzene (Surr)	88	%	75 - 120
Dibromofluoromethane	123	X %	75 - 120

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-6
 Lab Sample ID: 500-13672-20

Date Sampled: 08/27/2008 1440
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 1732			
Prep Method: 5030B		Date Prepared: 09/04/2008 1732			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0 *	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	12	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	21	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-6
 Lab Sample ID: 500-13672-20

Date Sampled: 08/27/2008 1440
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	114	%		70 - 125	
Toluene-d8 (Surr)	98	%		75 - 120	
4-Bromofluorobenzene (Surr)	90	%		75 - 120	
Dibromofluoromethane	121	X %		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-7
 Lab Sample ID: 500-13672-21

Date Sampled: 08/27/2008 1445
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 1755			
Prep Method: 5030B		Date Prepared: 09/04/2008 1755			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	1.1	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	9.8	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	7.1	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	14	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-7
 Lab Sample ID: 500-13672-21

Date Sampled: 08/27/2008 1445
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate			Acceptance Limits		
1,2-Dichloroethane-d4 (Surr)	116	%		70 - 125	
Toluene-d8 (Surr)	98	%		75 - 120	
4-Bromofluorobenzene (Surr)	89	%		75 - 120	
Dibromofluoromethane	124	X %		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-8
 Lab Sample ID: 500-13672-22

Date Sampled: 08/27/2008 1530
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 1818			
Prep Method: 5030B		Date Prepared: 09/04/2008 1818			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0 *	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	1.1	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	27	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	13	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	81	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-8
 Lab Sample ID: 500-13672-22

Date Sampled: 08/27/2008 1530
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate			Acceptance Limits		
1,2-Dichloroethane-d4 (Surr)	116	%	70 - 125		
Toluene-d8 (Surr)	98	%	75 - 120		
4-Bromofluorobenzene (Surr)	86	%	75 - 120		
Dibromofluoromethane	119	%	75 - 120		

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-9
 Lab Sample ID: 500-13672-23

Date Sampled: 08/27/2008 1520
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 1904			
Prep Method: 5030B		Date Prepared: 09/04/2008 1904			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	1.6	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-9
 Lab Sample ID: 500-13672-23

Date Sampled: 08/27/2008 1520
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0

Surrogate	Result	Unit	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	115	%	70 - 125
Toluene-d8 (Surr)	98	%	75 - 120
4-Bromofluorobenzene (Surr)	88	%	75 - 120
Dibromofluoromethane	121	X %	75 - 120

Method: 8260B Run Type: DL

Date Analyzed: 09/04/2008 1928

Prep Method: 5030B

Date Prepared: 09/04/2008 1928

Tetrachloroethene	160	ug/L	1.4	10	10
-------------------	-----	------	-----	----	----

Surrogate	Result	Unit	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	117	%	70 - 125
Toluene-d8 (Surr)	99	%	75 - 120
4-Bromofluorobenzene (Surr)	85	%	75 - 120
Dibromofluoromethane	123	X %	75 - 120

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-10
 Lab Sample ID: 500-13672-24

Date Sampled: 08/27/2008 1510
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 1951			
Prep Method: 5030B		Date Prepared: 09/04/2008 1951			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	<1.0	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	2.7	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-10
 Lab Sample ID: 500-13672-24

Date Sampled: 08/27/2008 1510
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate			Acceptance Limits		
1,2-Dichloroethane-d4 (Surr)	115	%		70 - 125	
Toluene-d8 (Surr)	98	%		75 - 120	
4-Bromofluorobenzene (Surr)	87	%		75 - 120	
Dibromofluoromethane	121	X %		75 - 120	

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-9 DUP
 Lab Sample ID: 500-13672-25

Date Sampled: 08/27/2008 1520
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/04/2008 2014			
Prep Method: 5030B		Date Prepared: 09/04/2008 2014			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	<2.0	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	1.5	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: EW-9 DUP
 Lab Sample ID: 500-13672-25

Date Sampled: 08/27/2008 1520
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	112	%	70 - 125
Toluene-d8 (Surr)	94	%	75 - 120
4-Bromofluorobenzene (Surr)	89	%	75 - 120
Dibromofluoromethane	120	%	75 - 120

Method: 8260B Run Type: DL

Date Analyzed: 09/04/2008 2036

Prep Method: 5030B

Date Prepared: 09/04/2008 2036

Tetrachloroethene	170	ug/L	1.4	10
-------------------	-----	------	-----	----

Surrogate			Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	115	%	70 - 125
Toluene-d8 (Surr)	97	%	75 - 120
4-Bromofluorobenzene (Surr)	89	%	75 - 120
Dibromofluoromethane	123	X %	75 - 120

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: TRIP BLANK
 Lab Sample ID: 500-13672-26

Date Sampled: 08/27/2008 0800
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
Method: 8260B		Date Analyzed: 09/08/2008 1730			
Prep Method: 5030B		Date Prepared: 09/08/2008 1730			
Benzene	<1.0	ug/L	0.16	1.0	1.0
Dichlorodifluoromethane	<1.0	ug/L	0.29	1.0	1.0
Chloromethane	<1.0	ug/L	0.33	1.0	1.0
Vinyl chloride	<1.0	ug/L	0.23	1.0	1.0
Bromomethane	<1.0	ug/L	0.44	1.0	1.0
Chloroethane	<1.0	ug/L	0.45	1.0	1.0
Trichlorofluoromethane	<1.0	ug/L	0.32	1.0	1.0
1,1-Dichloroethene	<1.0	ug/L	0.22	1.0	1.0
Carbon disulfide	<5.0	ug/L	0.39	5.0	1.0
Acetone	<5.0	ug/L	1.2	5.0	1.0
Methylene Chloride	3.4	ug/L	0.99	2.0	1.0
trans-1,2-Dichloroethene	<1.0	ug/L	0.17	1.0	1.0
1,1-Dichloroethane	<1.0	ug/L	0.18	1.0	1.0
2,2-Dichloropropane	<1.0	ug/L	0.30	1.0	1.0
cis-1,2-Dichloroethene	<1.0	ug/L	0.21	1.0	1.0
Methyl Ethyl Ketone	<5.0	ug/L	0.83	5.0	1.0
Bromochloromethane	<1.0	ug/L	0.33	1.0	1.0
Chloroform	<1.0	ug/L	0.13	1.0	1.0
1,1,1-Trichloroethane	<1.0	ug/L	0.23	1.0	1.0
1,1-Dichloropropene	<1.0	ug/L	0.17	1.0	1.0
Carbon tetrachloride	<1.0	ug/L	0.21	1.0	1.0
1,2-Dichloroethane	<1.0	ug/L	0.22	1.0	1.0
Trichloroethene	<1.0	ug/L	0.20	1.0	1.0
1,2-Dichloropropane	<1.0	ug/L	0.23	1.0	1.0
Dibromomethane	<1.0	ug/L	0.31	1.0	1.0
Bromodichloromethane	<1.0	ug/L	0.18	1.0	1.0
cis-1,3-Dichloropropene	<1.0	ug/L	0.16	1.0	1.0
methyl isobutyl ketone	<5.0	ug/L	0.58	5.0	1.0
Toluene	<1.0	ug/L	0.16	1.0	1.0
trans-1,3-Dichloropropene	<1.0	ug/L	0.13	1.0	1.0
1,1,2-Trichloroethane	<1.0	ug/L	0.32	1.0	1.0
Tetrachloroethene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichloropropane	<1.0	ug/L	0.17	1.0	1.0
2-Hexanone	<5.0	ug/L	0.77	5.0	1.0
Dibromochloromethane	<1.0	ug/L	0.19	1.0	1.0
1,2-Dibromoethane	<1.0	ug/L	0.24	1.0	1.0
Chlorobenzene	<1.0	ug/L	0.17	1.0	1.0
1,1,1,2-Tetrachloroethane	<1.0	ug/L	0.18	1.0	1.0
Ethylbenzene	<1.0	ug/L	0.17	1.0	1.0

Mr. Tom Cornuet
 Weston Solutions, Inc.
 1400 Weston Way
 PO BOX 2653
 West Chester, PA 19380

Job Number: 500-13672-1

Client Sample ID: TRIP BLANK
 Lab Sample ID: 500-13672-26

Date Sampled: 08/27/2008 0800
 Date Received: 08/29/2008 1030
 Client Matrix: Water

Analyte	Result/Qualifier	Unit	MDL	RL	Dilution
m&p-Xylene	<2.0	ug/L	0.23	2.0	1.0
o-Xylene	<1.0	ug/L	0.12	1.0	1.0
Styrene	<1.0	ug/L	0.15	1.0	1.0
Bromoform	<1.0	ug/L	0.30	1.0	1.0
Isopropylbenzene	<1.0	ug/L	0.14	1.0	1.0
Bromobenzene	<1.0	ug/L	0.15	1.0	1.0
1,1,2,2-Tetrachloroethane	<1.0	ug/L	0.25	1.0	1.0
1,2,3-Trichloropropane	<1.0	ug/L	0.39	1.0	1.0
N-Propylbenzene	<1.0	ug/L	0.11	1.0	1.0
2-Chlorotoluene	<1.0	ug/L	0.16	1.0	1.0
1,3,5-Trimethylbenzene	<1.0	ug/L	0.14	1.0	1.0
4-Chlorotoluene	<1.0	ug/L	0.14	1.0	1.0
tert-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2,4-Trimethylbenzene	<1.0	ug/L	0.12	1.0	1.0
sec-Butylbenzene	<1.0	ug/L	0.14	1.0	1.0
1,3-Dichlorobenzene	<1.0	ug/L	0.19	1.0	1.0
p-Isopropyltoluene	<1.0	ug/L	0.12	1.0	1.0
1,4-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
n-Butylbenzene	<1.0	ug/L	0.13	1.0	1.0
1,2-Dichlorobenzene	<1.0	ug/L	0.15	1.0	1.0
1,2-Dibromo-3-Chloropropane	<2.0	ug/L	0.85	2.0	1.0
1,2,4-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Hexachlorobutadiene	<1.0	ug/L	0.27	1.0	1.0
Naphthalene	<1.0	ug/L	0.32	1.0	1.0
1,2,3-Trichlorobenzene	<1.0	ug/L	0.20	1.0	1.0
Surrogate				Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)	119	%		70 - 125	
Toluene-d8 (Surr)	98	%		75 - 120	
4-Bromofluorobenzene (Surr)	98	%		75 - 120	
Dibromofluoromethane	112	%		75 - 120	

DATA REPORTING QUALIFIERS

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

<u>Lab Section</u>	<u>Qualifier</u>	<u>Description</u>
GC/MS VOA	*	LCS or LCSD exceeds the control limits
	X	Surrogate exceeds the control limits

QUALITY CONTROL RESULTS

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

QC Association Summary

Lab Sample ID	Client Sample ID	Report Basis	Client Matrix	Method	Prep Batch
GC/MS VOA					
Analysis Batch:500-46522					
LCS 500-46522/4	Lab Control Spike	T	Water	8260B	
LCSD 500-46522/5	Lab Control Spike Duplicate	T	Water	8260B	
MB 500-46522/3	Method Blank	T	Water	8260B	
500-13672-1	RFW-1A	T	Water	8260B	
500-13672-3	RFW-2A	T	Water	8260B	
500-13672-4	RFW-2B	T	Water	8260B	
500-13672-6	RFW-4A	T	Water	8260B	
500-13672-7	RFW-4A DUP	T	Water	8260B	
500-13672-8	RFW-4B	T	Water	8260B	
500-13672-9	RFW-6	T	Water	8260B	
500-13672-10	RFW-7	T	Water	8260B	
500-13672-11	RFW-9	T	Water	8260B	
500-13672-12	RFW-11B	T	Water	8260B	
500-13672-13DL	RFW-12B	T	Water	8260B	
500-13672-14	RFW-13	T	Water	8260B	
500-13672-15	RFW-17	T	Water	8260B	
Analysis Batch:500-46648					
LCS 500-46648/6	Lab Control Spike	T	Water	8260B	
MB 500-46648/5	Method Blank	T	Water	8260B	
500-13672-2	RFW-1B	T	Water	8260B	
500-13672-5	RFW-3B	T	Water	8260B	
500-13672-13	RFW-12B	T	Water	8260B	
500-13672-16	EW-2	T	Water	8260B	
500-13672-16DL	EW-2	T	Water	8260B	
500-13672-17	EW-3	T	Water	8260B	
500-13672-17DL	EW-3	T	Water	8260B	
500-13672-18	EW-4	T	Water	8260B	
500-13672-18DL	EW-4	T	Water	8260B	
500-13672-19	EW-5	T	Water	8260B	
500-13672-19DL	EW-5	T	Water	8260B	
500-13672-20	EW-6	T	Water	8260B	
500-13672-21	EW-7	T	Water	8260B	
500-13672-22	EW-8	T	Water	8260B	
500-13672-23	EW-9	T	Water	8260B	
500-13672-23DL	EW-9	T	Water	8260B	
500-13672-24	EW-10	T	Water	8260B	
500-13672-25	EW-9 DUP	T	Water	8260B	
500-13672-25DL	EW-9 DUP	T	Water	8260B	
Analysis Batch:500-46836					
LCS 500-46836/11	Lab Control Spike	T	Water	8260B	
MB 500-46836/10	Method Blank	T	Water	8260B	
500-13672-26	TRIP BLANK	T	Water	8260B	

TestAmerica Chicago

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

QC Association Summary

Lab Sample ID	Client Sample ID	Report Basis	Client Matrix	Method	Prep Batch
---------------	------------------	--------------	---------------	--------	------------

Report Basis

T = Total

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Surrogate Recovery Report

8260B VOC

Client Matrix: Water

Lab Sample ID	Client Sample ID	12DCE %Rec	TOL %Rec	BFB %Rec	DBFM %Rec
500-13672-1	RFW-1A	110	97	88	117
500-13672-2	RFW-1B	109	97	89	117
500-13672-3	RFW-2A	105	98	88	114
500-13672-4	RFW-2B	109	99	88	115
500-13672-5	RFW-3B	111	98	90	114
500-13672-6	RFW-4A	111	100	89	119
500-13672-7	RFW-4A DUP	112	96	87	119
500-13672-8	RFW-4B	114	98	91	120
500-13672-9	RFW-6	110	95	91	119
500-13672-10	RFW-7	112	100	88	118
500-13672-11	RFW-9	111	99	88	115
500-13672-12	RFW-11B	107	98	91	114
500-13672-13 DL	RFW-12B DL	109	96	88	120
500-13672-13	RFW-12B	112	95	89	119
500-13672-14	RFW-13	110	97	88	118
500-13672-15	RFW-17	108	97	90	116
500-13672-16	EW-2	114	98	87	123X
500-13672-16 DL	EW-2 DL	112	98	89	119
500-13672-17	EW-3	115	100	90	121X
500-13672-17 DL	EW-3 DL	111	97	87	117
500-13672-18	EW-4	111	100	89	121X
500-13672-18 DL	EW-4 DL	116	100	88	117
500-13672-19	EW-5	115	101	88	121X
500-13672-19 DL	EW-5 DL	112	96	88	123X
500-13672-20	EW-6	114	98	90	121X
500-13672-21	EW-7	116	98	89	124X
500-13672-22	EW-8	116	98	86	119
500-13672-23	EW-9	115	98	88	121X
500-13672-23 DL	EW-9 DL	117	99	85	123X

Surrogate	Acceptance Limits
12DCE = 1,2-Dichloroethane-d4 (Surr)	70-125
TOL = Toluene-d8 (Surr)	75-120
BFB = 4-Bromofluorobenzene (Surr)	75-120
DBFM = Dibromofluoromethane	75-120

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Surrogate Recovery Report

8260B VOC

Client Matrix: Water

Lab Sample ID	Client Sample ID	12DCE %Rec	TOL %Rec	BFB %Rec	DBFM %Rec
500-13672-24	EW-10	115	98	87	121X
500-13672-25	EW-9 DUP	112	94	89	120
500-13672-25 DL	EW-9 DUP DL	115	97	89	123X
500-13672-26	TRIP BLANK	119	98	98	112
MB 500-46522/3		107	100	86	117
MB 500-46648/5		106	96	89	113
MB 500-46836/10		116	99	101	110
LCS 500-46522/4		108	99	100	113
LCS 500-46648/6		106	99	101	114
LCS 500-46836/11		109	100	104	107
LCSD 500-46522/5		108	97	100	117

Surrogate	Acceptance Limits
12DCE = 1,2-Dichloroethane-d4 (Surr)	70-125
TOL = Toluene-d8 (Surr)	75-120
BFB = 4-Bromofluorobenzene (Surr)	75-120
DBFM = Dibromofluoromethane	75-120

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Method Blank - Batch: 500-46522

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-46522/3
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/03/2008 2211
Date Prepared: 09/03/2008 2211

Analysis Batch: 500-46522
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2M0903A.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.16	1.0
Dichlorodifluoromethane	<1.0		0.29	1.0
Chloromethane	<1.0		0.33	1.0
Vinyl chloride	<1.0		0.23	1.0
Bromomethane	<1.0		0.44	1.0
Chloroethane	<1.0		0.45	1.0
Trichlorofluoromethane	<1.0		0.32	1.0
1,1-Dichloroethene	<1.0		0.22	1.0
Carbon disulfide	<5.0		0.39	5.0
Acetone	<5.0		1.2	5.0
Methylene Chloride	<2.0		0.99	2.0
trans-1,2-Dichloroethene	<1.0		0.17	1.0
1,1-Dichloroethane	<1.0		0.18	1.0
2,2-Dichloropropane	<1.0		0.30	1.0
cis-1,2-Dichloroethene	<1.0		0.21	1.0
Methyl Ethyl Ketone	<5.0		0.83	5.0
Bromochloromethane	<1.0		0.33	1.0
Chloroform	<1.0		0.13	1.0
1,1,1-Trichloroethane	<1.0		0.23	1.0
1,1-Dichloropropene	<1.0		0.17	1.0
Carbon tetrachloride	<1.0		0.21	1.0
1,2-Dichloroethane	<1.0		0.22	1.0
Trichloroethene	<1.0		0.20	1.0
1,2-Dichloropropane	<1.0		0.23	1.0
Dibromomethane	<1.0		0.31	1.0
Bromodichloromethane	<1.0		0.18	1.0
cis-1,3-Dichloropropene	<1.0		0.16	1.0
methyl isobutyl ketone	<5.0		0.58	5.0
Toluene	<1.0		0.16	1.0
trans-1,3-Dichloropropene	<1.0		0.13	1.0
1,1,2-Trichloroethane	<1.0		0.32	1.0
Tetrachloroethene	<1.0		0.14	1.0
1,3-Dichloropropane	<1.0		0.17	1.0
2-Hexanone	<5.0		0.77	5.0
Dibromochloromethane	<1.0		0.19	1.0
1,2-Dibromoethane	<1.0		0.24	1.0
Chlorobenzene	<1.0		0.17	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.18	1.0
Ethylbenzene	<1.0		0.17	1.0
m&p-Xylene	<2.0		0.23	2.0
o-Xylene	<1.0		0.12	1.0

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Method Blank - Batch: 500-46522

**Method: 8260B
Preparation: 5030B**

Lab Sample ID: MB 500-46522/3
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/03/2008 2211
Date Prepared: 09/03/2008 2211

Analysis Batch: 500-46522
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2M0903A.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Styrene	<1.0		0.15	1.0
Bromoform	<1.0		0.30	1.0
Isopropylbenzene	<1.0		0.14	1.0
Bromobenzene	<1.0		0.15	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.25	1.0
1,2,3-Trichloropropane	<1.0		0.39	1.0
N-Propylbenzene	<1.0		0.11	1.0
2-Chlorotoluene	<1.0		0.16	1.0
1,3,5-Trimethylbenzene	<1.0		0.14	1.0
4-Chlorotoluene	<1.0		0.14	1.0
tert-Butylbenzene	<1.0		0.13	1.0
1,2,4-Trimethylbenzene	<1.0		0.12	1.0
sec-Butylbenzene	<1.0		0.14	1.0
1,3-Dichlorobenzene	<1.0		0.19	1.0
p-Isopropyltoluene	<1.0		0.12	1.0
1,4-Dichlorobenzene	<1.0		0.15	1.0
n-Butylbenzene	<1.0		0.13	1.0
1,2-Dichlorobenzene	<1.0		0.15	1.0
1,2-Dibromo-3-Chloropropane	<2.0		0.85	2.0
1,2,4-Trichlorobenzene	<1.0		0.20	1.0
Hexachlorobutadiene	<1.0		0.27	1.0
Naphthalene	<1.0		0.32	1.0
1,2,3-Trichlorobenzene	<1.0		0.20	1.0

Surrogate	% Rec	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	107	70 - 125
Toluene-d8 (Surr)	100	75 - 120
4-Bromofluorobenzene (Surr)	86	75 - 120
Dibromofluoromethane	117	75 - 120

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

**Lab Control Spike/
Lab Control Spike Duplicate Recovery Report - Batch: 500-46522**

Method: 8260B

Preparation: 5030B

LCS Lab Sample ID: LCS 500-46522/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/03/2008 2234
Date Prepared: 09/03/2008 2234

Analysis Batch: 500-46522
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2S0903A.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

LCSD Lab Sample ID: LCSD 500-46522/5
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/04/2008 0815
Date Prepared: 09/04/2008 0815

Analysis Batch: 500-46522
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973I
Lab File ID: 2T0903A.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	LCS Qual	LCSD Qual
	LCS	LCSD					
Benzene	88	85	74 - 120	4	20		
Dichlorodifluoromethane	116	114	20 - 171	2	20		
Chloromethane	108	109	38 - 148	1	20		
Vinyl chloride	137	135	49 - 140	1	20		
Bromomethane	130	124	56 - 157	5	20		
Chloroethane	129	130	56 - 140	1	20		
Trichlorofluoromethane	133	127	48 - 134	5	20		
1,1-Dichloroethene	76	79	55 - 121	3	20		
Carbon disulfide	101	100	38 - 135	1	20		
Acetone	113	115	10 - 175	2	20		
Methylene Chloride	97	99	65 - 126	2	20		
trans-1,2-Dichloroethene	90	91	69 - 120	1	20		
1,1-Dichloroethane	101	104	69 - 120	3	20		
2,2-Dichloropropane	86	76	57 - 127	12	20		
cis-1,2-Dichloroethene	99	99	76 - 124	0	20		
Methyl Ethyl Ketone	121	99	28 - 160	20	20		
Bromochloromethane	104	105	67 - 120	1	20		
Chloroform	104	107	70 - 120	3	20		
1,1,1-Trichloroethane	97	97	68 - 125	0	20		
1,1-Dichloropropene	91	90	68 - 120	0	20		
Carbon tetrachloride	85	86	61 - 128	0	20		
1,2-Dichloroethane	95	96	71 - 120	1	20		
Trichloroethene	91	90	69 - 120	0	20		
1,2-Dichloropropane	103	100	75 - 120	3	20		
Dibromomethane	98	97	73 - 120	0	20		
Bromodichloromethane	101	101	79 - 134	0	20		
cis-1,3-Dichloropropene	83	76	64 - 120	9	20		
methyl isobutyl ketone	90	90	38 - 172	0	20		
Toluene	90	90	78 - 120	1	20		
trans-1,3-Dichloropropene	88	84	65 - 120	5	20		
1,1,2-Trichloroethane	115	117	74 - 123	2	20		
Tetrachloroethene	84	78	65 - 120	7	20		

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

**Lab Control Spike/
Lab Control Spike Duplicate Recovery Report - Batch: 500-46522**

**Method: 8260B
Preparation: 5030B**

LCS Lab Sample ID: LCS 500-46522/4
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/03/2008 2234
Date Prepared: 09/03/2008 2234

Analysis Batch: 500-46522
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2S0903A.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

LCSD Lab Sample ID: LCSD 500-46522/5
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/04/2008 0815
Date Prepared: 09/04/2008 0815

Analysis Batch: 500-46522
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2T0903A.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	LCS Qual	LCSD Qual
	LCS	LCSD					
1,3-Dichloropropane	94	93	77 - 120	0	20		
2-Hexanone	86	89	39 - 158	4	20		
Dibromochloromethane	103	102	78 - 126	1	20		
1,2-Dibromoethane	95	94	77 - 120	2	20		
Chlorobenzene	91	89	78 - 120	2	20		
1,1,1,2-Tetrachloroethane	95	97	75 - 121	2	20		
Ethylbenzene	92	91	79 - 120	2	20		
m&p-Xylene	93	90	78 - 120	3	20		
o-Xylene	94	93	79 - 120	2	20		
Styrene	98	96	80 - 121	2	20		
Bromoform	96	92	58 - 122	4	20		
Isopropylbenzene	82	82	67 - 120	1	20		
Bromobenzene	92	90	74 - 120	2	20		
1,1,2,2-Tetrachloroethane	94	95	71 - 120	2	20		
1,2,3-Trichloropropane	101	99	71 - 120	2	20		
N-Propylbenzene	89	87	70 - 122	3	20		
2-Chlorotoluene	91	89	72 - 121	2	20		
1,3,5-Trimethylbenzene	93	92	75 - 120	1	20		
4-Chlorotoluene	92	90	71 - 119	3	20		
tert-Butylbenzene	90	89	74 - 122	1	20		
1,2,4-Trimethylbenzene	96	94	76 - 120	2	20		
sec-Butylbenzene	91	89	66 - 124	2	20		
1,3-Dichlorobenzene	90	87	76 - 120	3	20		
p-Isopropyltoluene	88	85	70 - 120	3	20		
1,4-Dichlorobenzene	88	86	74 - 120	2	20		
n-Butylbenzene	91	86	73 - 127	6	20		
1,2-Dichlorobenzene	91	91	76 - 120	0	20		
1,2-Dibromo-3-Chloropropane	94	102	59 - 120	8	20		
1,2,4-Trichlorobenzene	78	77	49 - 126	1	20		
Hexachlorobutadiene	91	88	52 - 128	4	20		
Naphthalene	75	79	54 - 120	6	20		
1,2,3-Trichlorobenzene	85	87	57 - 121	2	20		

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Lab Control Spike/

Method: 8260B

Lab Control Spike Duplicate Recovery Report - Batch: 500-46522

Preparation: 5030B

LCS Lab Sample ID: LCS 500-46522/4
 Client Matrix: Water
 Dilution: 1.0
 Date Analyzed: 09/03/2008 2234
 Date Prepared: 09/03/2008 2234

Analysis Batch: 500-46522
 Prep Batch: N/A
 Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
 Lab File ID: 2S0903A.D
 Initial Weight/Volume: 10 mL
 Final Weight/Volume: 10 mL

LCSD Lab Sample ID: LCSD 500-46522/5
 Client Matrix: Water
 Dilution: 1.0
 Date Analyzed: 09/04/2008 0815
 Date Prepared: 09/04/2008 0815

Analysis Batch: 500-46522
 Prep Batch: N/A
 Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
 Lab File ID: 2T0903A.D
 Initial Weight/Volume: 10 mL
 Final Weight/Volume: 10 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	LCS Qual	LCSD Qual
	LCS	LCSD					
Surrogate	LCS % Rec		LCSD % Rec	Acceptance Limits			
1,2-Dichloroethane-d4 (Surr)	108		108			70 - 125	
Toluene-d8 (Surr)	99		97			75 - 120	
4-Bromofluorobenzene (Surr)	100		100			75 - 120	
Dibromofluoromethane	113		117			75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Method Blank - Batch: 500-46648

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-46648/5
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/04/2008 1032
Date Prepared: 09/04/2008 1032

Analysis Batch: 500-46648
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2M0904.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.16	1.0
Dichlorodifluoromethane	<1.0		0.29	1.0
Chloromethane	<1.0		0.33	1.0
Vinyl chloride	<1.0		0.23	1.0
Bromomethane	<1.0		0.44	1.0
Chloroethane	<1.0		0.45	1.0
Trichlorofluoromethane	<1.0		0.32	1.0
1,1-Dichloroethene	<1.0		0.22	1.0
Carbon disulfide	<5.0		0.39	5.0
Acetone	<5.0		1.2	5.0
Methylene Chloride	<2.0		0.99	2.0
trans-1,2-Dichloroethene	<1.0		0.17	1.0
1,1-Dichloroethane	<1.0		0.18	1.0
2,2-Dichloropropane	<1.0		0.30	1.0
cis-1,2-Dichloroethene	<1.0		0.21	1.0
Methyl Ethyl Ketone	<5.0		0.83	5.0
Bromochloromethane	<1.0		0.33	1.0
Chloroform	<1.0		0.13	1.0
1,1,1-Trichloroethane	<1.0		0.23	1.0
1,1-Dichloropropene	<1.0		0.17	1.0
Carbon tetrachloride	<1.0		0.21	1.0
1,2-Dichloroethane	<1.0		0.22	1.0
Trichloroethene	<1.0		0.20	1.0
1,2-Dichloropropane	<1.0		0.23	1.0
Dibromomethane	<1.0		0.31	1.0
Bromodichloromethane	<1.0		0.18	1.0
cis-1,3-Dichloropropene	<1.0		0.16	1.0
methyl isobutyl ketone	<5.0		0.58	5.0
Toluene	<1.0		0.16	1.0
trans-1,3-Dichloropropene	<1.0		0.13	1.0
1,1,2-Trichloroethane	<1.0		0.32	1.0
Tetrachloroethene	<1.0		0.14	1.0
1,3-Dichloropropane	<1.0		0.17	1.0
2-Hexanone	<5.0		0.77	5.0
Dibromochloromethane	<1.0		0.19	1.0
1,2-Dibromoethane	<1.0		0.24	1.0
Chlorobenzene	<1.0		0.17	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.18	1.0
Ethylbenzene	<1.0		0.17	1.0
m&p-Xylene	<2.0		0.23	2.0
o-Xylene	<1.0		0.12	1.0

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Method Blank - Batch: 500-46648

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-46648/5
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/04/2008 1032
Date Prepared: 09/04/2008 1032

Analysis Batch: 500-46648
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2M0904.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Styrene	<1.0		0.15	1.0
Bromoform	<1.0		0.30	1.0
Isopropylbenzene	<1.0		0.14	1.0
Bromobenzene	<1.0		0.15	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.25	1.0
1,2,3-Trichloropropane	<1.0		0.39	1.0
N-Propylbenzene	<1.0		0.11	1.0
2-Chlorotoluene	<1.0		0.16	1.0
1,3,5-Trimethylbenzene	<1.0		0.14	1.0
4-Chlorotoluene	<1.0		0.14	1.0
tert-Butylbenzene	<1.0		0.13	1.0
1,2,4-Trimethylbenzene	<1.0		0.12	1.0
sec-Butylbenzene	<1.0		0.14	1.0
1,3-Dichlorobenzene	<1.0		0.19	1.0
p-Isopropyltoluene	<1.0		0.12	1.0
1,4-Dichlorobenzene	<1.0		0.15	1.0
n-Butylbenzene	<1.0		0.13	1.0
1,2-Dichlorobenzene	<1.0		0.15	1.0
1,2-Dibromo-3-Chloropropane	<2.0		0.85	2.0
1,2,4-Trichlorobenzene	<1.0		0.20	1.0
Hexachlorobutadiene	<1.0		0.27	1.0
Naphthalene	<1.0		0.32	1.0
1,2,3-Trichlorobenzene	<1.0		0.20	1.0

Surrogate	% Rec	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	106	70 - 125
Toluene-d8 (Surr)	96	75 - 120
4-Bromofluorobenzene (Surr)	89	75 - 120
Dibromofluoromethane	113	75 - 120

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Lab Control Spike - Batch: 500-46648

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-46648/6
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/04/2008 1055
Date Prepared: 09/04/2008 1055

Analysis Batch: 500-46648
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2S0904.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	25.0	23.5	94	74 - 120	
Dichlorodifluoromethane	25.0	24.6	99	20 - 171	
Chloromethane	25.0	24.0	96	38 - 148	
Vinyl chloride	25.0	31.0	124	49 - 140	
Bromomethane	25.0	26.2	105	56 - 157	
Chloroethane	25.0	29.2	117	56 - 140	
Trichlorofluoromethane	25.0	29.0	116	48 - 134	
1,1-Dichloroethene	25.0	26.3	105	55 - 121	
Carbon disulfide	25.0	39.4	158	38 - 135	
Acetone	25.0	30.7	123	10 - 175	
Methylene Chloride	25.0	26.9	108	65 - 126	
trans-1,2-Dichloroethene	25.0	26.0	104	69 - 120	
1,1-Dichloroethane	25.0	26.6	106	69 - 120	
2,2-Dichloropropane	25.0	24.1	96	57 - 127	
cis-1,2-Dichloroethene	25.0	25.9	103	76 - 124	
Methyl Ethyl Ketone	25.0	24.5	98	28 - 160	
Bromochloromethane	25.0	23.1	92	67 - 120	
Chloroform	25.0	26.9	107	70 - 120	
1,1,1-Trichloroethane	25.0	25.6	103	68 - 125	
1,1-Dichloropropene	25.0	24.8	99	68 - 120	
Carbon tetrachloride	25.0	24.0	96	61 - 128	
1,2-Dichloroethane	25.0	25.5	102	71 - 120	
Trichloroethene	25.0	23.8	95	69 - 120	
1,2-Dichloropropane	25.0	26.2	105	75 - 120	
Dibromomethane	25.0	26.0	104	73 - 120	
Bromodichloromethane	25.0	26.6	106	79 - 134	
cis-1,3-Dichloropropene	26.9	23.8	89	64 - 120	
methyl isobutyl ketone	25.0	24.7	99	38 - 172	
Toluene	25.0	24.0	96	78 - 120	
trans-1,3-Dichloropropene	24.3	23.6	97	65 - 120	
1,1,2-Trichloroethane	25.0	28.2	113	74 - 123	
Tetrachloroethene	25.0	22.0	88	65 - 120	
1,3-Dichloropropane	25.0	24.4	97	77 - 120	
2-Hexanone	25.0	25.5	102	39 - 158	
Dibromochloromethane	25.0	26.3	105	78 - 126	
1,2-Dibromoethane	25.0	24.8	99	77 - 120	
Chlorobenzene	25.0	23.4	94	78 - 120	
1,1,1,2-Tetrachloroethane	25.0	24.6	98	75 - 121	
Ethylbenzene	25.0	23.7	95	79 - 120	
m&p-Xylene	50.0	48.3	97	78 - 120	
o-Xylene	25.0	24.2	97	79 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Lab Control Spike - Batch: 500-46648

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-46648/6
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/04/2008 1055
Date Prepared: 09/04/2008 1055

Analysis Batch: 500-46648
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890N GC - 5973N
Lab File ID: 2S0904.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Styrene	25.0	25.2	101	80 - 121	
Bromoform	25.0	25.2	101	58 - 122	
Isopropylbenzene	25.0	21.0	84	67 - 120	
Bromobenzene	25.0	22.9	92	74 - 120	
1,1,2,2-Tetrachloroethane	25.0	25.2	101	71 - 120	
1,2,3-Trichloropropane	25.0	26.0	104	71 - 120	
N-Propylbenzene	25.0	22.7	91	70 - 122	
2-Chlorotoluene	25.0	22.7	91	72 - 121	
1,3,5-Trimethylbenzene	25.0	23.5	94	75 - 120	
4-Chlorotoluene	25.0	23.3	93	71 - 119	
tert-Butylbenzene	25.0	22.7	91	74 - 122	
1,2,4-Trimethylbenzene	25.0	24.0	96	76 - 120	
sec-Butylbenzene	25.0	23.2	93	66 - 124	
1,3-Dichlorobenzene	25.0	22.6	90	76 - 120	
p-Isopropyltoluene	25.0	22.1	89	70 - 120	
1,4-Dichlorobenzene	25.0	21.9	87	74 - 120	
n-Butylbenzene	25.0	23.4	93	73 - 127	
1,2-Dichlorobenzene	25.0	23.6	94	76 - 120	
1,2-Dibromo-3-Chloropropane	25.0	26.2	105	59 - 120	
1,2,4-Trichlorobenzene	25.0	20.0	80	49 - 126	
Hexachlorobutadiene	25.0	22.2	89	52 - 128	
Naphthalene	25.0	20.6	82	54 - 120	
1,2,3-Trichlorobenzene	25.0	21.8	87	57 - 121	
Surrogate			% Rec	Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)			106	70 - 125	
Toluene-d8 (Surr)			99	75 - 120	
4-Bromofluorobenzene (Surr)			101	75 - 120	
Dibromofluoromethane			114	75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Method Blank - Batch: 500-46836

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-46836/10
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/08/2008 1057
Date Prepared: 09/08/2008 1057

Analysis Batch: 500-46836
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890A GC - 5973 M
Lab File ID: 22M0908.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Benzene	<1.0		0.16	1.0
Dichlorodifluoromethane	<1.0		0.29	1.0
Chloromethane	<1.0		0.33	1.0
Vinyl chloride	<1.0		0.23	1.0
Bromomethane	<1.0		0.44	1.0
Chloroethane	<1.0		0.45	1.0
Trichlorofluoromethane	<1.0		0.32	1.0
1,1-Dichloroethene	<1.0		0.22	1.0
Carbon disulfide	<5.0		0.39	5.0
Acetone	<5.0		1.2	5.0
Methylene Chloride	<2.0		0.99	2.0
trans-1,2-Dichloroethene	<1.0		0.17	1.0
1,1-Dichloroethane	<1.0		0.18	1.0
2,2-Dichloropropane	<1.0		0.30	1.0
cis-1,2-Dichloroethene	<1.0		0.21	1.0
Methyl Ethyl Ketone	<5.0		0.83	5.0
Bromochloromethane	<1.0		0.33	1.0
Chloroform	<1.0		0.13	1.0
1,1,1-Trichloroethane	<1.0		0.23	1.0
1,1-Dichloropropene	<1.0		0.17	1.0
Carbon tetrachloride	<1.0		0.21	1.0
1,2-Dichloroethane	<1.0		0.22	1.0
Trichloroethene	<1.0		0.20	1.0
1,2-Dichloropropane	<1.0		0.23	1.0
Dibromomethane	<1.0		0.31	1.0
Bromodichloromethane	<1.0		0.18	1.0
cis-1,3-Dichloropropene	<1.0		0.16	1.0
methyl isobutyl ketone	<5.0		0.58	5.0
Toluene	<1.0		0.16	1.0
trans-1,3-Dichloropropene	<1.0		0.13	1.0
1,1,2-Trichloroethane	<1.0		0.32	1.0
Tetrachloroethene	<1.0		0.14	1.0
1,3-Dichloropropane	<1.0		0.17	1.0
2-Hexanone	<5.0		0.77	5.0
Dibromochloromethane	<1.0		0.19	1.0
1,2-Dibromoethane	<1.0		0.24	1.0
Chlorobenzene	<1.0		0.17	1.0
1,1,1,2-Tetrachloroethane	<1.0		0.18	1.0
Ethylbenzene	<1.0		0.17	1.0
m&p-Xylene	<2.0		0.23	2.0
o-Xylene	<1.0		0.12	1.0

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Method Blank - Batch: 500-46836

Method: 8260B
Preparation: 5030B

Lab Sample ID: MB 500-46836/10
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/08/2008 1057
Date Prepared: 09/08/2008 1057

Analysis Batch: 500-46836
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890A GC - 5973 M
Lab File ID: 22M0908.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Result	Qual	MDL	RL
Styrene	<1.0		0.15	1.0
Bromoform	<1.0		0.30	1.0
Isopropylbenzene	<1.0		0.14	1.0
Bromobenzene	<1.0		0.15	1.0
1,1,2,2-Tetrachloroethane	<1.0		0.25	1.0
1,2,3-Trichloropropane	<1.0		0.39	1.0
N-Propylbenzene	<1.0		0.11	1.0
2-Chlorotoluene	<1.0		0.16	1.0
1,3,5-Trimethylbenzene	<1.0		0.14	1.0
4-Chlorotoluene	<1.0		0.14	1.0
tert-Butylbenzene	<1.0		0.13	1.0
1,2,4-Trimethylbenzene	<1.0		0.12	1.0
sec-Butylbenzene	<1.0		0.14	1.0
1,3-Dichlorobenzene	<1.0		0.19	1.0
p-Isopropyltoluene	<1.0		0.12	1.0
1,4-Dichlorobenzene	<1.0		0.15	1.0
n-Butylbenzene	<1.0		0.13	1.0
1,2-Dichlorobenzene	<1.0		0.15	1.0
1,2-Dibromo-3-Chloropropane	<2.0		0.85	2.0
1,2,4-Trichlorobenzene	<1.0		0.20	1.0
Hexachlorobutadiene	<1.0		0.27	1.0
Naphthalene	<1.0		0.32	1.0
1,2,3-Trichlorobenzene	<1.0		0.20	1.0

Surrogate	% Rec	Acceptance Limits
1,2-Dichloroethane-d4 (Surr)	116	70 - 125
Toluene-d8 (Surr)	99	75 - 120
4-Bromofluorobenzene (Surr)	101	75 - 120
Dibromofluoromethane	110	75 - 120

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Lab Control Spike - Batch: 500-46836

Method: 8260B
Preparation: 5030B

Lab Sample ID: LCS 500-46836/11
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/08/2008 1131
Date Prepared: 09/08/2008 1131

Analysis Batch: 500-46836
Prep Batch: N/A
Units: ug/L

Instrument ID: Agilent 6890A GC - 5973 M
Lab File ID: 22S0908.D
Initial Weight/Volume: 10 mL
Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Benzene	25.0	22.0	88	74 - 120	
Dichlorodifluoromethane	25.0	30.4	122	20 - 171	
Chloromethane	25.0	23.1	92	38 - 148	
Vinyl chloride	25.0	28.8	115	49 - 140	
Bromomethane	25.0	28.2	113	56 - 157	
Chloroethane	25.0	26.7	107	56 - 140	
Trichlorofluoromethane	25.0	25.2	101	48 - 134	
1,1-Dichloroethene	25.0	25.0	100	55 - 121	
Carbon disulfide	25.0	23.4	94	38 - 135	
Acetone	25.0	35.0	140	10 - 175	
Methylene Chloride	25.0	22.2	89	65 - 126	
trans-1,2-Dichloroethene	25.0	22.4	90	69 - 120	
1,1-Dichloroethane	25.0	23.2	93	69 - 120	
2,2-Dichloropropane	25.0	24.1	97	57 - 127	
cis-1,2-Dichloroethene	25.0	23.8	95	76 - 124	
Methyl Ethyl Ketone	25.0	24.2	97	28 - 160	
Bromochloromethane	25.0	22.8	91	67 - 120	
Chloroform	25.0	24.1	96	70 - 120	
1,1,1-Trichloroethane	25.0	23.9	96	68 - 125	
1,1-Dichloropropene	25.0	24.1	96	68 - 120	
Carbon tetrachloride	25.0	26.2	105	61 - 128	
1,2-Dichloroethane	25.0	23.1	93	71 - 120	
Trichloroethene	25.0	21.9	87	69 - 120	
1,2-Dichloropropane	25.0	23.4	93	75 - 120	
Dibromomethane	25.0	22.5	90	73 - 120	
Bromodichloromethane	25.0	24.3	97	79 - 134	
cis-1,3-Dichloropropene	26.9	22.8	85	64 - 120	
methyl isobutyl ketone	25.0	20.0	80	38 - 172	
Toluene	25.0	21.3	85	78 - 120	
trans-1,3-Dichloropropene	24.3	21.5	88	65 - 120	
1,1,2-Trichloroethane	25.0	23.5	94	74 - 123	
Tetrachloroethene	25.0	20.3	81	65 - 120	
1,3-Dichloropropane	25.0	22.9	91	77 - 120	
2-Hexanone	25.0	20.4	82	39 - 158	
Dibromochloromethane	25.0	21.5	86	78 - 126	
1,2-Dibromoethane	25.0	22.2	89	77 - 120	
Chlorobenzene	25.0	20.4	81	78 - 120	
1,1,1,2-Tetrachloroethane	25.0	22.3	89	75 - 121	
Ethylbenzene	25.0	21.3	85	79 - 120	
m&p-Xylene	50.0	45.6	91	78 - 120	
o-Xylene	25.0	23.3	93	79 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Lab Control Spike - Batch: 500-46836

Method: 8260B

Preparation: 5030B

Lab Sample ID: LCS 500-46836/11
 Client Matrix: Water
 Dilution: 1.0
 Date Analyzed: 09/08/2008 1131
 Date Prepared: 09/08/2008 1131

Analysis Batch: 500-46836
 Prep Batch: N/A
 Units: ug/L

Instrument ID: Agilent 6890A GC - 5973 N
 Lab File ID: 22S0908.D
 Initial Weight/Volume: 10 mL
 Final Weight/Volume: 10 mL

Analyte	Spike Amount	Result	% Rec.	Limit	Qual
Styrene	25.0	22.9	92	80 - 121	
Bromoform	25.0	20.5	82	58 - 122	
Isopropylbenzene	25.0	19.4	78	67 - 120	
Bromobenzene	25.0	20.4	81	74 - 120	
1,1,2,2-Tetrachloroethane	25.0	20.7	83	71 - 120	
1,2,3-Trichloropropane	25.0	20.9	84	71 - 120	
N-Propylbenzene	25.0	22.2	89	70 - 122	
2-Chlorotoluene	25.0	21.8	87	72 - 121	
1,3,5-Trimethylbenzene	25.0	22.6	90	75 - 120	
4-Chlorotoluene	25.0	21.9	88	71 - 119	
tert-Butylbenzene	25.0	21.7	87	74 - 122	
1,2,4-Trimethylbenzene	25.0	22.7	91	76 - 120	
sec-Butylbenzene	25.0	21.6	86	66 - 124	
1,3-Dichlorobenzene	25.0	21.1	84	76 - 120	
p-Isopropyltoluene	25.0	20.6	82	70 - 120	
1,4-Dichlorobenzene	25.0	20.5	82	74 - 120	
n-Butylbenzene	25.0	21.9	88	73 - 127	
1,2-Dichlorobenzene	25.0	21.0	84	76 - 120	
1,2-Dibromo-3-Chloropropane	25.0	21.2	85	59 - 120	
1,2,4-Trichlorobenzene	25.0	16.8	67	49 - 126	
Hexachlorobutadiene	25.0	20.7	83	52 - 128	
Naphthalene	25.0	16.2	65	54 - 120	
1,2,3-Trichlorobenzene	25.0	16.8	67	57 - 121	
Surrogate		% Rec		Acceptance Limits	
1,2-Dichloroethane-d4 (Surr)		109		70 - 125	
Toluene-d8 (Surr)		100		75 - 120	
4-Bromofluorobenzene (Surr)		104		75 - 120	
Dibromofluoromethane		107		75 - 120	

Calculations are performed before rounding to avoid round-off errors in calculated results.

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

2417 Bond Street, University Park, IL 60466
Phone: 708.534.5200 Fax: 708.534.5211

Report To _____ (optional)
Contact: _____
Company: _____
Address: _____
Address: _____
Phone: _____
Fax: _____
E-Mail: _____

Bill To _____ (optional)
Contact: _____
Company: _____
Address: _____
Address: _____
Phone: _____
Fax: _____
PO#Reference# _____

Chain of Custody Record

Lab Job #: 500-13672
Chain of Custody Number: _____
Page 1 of 3
Temperature °C of Cooler: 4.3

09/10/2008

Client		Client Project #		Preservative		Parameter		Matrix		Comments	
Weston Black + Decker		02501.004.004		HCl		VOC				Preservative Key 1. HCL, Cool to 4° 2. H2SO4, Cool to 4° 3. HNO3, Cool to 4° 4. NaOH, Cool to 4° 5. NaOH/Zn, Cool to 4° 6. Cool to 4° 7. None 8. Other	
Project Name		Lab Project #		Sampling		# of Containers		Matrix		Comments	
Black + Decker				Date Time							
Project Location/State		Lab PM									
Hampstead MD		Dick Wright									
Sampler											
Greg Fikuski											
Lab ID	MS/MSO	Sample ID	Date	Time	# of Containers	Matrix					
1		RFW-1A	8/27	0945	3	W	✓				
2		RFW-1B	8/28	0730			✓				
3		RFW-2A	8/27	1035			✓				
4		RFW-2B	8/27	1110			✓				
5		RFW-3B	8/27	1605			✓				
6		RFW-4A	8/28	0720			✓				
7		RFW-4A Dup	8/28	0720			✓				
8		RFW-4B	8/28	0820			✓				
9		RFW-6	8/28	0710			✓				
10		RFW-7	8/27	1125			✓				

Page 80 of 83

Turnaround Time Required (Business Days)

1 Day 2 Days 5 Days 10 days 15 Days Other

Sample Disposal

Return to Client Disposal by Lab Archive for _____ Months

(A fee may be assessed if samples are retained longer than 6 months)

Relinquished By: <u>[Signature]</u>	Company: <u>Weston</u>	Date: <u>8/28/08</u>	Time: <u>1600</u>	Received By: <u>[Signature]</u>	Company: <u>TA</u>	Date: <u>8/29/08</u>	Time: <u>1030</u>
Relinquished By:	Company:	Date:	Time:	Received By:	Company:	Date:	Time:
Relinquished By:	Company:	Date:	Time:	Received By:	Company:	Date:	Time:

Lab Courier: _____
Shipped: FX
Hand Delivered: _____

Matrix Key
WW - Wastewater SE - Sediment
W - Water SO - Soil
S - Soil L - Leachate
SL - Sludge WI - Wipe
MS - Miscellaneous DW - Drinking Water
OL - Oil O - Other
A - Air

Client Comments

Lab Comments:

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

2417 Bond Street, University Park, IL 60466
 Phone: 708.534.5200 Fax: 708.534.5211

Report To _____ (optional)
 Contact: _____
 Company: _____
 Address: _____
 Address: _____
 Phone: _____
 Fax: _____
 E-Mail: _____

Set Page 1

B# To _____ (optional)
 Contact: _____
 Company: _____
 Address: _____
 Address: _____
 Phone: _____
 Fax: _____
 PC#Reference# _____

Chain of Custody Record

Lab Job #: 500-13672
 Chain of Custody Number: _____
 Page 2 of 3
 Temperature °C of Cooler: _____

09/10/2008

Client		Client Project #		Preservative		Parameter												Preservative Key	
Project Name <i>Black Decker</i>		Lab Project #		Sampler <i>Dick Wright</i>		Lab PM												1. HCL, Cool to 4° 2. H2SO4, Cool to 4° 3. HNO3, Cool to 4° 4. NaOH, Cool to 4° 5. NaOH2n, Cool to 4° 6. Cool to 4° 7. None 8. Other	
Lab ID	MS/MSO	Sample ID	Sampling		# of Containers	Matrix											Comments		
			Date	Time															
11		RFW-9	8/27	1635	3	W													
12		RFW-11B	8/28	1230															
13		RFW-12B	8/28	1215															
14		RFW-13	8/28	1050															
15		RFW-17	8/27	1158															
16		EW-2	8/27	1700															
17		EW-3	8/28	1100															
18		EW-4	8/28	1030															
19		EW-5	8/27	935															
20		EW-6	8/27	1440															

VOC

Page 81 of 88

Turnaround Time Required (Business Days): 1 Day 2 Days 5 Days 10 days 15 Days Other

Sample Disposal: Return to Client Disposal by Lab Archive for _____ Months (A fee may be assessed if samples are retained longer than 1 month)

Relinquished By: <i>[Signature]</i>	Company: <i>Western</i>	Date: <i>8/28/08</i>	Time: <i>1600</i>	Received By: <i>[Signature]</i>	Company: <i>TA</i>	Date: <i>8/29/08</i>	Time: <i>1030</i>
Relinquished By:	Company:	Date:	Time:	Received By:	Company:	Date:	Time:
Relinquished By:	Company:	Date:	Time:	Received By:	Company:	Date:	Time:

Lab Courier: _____
 Shipped: *FL*
 Hand Delivered: _____

Matrix Key

WW - Wastewater	SE - Sediment
W - Water	SO - Soil
S - Soil	L - Leachate
SL - Sludge	WI - Wipe
MS - Miscellaneous	DW - Drinking Water
OL - Oil	O - Other
A - Air	

TAL-4124-500 (0306)

Client Comments:

Lab Comments:

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

2417 Bond Street, University Park, IL 60466
 Phone: 708.534.5200 Fax: 708.534.5211

Report To (optional)
 Contact: _____
 Company: *see page 1*
 Address: _____
 Address: _____
 Phone: _____
 Fax: _____
 E-Mail: _____

Bill To (optional)
 Contact: _____
 Company: _____
 Address: _____
 Address: _____
 Phone: _____
 Fax: _____
 PO#/Reference#: _____

Chain of Custody Record

Lab Job #: *500-13672*
 Chain of Custody Number: _____
 Page *3* of *3*
 Temperature °C of Cooler: _____

09/19/2008

Client		Client Project #		Preservative		Parameter	Matrix	# of Containers	Matrix	Comments			
Project Name		Lab Project #		Sampler							Date	Time	Matrix
Project Location/State		Lab PM											
21	EW-7	8/27	1445	3	W	<i>VOU</i>	✓						
22	EW-8	8/27	1530	1			✓						
23	EW-9	8/27	1520	1			✓						
24	EW-10	8/27	1510	1			✓						
25	EW-9 Dup	8/29	1520	1			✓						
26	Trip Blank	8/27	800	2			✓						

Page 82 of 88

- Preservative Key
1. HCL, Cool to 4°
 2. H2SO4, Cool to 4°
 3. HNO3, Cool to 4°
 4. NaOH, Cool to 4°
 5. NaOH/Zn, Cool to 4°
 6. Cool to 4°
 7. None
 8. Other

Turnaround Time Required (Business Days): 1 Day 2 Days 3 Days 10 days 15 Days Other

Sample Disposal: Return to Client Disposal by Lab Archive for _____ Months (A fee may be assessed if samples are retained longer than 1 month)

Relinquished By: <i>[Signature]</i> Company: <i>Wester</i> Date: <i>8/26/08</i> Time: <i>11:00</i>	Received By: <i>[Signature]</i> Company: <i>TA</i> Date: <i>8/27/08</i> Time: <i>10:30</i>	Lab Courier: _____
Relinquished By: _____ Company: _____ Date: _____ Time: _____	Received By: _____ Company: _____ Date: _____ Time: _____	Shipped: <i>FR</i>
Relinquished By: _____ Company: _____ Date: _____ Time: _____	Received By: _____ Company: _____ Date: _____ Time: _____	Hand Delivered: _____

- Matrix Key
- | | |
|-------------------------|---------------------|
| WW - Wastewater | SE - Sediment |
| W - Water | SO - Sol |
| S - Soil | L - Leachate |
| S _s - Sludge | WI - Wipe |
| MS - Miscellaneous | DW - Drinking Water |
| CL - Cl | O - Other |
| A - Air | |

Client Comments: _____

Lab Comments: _____

Login Sample Receipt Check List

Client: Weston Solutions, Inc.

Job Number: 500-13672-1

Login Number: 13672

List Source: TestAmerica Chicago

Creator: Lunt, Jeff T

List Number: 1

Question	T / F / NA	Comment
Radioactivity either was not measured or, if measured, is at or below background	True	
The cooler's custody seal, if present, is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	4.3
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	True	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	

ANALYTICAL REPORT

Job Number: 680-39984-1

Job Description: Black & Decker

For:


Weston Solutions, Inc.

1400 Weston Way

PO BOX 2653

West Chester, PA 19380

Attention: Mr. Tom Cornuet



Abbie Page

Project Manager I

abbie.page@testamericainc.com

09/04/2008

The test results in this report meet all NELAP requirements for parameters for which accreditation is required or available. Any exceptions to NELAP requirements are noted in this report. Pursuant to NELAP, this report may not be reproduced, except in full, without the written approval of the laboratory. All questions regarding this report should be directed to the TestAmerica Project Manager who signed this report.

TestAmerica Laboratories, Inc.

TestAmerica Savannah 5102 LaRoche Avenue, Savannah, GA 31404

Tel (912) 354-7858 Fax (912) 352-0165 www.testamericainc.com



Job Narrative
680-J39984-1

Comments

No additional comments.

Receipt

All samples were received in good condition within temperature requirements.

GC/MS VOA

Method(s) 524.2: The laboratory control standard (LCS) for analyst batch 116134 exceeded control limits for the following analyte: bromomethane. This analyte was biased high in the LCS and was not detected in the associated samples; therefore, the data has been reported.

No other analytical or quality issues were noted.

METHOD SUMMARY

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

Description	Lab Location	Method	Preparation Method
Matrix Water			
Purgeable Organic Compounds in Water by GC/MS	TAL SAV	EPA-DW 524.2	

Lab References:

TAL SAV = TestAmerica Savannah

Method References:

EPA-DW = "Methods For The Determination Of Organic Compounds In Drinking Water", EPA/600/4-88/039, December 1988 And Its Supplements.

SAMPLE SUMMARY

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
680-39984-1	RFW-20	Water	08/27/2008 1415	08/29/2008 0904
680-39984-2	RFW-21	Water	08/27/2008 1250	08/29/2008 0904
680-39984-3TB	Trip Blank	Water	08/27/2008 0800	08/29/2008 0904
680-39984-4	HAMP-22	Water	08/28/2008 0910	08/29/2008 0904
680-39984-5	HAMP-23	Water	08/28/2008 0915	08/29/2008 0904

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

Client Sample ID: RFW-20

Lab Sample ID: 680-39984-1
Client Matrix: Water

Date Sampled: 08/27/2008 1415
Date Received: 08/29/2008 0904

524.2 Purgeable Organic Compounds in Water by GC/MS

Method:	524.2	Analysis Batch: 680-116134	Instrument ID: GC/MS Volatiles - S
Preparation:	N/A		Lab File ID: s090209.d
Dilution:	1.0		Initial Weight/Volume: 5 mL
Date Analyzed:	09/02/2008 1619		Final Weight/Volume: 5 mL
Date Prepared:	N/A		

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0	*	0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.43	1.0

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

Client Sample ID: RFW-20

Lab Sample ID: 680-39984-1

Date Sampled: 08/27/2008 1415

Client Matrix: Water

Date Received: 08/29/2008 0904

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2
 Preparation: N/A
 Dilution: 1.0
 Date Analyzed: 09/02/2008 1619
 Date Prepared: N/A

Analysis Batch: 680-116134

Instrument ID: GC/MS Volatiles - S
 Lab File ID: s090209.d
 Initial Weight/Volume: 5 mL
 Final Weight/Volume: 5 mL

Analyte	Result (ug/L)	Qualifier	MDL	RL
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0		1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,3-Trichlorobenzene	<0.50		0.45	0.50
1,2,4-Trichlorobenzene	<0.50		0.38	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
Trichloroethene	0.59		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50
Surrogate	%Rec		Acceptance Limits	
4-Bromofluorobenzene	107		70 - 130	
1,2-Dichlorobenzene-d4	86		70 - 130	

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

Client Sample ID: RFW-21

Lab Sample ID: 680-39984-2

Date Sampled: 08/27/2008 1250

Client Matrix: Water

Date Received: 08/29/2008 0904

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-116134

Instrument ID: GC/MS Volatiles - S

Preparation: N/A

Lab File ID: s090210.d

Dilution: 1.0

Initial Weight/Volume: 5 mL

Date Analyzed: 09/02/2008 1641

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0	*	0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.43	1.0

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

Client Sample ID: RFW-21

Lab Sample ID: 680-39984-2
 Client Matrix: Water

Date Sampled: 08/27/2008 1250
 Date Received: 08/29/2008 0904

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2
 Preparation: N/A
 Dilution: 1.0
 Date Analyzed: 09/02/2008 1641
 Date Prepared: N/A

Analysis Batch: 680-116134

Instrument ID: GC/MS Volatiles - S
 Lab File ID: s090210.d
 Initial Weight/Volume: 5 mL
 Final Weight/Volume: 5 mL

Analyte	Result (ug/L)	Qualifier	MDL	RL
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0		1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,3-Trichlorobenzene	<0.50		0.45	0.50
1,2,4-Trichlorobenzene	<0.50		0.38	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
Trichloroethene	<0.50		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50
Surrogate	%Rec	Acceptance Limits		
4-Bromofluorobenzene	113	70 - 130		
1,2-Dichlorobenzene-d4	89	70 - 130		

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-39984-3TB

Date Sampled: 08/27/2008 0800

Client Matrix: Water

Date Received: 08/29/2008 0904

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-116134

Instrument ID: GC/MS Volatiles - S

Preparation: N/A

Lab File ID: s090208.d

Dilution: 1.0

Initial Weight/Volume: 5 mL

Date Analyzed: 09/02/2008 1557

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0	*	0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.43	1.0

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

Client Sample ID: Trip Blank

Lab Sample ID: 680-39984-3TB

Date Sampled: 08/27/2008 0800

Client Matrix: Water

Date Received: 08/29/2008 0904

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2
 Preparation: N/A
 Dilution: 1.0
 Date Analyzed: 09/02/2008 1557
 Date Prepared: N/A

Analysis Batch: 680-116134

Instrument ID: GC/MS Volatiles - S
 Lab File ID: s090208.d
 Initial Weight/Volume: 5 mL
 Final Weight/Volume: 5 mL

Analyte	Result (ug/L)	Qualifier	MDL	RL
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0		1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,3-Trichlorobenzene	<0.50		0.45	0.50
1,2,4-Trichlorobenzene	<0.50		0.38	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
Trichloroethene	<0.50		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50

Surrogate	%Rec	Acceptance Limits
4-Bromofluorobenzene	110	70 - 130
1,2-Dichlorobenzene-d4	88	70 - 130

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

Client Sample ID: HAMP-22

Lab Sample ID: 680-39984-4

Date Sampled: 08/28/2008 0910

Client Matrix: Water

Date Received: 08/29/2008 0904

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-116134

Instrument ID: GC/MS Volatiles - S

Preparation: N/A

Lab File ID: s090211.d

Dilution: 1.0

Initial Weight/Volume: 5 mL

Date Analyzed: 09/02/2008 1703

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0	*	0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.43	1.0

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

Client Sample ID: HAMP-22

Lab Sample ID: 680-39984-4

Date Sampled: 08/28/2008 0910

Client Matrix: Water

Date Received: 08/29/2008 0904

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2
 Preparation: N/A
 Dilution: 1.0
 Date Analyzed: 09/02/2008 1703
 Date Prepared: N/A

Analysis Batch: 680-116134

Instrument ID: GC/MS Volatiles - S
 Lab File ID: s090211.d
 Initial Weight/Volume: 5 mL
 Final Weight/Volume: 5 mL

Analyte	Result (ug/L)	Qualifier	MDL	RL
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0		1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,3-Trichlorobenzene	<0.50		0.45	0.50
1,2,4-Trichlorobenzene	<0.50		0.38	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
Trichloroethene	<0.50		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50

Surrogate	%Rec	Acceptance Limits
4-Bromofluorobenzene	112	70 - 130
1,2-Dichlorobenzene-d4	88	70 - 130

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

Client Sample ID: HAMP-23

Lab Sample ID: 680-39984-5

Date Sampled: 08/28/2008 0915

Client Matrix: Water

Date Received: 08/29/2008 0904

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2

Analysis Batch: 680-116134

Instrument ID: GC/MS Volatiles - S

Preparation: N/A

Lab File ID: s090212.d

Dilution: 1.0

Initial Weight/Volume: 5 mL

Date Analyzed: 09/02/2008 1725

Final Weight/Volume: 5 mL

Date Prepared: N/A

Analyte	Result (ug/L)	Qualifier	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0	*	0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
2-Butanone (MEK)	<10		5.0	10
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.43	1.0

Analytical Data

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

Client Sample ID: HAMP-23

Lab Sample ID: 680-39984-5

Date Sampled: 08/28/2008 0915

Client Matrix: Water

Date Received: 08/29/2008 0904

524.2 Purgeable Organic Compounds in Water by GC/MS

Method: 524.2
 Preparation: N/A
 Dilution: 1.0
 Date Analyzed: 09/02/2008 1725
 Date Prepared: N/A

Analysis Batch: 680-116134

Instrument ID: GC/MS Volatiles - S
 Lab File ID: s090212.d
 Initial Weight/Volume: 5 mL
 Final Weight/Volume: 5 mL

Analyte	Result (ug/L)	Qualifier	MDL	RL
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0		1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,3-Trichlorobenzene	<0.50		0.45	0.50
1,2,4-Trichlorobenzene	<0.50		0.38	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
Trichloroethene	<0.50		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50

Surrogate	%Rec	Acceptance Limits
4-Bromofluorobenzene	109	70 - 130
1,2-Dichlorobenzene-d4	88	70 - 130

DATA REPORTING QUALIFIERS

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

Lab Section	Qualifier	Description
GC/MS VOA	*	LCS or LCSD exceeds the control limits

Quality Control Results

Job Number: 680-39984-1

Client: Weston Solutions, Inc.

Surrogate Recovery Report

524.2 Purgeable Organic Compounds in Water by GC/MS

Client Matrix: Water

Lab Sample ID	Client Sample ID	BFB %Rec	12DCB %Rec
680-39984-1	RFW-20	107	86
680-39984-2	RFW-21	113	89
680-39984-3	Trip Blank	110	88
680-39984-4	HAMP-22	112	88
680-39984-5	HAMP-23	109	88
MB 680-116134/26		116	97
LCS 680-116134/24		119	106
LCSD 680-116134/25		119	106

Surrogate	Acceptance Limits
BFB = 4-Bromofluorobenzene	70-130
12DCB = 1,2-Dichlorobenzene-d4	70-130

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

Method Blank - Batch: 680-116134

Method: 524.2

Preparation: N/A

Lab Sample ID: MB 680-116134/26
 Client Matrix: Water
 Dilution: 1.0
 Date Analyzed: 09/02/2008 1241
 Date Prepared: N/A

Analysis Batch: 680-116134
 Prep Batch: N/A
 Units: ug/L

Instrument ID: GC/MS Volatiles - S
 Lab File ID: sq090205.d
 Initial Weight/Volume: 5 mL
 Final Weight/Volume: 5 mL

Analyte	Result	Qual	MDL	RL
Acetone	<10		2.1	10
Benzene	<0.50		0.19	0.50
Bromobenzene	<0.50		0.13	0.50
Bromoform	<0.50		0.17	0.50
Bromomethane	<1.0		0.49	1.0
Carbon tetrachloride	<0.50		0.38	0.50
Chlorobenzene	<0.50		0.19	0.50
Chlorobromomethane	<0.50		0.27	0.50
Chlorodibromomethane	<0.50		0.16	0.50
Chloroethane	<1.0		0.36	1.0
Chloroform	<0.50		0.20	0.50
Chloromethane	<0.50		0.31	0.50
2-Chlorotoluene	<0.50		0.18	0.50
4-Chlorotoluene	<0.50		0.18	0.50
cis-1,2-Dichloroethene	<0.50		0.25	0.50
cis-1,3-Dichloropropene	<0.50		0.16	0.50
1,2-Dibromo-3-Chloropropane	<0.50		0.29	0.50
Dibromomethane	<0.50		0.18	0.50
1,2-Dichlorobenzene	<0.50		0.23	0.50
1,3-Dichlorobenzene	<0.50		0.19	0.50
1,4-Dichlorobenzene	<0.50		0.17	0.50
Dichlorobromomethane	<0.50		0.19	0.50
Dichlorodifluoromethane	<0.50		0.46	0.50
1,1-Dichloroethane	<0.50		0.23	0.50
1,2-Dichloroethane	<0.50		0.19	0.50
1,1-Dichloroethene	<0.50		0.24	0.50
1,2-Dichloropropane	<0.50		0.22	0.50
1,3-Dichloropropane	<0.50		0.19	0.50
2,2-Dichloropropane	<0.50		0.33	0.50
1,1-Dichloropropene	<0.50		0.19	0.50
1,3-Dichloropropene, Total	<0.50		0.37	0.50
Diisopropyl ether	<0.50		0.16	0.50
Ethylbenzene	<0.50		0.18	0.50
Ethylene Dibromide	<0.50		0.27	0.50
Freon 113	<0.50		0.22	0.50
Hexachlorobutadiene	<0.50		0.20	0.50
2-Hexanone	<10		5.0	10
Isopropylbenzene	<0.50		0.15	0.50
4-Isopropyltoluene	<0.50		0.15	0.50
Methylene Chloride	<0.50		0.21	0.50
2-Butanone (MEK)	<10		5.0	10

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

Method Blank - Batch: 680-116134

Method: 524.2
Preparation: N/A

Lab Sample ID: MB 680-116134/26
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/02/2008 1241
Date Prepared: N/A

Analysis Batch: 680-116134
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq090205.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	Result	Qual	MDL	RL
4-Methyl-2-pentanone (MIBK)	<10		5.0	10
m-Xylene & p-Xylene	<0.50		0.34	0.50
Naphthalene	<1.0		0.43	1.0
n-Butylbenzene	<0.50		0.14	0.50
N-Propylbenzene	<0.50		0.19	0.50
o-Xylene	<0.50		0.11	0.50
sec-Butylbenzene	<0.50		0.17	0.50
Styrene	<0.50		0.30	0.50
Tert-amyl methyl ether	<0.50		0.091	0.50
tert-Butyl alcohol	<2.0		1.1	2.0
tert-Butylbenzene	<0.50		0.17	0.50
Tert-butyl ethyl ether	<0.50		0.11	0.50
1,1,1,2-Tetrachloroethane	<0.50		0.20	0.50
1,1,2,2-Tetrachloroethane	<0.50		0.15	0.50
Tetrachloroethene	<0.50		0.22	0.50
Toluene	<0.50		0.21	0.50
trans-1,2-Dichloroethene	<0.50		0.22	0.50
trans-1,3-Dichloropropene	<0.50		0.21	0.50
1,2,3-Trichlorobenzene	<0.50		0.45	0.50
1,2,4-Trichlorobenzene	<0.50		0.38	0.50
1,1,1-Trichloroethane	<0.50		0.16	0.50
1,1,2-Trichloroethane	<0.50		0.25	0.50
Trichloroethene	<0.50		0.20	0.50
Trichlorofluoromethane	<0.50		0.31	0.50
1,2,3-Trichloropropane	<0.50		0.22	0.50
Trihalomethanes, Total	<0.50		0.16	0.50
1,2,4-Trimethylbenzene	<0.50		0.17	0.50
1,3,5-Trimethylbenzene	<0.50		0.17	0.50
Vinyl chloride	<0.50		0.29	0.50
Xylenes, Total	<0.50		0.44	0.50

Surrogate	% Rec	Acceptance Limits
4-Bromofluorobenzene	116	70 - 130
1,2-Dichlorobenzene-d4	97	70 - 130

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

**Lab Control Spike/
Lab Control Spike Duplicate Recovery Report - Batch: 680-116134**

**Method: 524.2
Preparation: N/A**

LCS Lab Sample ID: LCS 680-116134/24
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/02/2008 1104
Date Prepared: N/A

Analysis Batch: 680-116134
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq090203.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

LCSD Lab Sample ID: LCSD 680-116134/25
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/02/2008 1126
Date Prepared: N/A

Analysis Batch: 680-116134
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq090204.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	LCS Qual	LCSD Qual
	LCS	LCSD					
Acetone	93	91	70 - 130	2	30		
Benzene	105	104	70 - 130	1	30		
Bromobenzene	100	99	70 - 130	1	30		
Bromoform	110	107	70 - 130	3	30		
Bromomethane	136	124	70 - 130	9	30	*	
Carbon tetrachloride	120	117	70 - 130	2	30		
Chlorobenzene	100	99	70 - 130	1	30		
Chlorobromomethane	115	116	70 - 130	1	30		
Chlorodibromomethane	109	108	70 - 130	1	30		
Chloroethane	109	115	70 - 130	5	30		
Chloroform	107	105	70 - 130	2	30		
Chloromethane	107	109	70 - 130	2	30		
2-Chlorotoluene	105	104	70 - 130	2	30		
4-Chlorotoluene	107	106	70 - 130	0	30		
cis-1,2-Dichloroethene	101	98	70 - 130	3	30		
cis-1,3-Dichloropropene	108	107	70 - 130	1	30		
1,2-Dibromo-3-Chloropropane	106	106	70 - 130	0	30		
Dibromomethane	106	108	70 - 130	2	30		
1,2-Dichlorobenzene	102	102	70 - 130	0	30		
1,3-Dichlorobenzene	104	103	70 - 130	1	30		
1,4-Dichlorobenzene	105	103	70 - 130	2	30		
Dichlorobromomethane	109	108	70 - 130	0	30		
Dichlorodifluoromethane	93	96	70 - 130	3	30		
1,1-Dichloroethane	105	103	70 - 130	2	30		
1,2-Dichloroethane	110	108	70 - 130	2	30		
1,1-Dichloroethene	99	101	70 - 130	2	30		
1,2-Dichloropropane	104	105	70 - 130	1	30		
1,3-Dichloropropane	103	103	70 - 130	1	30		
2,2-Dichloropropane	118	111	70 - 130	6	30		
1,1-Dichloropropene	107	105	70 - 130	2	30		
1,3-Dichloropropene, Total	110	109	70 - 130	1	30		
Diisopropyl ether	98	97	70 - 130	1	30		

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

**Lab Control Spike/
Lab Control Spike Duplicate Recovery Report - Batch: 680-116134**

**Method: 524.2
Preparation: N/A**

LCS Lab Sample ID: LCS 680-116134/24
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/02/2008 1104
Date Prepared: N/A

Analysis Batch: 680-116134
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq090203.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

LCSD Lab Sample ID: LCSD 680-116134/25
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/02/2008 1126
Date Prepared: N/A

Analysis Batch: 680-116134
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq090204.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	LCS Qual	LCSD Qual
	LCS	LCSD					
Ethylbenzene	103	103	70 - 130	0	30		
Ethylene Dibromide	102	102	70 - 130	1	30		
Freon 113	107	107	70 - 130	1	30		
Hexachlorobutadiene	109	108	70 - 130	1	30		
2-Hexanone	92	94	70 - 130	2	30		
Isopropylbenzene	107	107	70 - 130	0	30		
4-Isopropyltoluene	113	113	70 - 130	1	30		
Methylene Chloride	99	99	70 - 130	0	30		
2-Butanone (MEK)	98	103	70 - 130	5	30		
4-Methyl-2-pentanone (MIBK)	92	93	70 - 130	0	30		
m-Xylene & p-Xylene	100	101	70 - 130	1	30		
Naphthalene	108	107	70 - 130	0	30		
n-Butylbenzene	118	116	70 - 130	2	30		
N-Propylbenzene	111	110	70 - 130	1	30		
o-Xylene	104	103	70 - 130	1	30		
sec-Butylbenzene	112	111	70 - 130	1	30		
Styrene	106	106	70 - 130	0	30		
Tert-amyl methyl ether	96	96	70 - 130	0	30		
tert-Butyl alcohol	87	91	70 - 130	5	30		
tert-Butylbenzene	109	109	70 - 130	0	30		
Tert-butyl ethyl ether	100	99	70 - 130	1	30		
1,1,1,2-Tetrachloroethane	109	107	70 - 130	1	30		
1,1,2,2-Tetrachloroethane	98	99	70 - 130	2	30		
Tetrachloroethene	102	102	70 - 130	0	30		
Toluene	103	98	70 - 130	5	30		
trans-1,2-Dichloroethene	114	115	70 - 130	1	30		
trans-1,3-Dichloropropene	111	111	70 - 130	1	30		
1,2,3-Trichlorobenzene	112	110	70 - 130	2	30		
1,2,4-Trichlorobenzene	90	90	70 - 130	0	30		
1,1,1-Trichloroethane	115	112	70 - 130	3	30		
1,1,2-Trichloroethane	102	101	70 - 130	0	30		
Trichloroethene	105	104	70 - 130	2	30		

Calculations are performed before rounding to avoid round-off errors in calculated results.

Quality Control Results

Client: Weston Solutions, Inc.

Job Number: 680-39984-1

**Lab Control Spike/
Lab Control Spike Duplicate Recovery Report - Batch: 680-116134**

**Method: 524.2
Preparation: N/A**

LCS Lab Sample ID: LCS 680-116134/24
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/02/2008 1104
Date Prepared: N/A

Analysis Batch: 680-116134
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq090203.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

LCSD Lab Sample ID: LCSD 680-116134/25
Client Matrix: Water
Dilution: 1.0
Date Analyzed: 09/02/2008 1126
Date Prepared: N/A

Analysis Batch: 680-116134
Prep Batch: N/A
Units: ug/L

Instrument ID: GC/MS Volatiles - S
Lab File ID: sq090204.d
Initial Weight/Volume: 5 mL
Final Weight/Volume: 5 mL

Analyte	% Rec.		Limit	RPD	RPD Limit	LCS Qual	LCSD Qual
	LCS	LCSD					
Trichlorofluoromethane	116	115	70 - 130	1	30		
1,2,3-Trichloropropane	100	99	70 - 130	0	30		
1,2,4-Trimethylbenzene	112	110	70 - 130	1	30		
1,3,5-Trimethylbenzene	110	109	70 - 130	2	30		
Vinyl chloride	111	107	70 - 130	4	30		
Xylenes, Total	102	102	70 - 130	0	30		
Surrogate	LCS % Rec		LCSD % Rec		Acceptance Limits		
4-Bromofluorobenzene	119		119		70 - 130		
1,2-Dichlorobenzene-d4	106		106		70 - 130		

Calculations are performed before rounding to avoid round-off errors in calculated results.

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

TestAmerica Savannah
5102 LaRoche Avenue
Savannah, GA 31404

Website: www.testamericainc.com
Phone: (912) 354-7858
Fax: (912) 352-0165

Alternate Laboratory Name/Location

Phone:
Fax:

PROJECT REFERENCE Black + Decker	PROJECT NO. 02501-004-004	PROJECT LOCATION (STATE)	MATRIX TYPE	REQUIRED ANALYSIS	PAGE	OF
TAL (LAB) PROJECT MANAGER Abbie Page	P.O. NUMBER	CONTRACT NO.	COMPOSITE (C) OR GRAB (G) INDICATE AQUEOUS (WATER) SOLID OR SEMISOLID AIR NONAQUEOUS LIQUID (OIL, SOLVENT, ...) HC1	PRESERVATIVE	STANDARD REPORT DELIVERY <input type="checkbox"/>	
CLIENT (SITE) PM Greg Flasiuski	CLIENT PHONE 610-701-7293	CLIENT FAX			DATE DUE _____	
CLIENT NAME Black + Decker	CLIENT E-MAIL Greg.Flasiuski@WesternSolutions.com				EXPEDITED REPORT DELIVERY (SURCHARGE) <input type="checkbox"/>	
CLIENT ADDRESS					DATE DUE _____	
COMPANY CONTRACTING THIS WORK (if applicable)				NUMBER OF COOLERS SUBMITTED PER SHIPMENT:		

SAMPLE		SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	SOLID OR SEMISOLID	AIR	NONAQUEOUS LIQUID (OIL, SOLVENT, ...)	NUMBER OF CONTAINERS SUBMITTED	REMARKS
DATE	TIME								
8/27/08	1415	RFW-20					✓		
8/27/08	1250	RFW-21					✓		
8/27/08	800	Trip Blank					✓		
8/28/08	910	HAMP-22					✓		
8/28/08	915	HAMP-23					✓		
TEMP.: <u>4.0</u>									

RELINQUISHED BY: (SIGNATURE) 	DATE 8/28/08	TIME 1600	RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RELINQUISHED BY: (SIGNATURE)	DATE	TIME
RECEIVED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME

LABORATORY USE ONLY							
RECEIVED FOR LABORATORY BY: (SIGNATURE) 	DATE 082908	TIME 0904	CUSTODY INTACT YES <input type="checkbox"/> NO <input type="checkbox"/>	CUSTODY SEAL NO.	SAVANNAH LOG NO. 68039984	LABORATORY REMARKS	

09/04/2008 Page 21 of 22

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

TestAmerica Savannah
 5102 LaRoche Avenue
 Savannah, GA 31404
 Website: www.testamericainc.com
 Phone: (912) 354-7858
 Fax: (912) 352-0165

Alternate Laboratory Name/Location
 Phone:
 Fax:

PROJECT REFERENCE Black + Decker	PROJECT NO. 02501.004.004	PROJECT LOCATION (STATE)	MATRIX TYPE	REQUIRED ANALYSIS								PAGE 1	OF 1
TAL (LAB) PROJECT MANAGER Abbie Page	P.O. NUMBER	CONTRACT NO.	COMPOSITE (C) OR GRAB (G) INDICATE AQUEOUS (WATER) SOLID OR SEMISOLID AIR NONAQUEOUS LIQUID (OIL, SOLVENT, ...)	HCl	PRESERVATIVE							STANDARD REPORT DELIVERY <input type="radio"/>	
CLIENT (SITE) PM Greg Flasiuski	CLIENT PHONE 610.701.7293	CLIENT FAX										DATE DUE _____	
CLIENT NAME Black + Decker	CLIENT E-MAIL Greg.Flasiuski@WesternSolutions.com											EXPEDITED REPORT DELIVERY (SURCHARGE) <input type="radio"/>	
CLIENT ADDRESS												DATE DUE _____	
COMPANY CONTRACTING THIS WORK (if applicable)												NUMBER OF COOLERS SUBMITTED PER SHIPMENT:	

SAMPLE		SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	SOLID OR SEMISOLID	AIR	NONAQUEOUS LIQUID (OIL, SOLVENT, ...)	NUMBER OF CONTAINERS SUBMITTED								REMARKS	
DATE	TIME																
8/27/08	1415	RFW-20						✓									
8/27/08	1250	RFW-21						✓									
8/27/08	800	Trip Blank						✓									
8/28/08	910	HAMP-22						✓									
8/28/08	915	HAMP-23						✓									

TEMP.: 4.0

RELINQUISHED BY: (SIGNATURE) <i>[Signature]</i>	DATE 8/28/08	TIME 1600	RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RELINQUISHED BY: (SIGNATURE)	DATE	TIME
RECEIVED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME

LABORATORY USE ONLY

RECEIVED FOR LABORATORY BY: (SIGNATURE) <i>[Signature]</i>	DATE 082908	TIME 0904	CUSTODY INTACT YES <input type="radio"/> NO <input type="radio"/>	CUSTODY SEAL NO.	SAVANNAH LOG NO. 68739984	LABORATORY REMARKS
---	-----------------------	---------------------	---	------------------	-------------------------------------	--------------------



Weston Solutions, Inc.
1400 Weston Way
P.O. Box 2653
West Chester, Pennsylvania 19380
610-701-3000 • Fax 610-701-3186
www.westonsolutions.com

30 October 2008

Mr. Arthur O'Connell
Waste Management Administration
Maryland Department of the Environment
1800 Washington Blvd
Baltimore, MD 21230

Re: Black & Decker Hampstead Facility

Dear Mr. O'Connell

On behalf of our client, Black & Decker (U.S.) Inc. (Black & Decker), Weston Solutions, Inc. (WESTON®) provides enclosed with this letter two copies of the Quarterly Groundwater Monitoring Report for the period of July through September 2008. This report has been drafted for your review pursuant to the Administrative Consent Order of 13 April 1995.

If you have any questions regarding the enclosure, please contact me at (610) 701-7360.

Very truly yours,

WESTON SOLUTIONS, INC.

A handwritten signature in cursive script that reads "Thomas Cornuet".

Thomas Cornuet, P.G.
Project Manager

Enclosure

cc: L. Biagioni, B&D
J. Freed, B&D
T. Lynch III, M&S
K. Decker, Town of Hampstead
L. Bove, WESTON (w/o encl.)
B. Dietz, MDE (w/o encl.)





Weston Solutions, Inc.
1400 Weston Way
P.O. Box 2653
West Chester, Pennsylvania 19380
610-701-3000 • Fax 610-701-3186
www.westonsolutions.com

30 October 2008

Mr. Charlie Zeleski
Carroll County Health Department
Bureau of Environmental Health
P.O. Box 845
290 S. Center St.
Westminster, MD 21158

Re: Black & Decker Hampstead Facility

Dear Mr. Zeleski:

On behalf of our client, Black & Decker (U.S.) Inc. (Black & Decker), Weston Solutions, Inc. (WESTON®) provides enclosed with this letter a copy of the Quarterly Groundwater Monitoring Report for the period of July through September 2008.

If you have any questions regarding the enclosure, please contact me at (610) 701-7360.

Very truly yours,

WESTON SOLUTIONS, INC.

A handwritten signature in cursive script that reads "Thomas Cornuet".

Thomas Cornuet, P.G.
Project Manager

Enclosure

cc: L. Biagioni, B&D
J. Freed, B&D
T. Lynch III, M&S
L. Bove, WESTON (w/o encl.)

